

NOTES:

1. Year 2026 is the End-Year and should not be used for analysis.

	2007	2010	2015	2020	2026
1. Reserve Margin Capacity WINTER [MW]	906019.	912828.	946046.	1014413.	1109797.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In WINTER [MW]	6454.	6825.	5487.	4990.	9411.
Total R.M. Capacity WINTER [MW]	912473.	919653.	951533.	1019403.	1119208.
2. Peak Load WINTER [MW]	649218.	681168.	729980.	785419.	858871.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out WINTER [MW]	6519.	6894.	5543.	5041.	9506.
Net Demand WINTER [MW]	655738.	688061.	735523.	790460.	868376.
3. Reserve Margin WINTER [%]	40.	34.	30.	29.	29.
1. Reserve Margin Capacity SUMMER [MW]	906018.	912827.	946045.	1014412.	1109799.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In SUMMER [MW]	30052.	29950.	40102.	28570.	33401.
Total R.M. Capacity SUMMER [MW]	936070.	942777.	986147.	1042982.	1143200.
2. Peak Load SUMMER [MW]	724779.	761827.	817715.	881026.	965092.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out SUMMER [MW]	30356.	30252.	40507.	28859.	33738.
Net Demand SUMMER [MW]	755134.	792079.	858222.	909885.	998830.
3. Reserve Margin SUMMER [%]	25.	20.	16.	15.	15.
4. Generation [GWh]	4011982.	4187920.	4499200.	4846920.	5311922.
Inter-Region Transmission [GWh]	-11570.	-11194.	-9747.	-8554.	-8961.
Pumping & Storage Losses [GWh]	21342.	19194.	23560.	21977.	24415.
Plus Purchases [GWh]	0.	0.	0.	0.	0.
Less Sales [GWh]	0.	0.	0.	0.	0.
5. Total Supply for Demand [GWh]	3979070.	4157533.	4465894.	4816389.	5278546.
6. Projected Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
Energy Not Served [GWh]	0.	0.	0.	0.	0.
Less DSM [GWh]	0.	0.	0.	0.	0.
Net Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
7. Dumped Energy [GWh]	-3.	-2.	-4.	-5.	-5.
8. Total Supply for Demand [GWh]	3979070.	4157533.	4465894.	4816389.	5278546.
Less T&D Losses [GWh]	305718.	319430.	343122.	370051.	405559.
9. Total Sales [GWh]	3673352.	3838103.	4122772.	4446338.	4872988.
Capacity Avoided Costs [US\$/kW]	2007	2010	2015	2020	2026
ANNUAL	0.00	0.00	0.00	0.00	0.00
WINTER	0.00	0.00	0.00	0.00	0.00
SUMMER	1.04	0.60	32.71	35.80	34.05

10. Capacity by Plant Type [MW]		2007	2010	2015	2020	2026

Scrubbed Coal_SCR	1	30480.	31476.	31492.	46458.	84862.
Scrubbed Coal_SNCR	2	2280.	1950.	1950.	1950.	1806.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	63809.	50417.	44284.	40881.	32801.
Unscrubbed Coal_SCR	5	51371.	23980.	15376.	10757.	7437.
Unscrubbed Coal_SNCR	6	7457.	6640.	3408.	3228.	2745.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	122188.	106984.	72068.	59378.	41973.
Oil/Gas Steam	9	76774.	75337.	75337.	75337.	75337.
Oil/Gas Steam_SCR	10	8180.	5588.	5588.	5588.	5588.
Oil/Gas Steam_NOx	11	482.	371.	368.	368.	367.
Nuclear	12	100221.	100571.	102123.	102603.	102603.
Hydro	13	89877.	89877.	89877.	89877.	89877.
Comb.Cycle Gas	14	147086.	148565.	180887.	209088.	225499.
IGCC	15	612.	612.	612.	8095.	28623.
Combustion Turbine	16	130223.	129970.	129613.	147201.	164984.
Biomass	17	1358.	1456.	1456.	1456.	1456.
Geothermal	18	3165.	3289.	3399.	3399.	3399.
Landfill Gas	19	549.	581.	1003.	1075.	1080.
Wind	20	6896.	7218.	7297.	7297.	7330.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	449.	465.	494.	494.	494.
Non Fossil_Other	23	2173.	2207.	2207.	2207.	2207.
Fossil_Other	24	566.	566.	566.	566.	566.
Pump Storage	25	19766.	19766.	19766.	19766.	19766.
Int. Imports	26	9000.	9000.	9000.	9000.	9000.
Cgn_CT	27	5542.	5542.	5542.	5542.	5542.
Cgn_CC	28	17845.	17836.	17836.	17833.	17833.
Cgn_Oil/Gas Steam	29	452.	324.	322.	322.	320.
Cgn_Biomass	30	366.	366.	366.	366.	366.
Cgn_Fossil_Other	31	361.	361.	361.	361.	361.
Cgn_NonFossil_Other	32	314.	314.	314.	314.	314.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	915.	915.	915.
Rep.O/G-CC	35	0.	8356.	8370.	8370.	8377.
Rep.Coal-IGCC	36	0.	103.	111.	111.	111.
Ret.Scrubber	37	1707.	3328.	13878.	18778.	13619.
Ret.ExistSCR & Scrub	38	2717.	29518.	37927.	42448.	44549.
Ret.ExistSNCR & Scrub	39	502.	1171.	4135.	4311.	4632.
Ret.SCR	40	11528.	14627.	18461.	10878.	5091.
Ret.ExistScrub & SCR	41	2506.	14437.	20262.	20262.	20271.
Ret.SNCR	42	201.	201.	293.	293.	288.
Ret.ExistScrub & SNCR	43	0.	0.	0.	0.	178.
Ret.SCR+Scrb	44	3074.	12076.	31861.	41714.	46671.
Ret.SNCR+Scrub	45	0.	0.	0.	176.	635.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	24.	24.	5048.	14924.
Ret.ExistScrub&ACI	50	0.	1462.	1769.	5172.	13065.
Ret.ExistSCR&ACI	51	0.	15.	30.	30.	87.
Ret.ExistSNCR&ACI	52	0.	87.	87.	87.	87.
Ret.ACI & SCR	53	0.	0.	0.	0.	1147.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	5.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	280.	280.	280.	10628.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	1095.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	200.	200.	352.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	330.	330.	330.	474.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	2652.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	1227.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	552.	552.	552.	552.
Ret.O/G SNCR	66	760.	760.	760.	760.	760.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2326.	2579.	3114.	3140.	3143.
CC Early Retirement	71	954.	1070.	1563.	1566.	1566.
O/G Early Retirement	72	40615.	41190.	41190.	41190.	41190.
Coal Early Retirement	73	4178.	4655.	4655.	4655.	4738.
Nuke Early Retirement	74	0.	0.	0.	0.	0.

Total		970911.	979364.	1013679.	1082074.	1177566.

11. Capacity Additions and Changes
by Plant Type [MW]

		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	0.	206.	16.	14966.	41056.
Scrubbed Coal_SNCR	2	0.	0.	0.	0.	0.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	0.	0.	0.	0.	0.
Unscrubbed Coal_SCR	5	0.	0.	0.	0.	0.
Unscrubbed Coal_SNCR	6	0.	0.	0.	0.	0.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	0.	0.	0.	0.	0.
Oil/Gas Steam	9	0.	0.	0.	0.	0.
Oil/Gas Steam_SCR	10	0.	0.	0.	0.	0.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	0.	0.	0.	0.	0.
Hydro	13	0.	0.	0.	0.	0.
Comb.Cycle Gas	14	0.	1586.	32815.	28201.	16411.
IGCC	15	0.	0.	0.	7483.	20528.
Combustion Turbine	16	0.	0.	178.	17614.	17786.
Biomass	17	0.	0.	0.	0.	0.
Geothermal	18	0.	0.	0.	0.	0.
Landfill Gas	19	0.	0.	422.	72.	5.
Wind	20	0.	0.	19.	0.	34.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	0.	0.	0.	0.	0.
Non Fossil_Other	23	0.	0.	0.	0.	0.
Fossil_Other	24	0.	0.	0.	0.	0.
Pump Storage	25	0.	0.	0.	0.	0.
Int. Imports	26	0.	0.	0.	0.	0.
Cgn_CT	27	0.	0.	0.	0.	0.
Cgn_CC	28	0.	0.	0.	0.	0.
Cgn_Oil/Gas Steam	29	0.	0.	0.	0.	0.
Cgn_Biomass	30	0.	0.	0.	0.	0.
Cgn_Fossil_Other	31	0.	0.	0.	0.	0.
Cgn_NonFossil_Other	32	0.	0.	0.	0.	0.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	0.	0.	0.
Rep.O/G-CC	35	0.	8356.	14.	0.	7.
Rep.Coal-IGCC	36	0.	103.	8.	0.	0.
Ret.Scrubber	37	1707.	6991.	18528.	5077.	6273.
Ret.ExistSCR & Scrub	38	2717.	26802.	8409.	4521.	3195.
Ret.ExistSNCR & Scrub	39	502.	669.	3164.	176.	473.
Ret.SCR	40	11528.	3699.	6765.	0.	0.
Ret.ExistScrub & SCR	41	2506.	11930.	5825.	0.	9.
Ret.SNCR	42	201.	0.	92.	0.	0.
Ret.ExistScrub & SNCR	43	0.	0.	0.	0.	178.
Ret.SCR+Scrb	44	3074.	9001.	19785.	9854.	6183.
Ret.SNCR+Scrub	45	0.	0.	0.	176.	459.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	24.	0.	5024.	9876.
Ret.ExistScrub&ACI	50	0.	1462.	307.	3403.	7893.
Ret.ExistSCR&ACI	51	0.	15.	15.	0.	56.
Ret.ExistSNCR&ACI	52	0.	87.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	1147.
Ret.ExistScrub&ACI&SNCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	5.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	280.	0.	0.	10348.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	1095.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	200.	0.	153.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	330.	0.	0.	144.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	2652.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	1226.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	552.	0.	0.	0.
Ret.O/G SNCR	66	760.	0.	0.	0.	0.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2326.	253.	535.	26.	3.
CC Early Retirement	71	954.	116.	493.	3.	0.
O/G Early Retirement	72	40615.	575.	0.	0.	0.
Coal Early Retirement	73	4178.	477.	0.	0.	83.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
Total		71068.	74429.	97590.	96596.	147280.

12. Generation by Plant Type [GWh]		2007	2010	2015	2020	2026

Scrubbed Coal_SCR	1	226963.	233908.	234501.	345992.	632098.
Scrubbed Coal_SNCR	2	16462.	13746.	14267.	14059.	12689.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	471135.	373169.	329455.	303057.	233866.
Unscrubbed Coal_SCR	5	364239.	169637.	112227.	79931.	54805.
Unscrubbed Coal_SNCR	6	47228.	44079.	24309.	21855.	18401.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	832658.	745248.	511008.	414831.	279235.
Oil/Gas Steam	9	28106.	33024.	22510.	15855.	11457.
Oil/Gas Steam_SCR	10	14815.	1676.	974.	557.	916.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	785243.	798667.	811007.	808645.	796943.
Hydro	13	275692.	275692.	275692.	275692.	275692.
Comb.Cycle Gas	14	569306.	637586.	917705.	1107775.	1146452.
IGCC	15	4702.	4702.	4702.	62175.	219843.
Combustion Turbine	16	24948.	31459.	30285.	52324.	64771.
Biomass	17	8402.	8849.	9224.	9103.	8905.
Geothermal	18	24121.	25066.	25904.	25904.	25904.
Landfill Gas	19	4328.	4580.	7724.	8261.	8298.
Wind	20	14091.	14738.	14889.	14889.	15013.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	444.	459.	488.	488.	488.
Non Fossil_Other	23	17132.	17400.	17400.	17400.	17400.
Fossil_Other	24	4462.	4462.	4462.	4462.	4462.
Pump Storage	25	16093.	14438.	17853.	16715.	18535.
Int. Imports	26	41303.	44063.	40296.	27331.	13578.
Cgn_CT	27	7268.	1825.	1281.	1023.	1140.
Cgn_CC	28	40047.	38310.	30917.	25834.	28065.
Cgn_Oil/Gas Steam	29	0.	0.	0.	0.	0.
Cgn_Biomass	30	2645.	2606.	2612.	2676.	2695.
Cgn_Fossil_Other	31	2846.	2846.	2846.	2846.	2846.
Cgn_NonFossil_Other	32	2412.	2412.	2412.	2412.	2412.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	157.	553.	840.	840.
Rep.O/G-CC	35	0.	66175.	66288.	66288.	66345.
Rep.Coal-IGCC	36	0.	792.	854.	854.	854.
Ret.Scrubber	37	12566.	24784.	103342.	139827.	101356.
Ret.ExistSCR & Scrub	38	20229.	219802.	282415.	316082.	330211.
Ret.ExistSNCR & Scrub	39	3469.	8718.	30790.	32103.	34219.
Ret.SCR	40	85298.	106598.	136684.	80460.	36562.
Ret.ExistScrub & SCR	41	18661.	107499.	150876.	150876.	150719.
Ret.SNCR	42	974.	1133.	1757.	1509.	1186.
Ret.ExistScrub & SNCR	43	0.	0.	0.	0.	1325.
Ret.SCR+Scrb	44	22893.	89605.	237243.	310616.	347527.
Ret.SNCR+Scrub	45	0.	0.	0.	1312.	4731.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	176.	176.	37528.	109743.
Ret.ExistScrub&ACI	50	0.	10809.	13095.	38416.	96734.
Ret.ExistSCR&ACI	51	0.	105.	209.	209.	599.
Ret.ExistSNCR&ACI	52	0.	601.	601.	543.	487.
Ret.ACI & SCR	53	0.	0.	0.	0.	8541.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	36.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	2083.	2083.	2083.	79139.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	8154.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	1487.	1487.	2624.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	2413.	2413.	2413.	3391.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	19374.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	9133.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	1019.	582.	582.	582.
Ret.O/G SNCR	66	801.	801.	801.	801.	601.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.

Total		4011981.	4187920.	4499200.	4846920.	5311924.

12a. Generation by Fuel Type [GWh]	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
Coal	2127472.	2159607.	2194492.	2358214.	2797576.
Oil	0.	0.	0.	0.	0.
Nuclear	785243.	798666.	811008.	808645.	796944.
Hydro	275692.	275692.	275692.	275692.	275692.
Gas	685291.	812032.	1071896.	1271878.	1321168.
Other	11636.	11889.	15032.	15569.	15606.
None	115596.	118576.	119243.	105140.	93330.
Biomass	11047.	11455.	11835.	11779.	11601.
-----	-----	-----	-----	-----	-----
Total	4011981.	4187920.	4499200.	4846920.	5311924.

13. Generation by Plant Type [TBtu]		2007	2010	2015	2020	2026
<hr/>						
Scrubbed Coal_SCR	1	774.	798.	800.	1181.	2157.
Scrubbed Coal_SNCR	2	56.	47.	49.	48.	43.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	1608.	1273.	1124.	1034.	798.
Unscrubbed Coal_SCR	5	1243.	579.	383.	273.	187.
Unscrubbed Coal_SNCR	6	161.	150.	83.	75.	63.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	2841.	2543.	1744.	1415.	953.
Oil/Gas Steam	9	96.	113.	77.	54.	39.
Oil/Gas Steam_SCR	10	51.	6.	3.	2.	3.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	2679.	2725.	2767.	2759.	2719.
Hydro	13	941.	941.	941.	941.	941.
Comb.Cycle Gas	14	1942.	2175.	3131.	3780.	3912.
IGCC	15	16.	16.	16.	212.	750.
Combustion Turbine	16	85.	107.	103.	179.	221.
Biomass	17	29.	30.	31.	31.	30.
Geothermal	18	82.	86.	88.	88.	88.
Landfill Gas	19	15.	16.	26.	28.	28.
Wind	20	48.	50.	51.	51.	51.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	2.	2.	2.	2.	2.
Non Fossil_Other	23	58.	59.	59.	59.	59.
Fossil_Other	24	15.	15.	15.	15.	15.
Pump Storage	25	55.	49.	61.	57.	63.
Int. Imports	26	141.	150.	137.	93.	46.
Cgn_CT	27	25.	6.	4.	3.	4.
Cgn_CC	28	137.	131.	105.	88.	96.
Cgn_Oil/Gas Steam	29	0.	0.	0.	0.	0.
Cgn_Biomass	30	9.	9.	9.	9.	9.
Cgn_Fossil_Other	31	10.	10.	10.	10.	10.
Cgn_NonFossil_Other	32	8.	8.	8.	8.	8.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	1.	2.	3.	3.
Rep.O/G-CC	35	0.	226.	226.	226.	226.
Rep.Coal-IGCC	36	0.	3.	3.	3.	3.
Ret.Scrubber	37	43.	85.	353.	477.	346.
Ret.ExistSCR & Scrub	38	69.	750.	964.	1078.	1127.
Ret.ExistSNCR & Scrub	39	12.	30.	105.	110.	117.
Ret.SCR	40	291.	364.	466.	275.	125.
Ret.ExistScrub & SCR	41	64.	367.	515.	515.	514.
Ret.SNCR	42	3.	4.	6.	5.	4.
Ret.ExistScrub & SNCR	43	0.	0.	0.	0.	5.
Ret.SCR+Scrb	44	78.	306.	809.	1060.	1186.
Ret.SNCR+Scrub	45	0.	0.	0.	4.	16.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	1.	1.	128.	374.
Ret.ExistScrub&ACI	50	0.	37.	45.	131.	330.
Ret.ExistSCR&ACI	51	0.	0.	1.	1.	2.
Ret.ExistSNCR&ACI	52	0.	2.	2.	2.	2.
Ret.ACI & SCR	53	0.	0.	0.	0.	29.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	7.	7.	7.	270.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	28.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	5.	5.	9.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	8.	8.	8.	12.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	66.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	31.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	3.	2.	2.	2.
Ret.O/G SNCR	66	3.	3.	3.	3.	2.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
<hr/>		<hr/>				
Total		13689.	14289.	15351.	16538.	18124.

14. Capacity Factor by Plant Type [%]		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	85.0	84.8	85.0	85.0	85.0
Scrubbed Coal_SNCR	2	82.4	80.5	83.5	82.3	80.2
Scrubbed Coal_NOx	3	N/A	N/A	N/A	N/A	N/A
Scrubbed Coal	4	84.3	84.5	84.9	84.6	81.4
Unscrubbed Coal_SCR	5	80.9	80.8	83.3	84.8	84.1
Unscrubbed Coal_SNCR	6	72.3	75.8	81.4	77.3	76.5
Unscrubbed Coal_NOx	7	N/A	N/A	N/A	N/A	N/A
Unscrubbed Coal	8	77.8	79.5	80.9	79.8	75.9
Oil/Gas Steam	9	4.2	5.0	3.4	2.4	1.7
Oil/Gas Steam_SCR	10	20.7	3.4	2.0	1.1	1.9
Oil/Gas Steam_NOx	11	0.0	0.0	0.0	0.0	0.0
Nuclear	12	89.4	90.7	90.7	90.0	88.7
Hydro	13	35.0	35.0	35.0	35.0	35.0
Comb.Cycle Gas	14	44.2	49.0	57.9	60.5	58.0
IGCC	15	87.7	87.7	87.7	87.7	87.7
Combustion Turbine	16	2.2	2.8	2.7	4.1	4.5
Biomass	17	70.6	69.4	72.3	71.4	69.8
Geothermal	18	87.0	87.0	87.0	87.0	87.0
Landfill Gas	19	90.0	90.0	87.9	87.7	87.7
Wind	20	23.3	23.3	23.3	23.3	23.4
Fuel Cell	21	0.0	0.0	0.0	0.0	0.0
Solar	22	11.3	11.3	11.3	11.3	11.3
Non Fossil_Other	23	90.0	90.0	90.0	90.0	90.0
Fossil_Other	24	90.0	90.0	90.0	90.0	90.0
Pump Storage	25	9.3	8.3	10.3	9.7	10.7
Int. Imports	26	52.4	55.9	51.1	34.7	17.2
Cgn_CT	27	15.0	3.8	2.6	2.1	2.3
Cgn_CC	28	25.6	24.5	19.8	16.5	18.0
Cgn_Oil/Gas Steam	29	0.0	0.0	0.0	0.0	0.0
Cgn_Biomass	30	82.5	81.3	81.5	83.5	84.1
Cgn_Fossil_Other	31	90.0	90.0	90.0	90.0	90.0
Cgn_NonFossil_Other	32	87.7	87.7	87.7	87.7	87.7
Distributed Generation	33	N/A	N/A	N/A	N/A	N/A
Rep.Coal-CC	34	N/A	2.0	6.9	10.5	10.5
Rep.O/G-CC	35	N/A	90.4	90.4	90.4	90.4
Rep.Coal-IGCC	36	N/A	87.7	87.7	87.7	87.7
Ret.Scrubber	37	84.0	85.0	85.0	85.0	85.0
Ret.ExistSCR & Scrub	38	85.0	85.0	85.0	85.0	84.6
Ret.ExistSNCR & Scrub	39	78.9	85.0	85.0	85.0	84.3
Ret.SCR	40	84.5	83.2	84.5	84.4	82.0
Ret.ExistScrub & SCR	41	85.0	85.0	85.0	85.0	84.9
Ret.SNCR	42	55.3	64.4	68.5	58.8	47.0
Ret.ExistScrub & SNCR	43	0.0	0.0	53.7	56.2	85.0
Ret.SCR+Scrb	44	85.0	84.7	85.0	85.0	85.0
Ret.SNCR+Scrub	45	0.0	0.0	0.0	85.0	85.0
Ret.Gas Reburn	46	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub+GasR	47	N/A	N/A	N/A	N/A	N/A
Ret.GasReburn+Scrub	48	N/A	N/A	N/A	N/A	N/A
Ret.ACI	49	0.0	84.9	84.9	84.9	83.9
Ret.ExistScrub&ACI	50	0.0	84.4	84.5	84.8	84.5
Ret.ExistSCR&ACI	51	0.0	78.9	78.9	78.9	78.9
Ret.ExistSNCR&ACI	52	0.0	78.9	78.9	71.2	63.9
Ret.ACI & SCR	53	0.0	0.0	0.0	0.0	85.0
Ret.ExistScrub&ACI&SCR	54	0.0	0.0	0.0	0.0	0.0
Ret.ACI & SNCR	55	0.0	0.0	0.0	0.0	84.7
Ret.ExistScrub&ACI&SNCR	56	0.0	0.0	0.0	0.0	0.0
Ret.ACI & Srub	57	0.0	85.0	85.0	85.0	85.0
Ret.ExistSCR&ACI&Scrub	58	0.0	0.0	0.0	0.0	85.0
Ret.ExistSNCR&ACI&Scrub	59	0.0	0.0	85.0	85.0	85.0
Ret.ExistSNCR&ExistScrub&ACI	60	0.0	83.5	83.5	83.5	81.7
Ret.ExistSCR&ExistScrub&ACI	61	0.0	0.0	0.0	0.0	83.4
Ret.ExistNOx&ExistScrub&ACI	62	N/A	N/A	N/A	N/A	N/A
Ret.SCR & Scrub & ACI	63	0.0	0.0	0.0	0.0	85.0
Ret.SNCR & Scrub & ACI	64	0.0	0.0	0.0	0.0	0.0
Ret.O/G SCR	65	0.0	21.1	12.0	12.0	12.0
Ret.O/G SNCR	66	12.0	12.0	12.0	12.0	9.0
Ret.Nuclear (age 30+10 yrs)	67	N/A	N/A	N/A	N/A	N/A
Ret.Nuclear (age 40+20 yrs)	68	N/A	N/A	N/A	N/A	N/A
Ret. Biomass Cofiring	69	N/A	N/A	N/A	N/A	N/A
CT Early Retirement	70	0.0	0.0	0.0	0.0	0.0
CC Early Retirement	71	0.0	0.0	0.0	0.0	0.0
O/G Early Retirement	72	0.0	0.0	0.0	0.0	0.0
Coal Early Retirement	73	0.0	0.0	0.0	0.0	0.0
Nuke Early Retirement	74	N/A	N/A	N/A	N/A	N/A
Average		47.2	48.8	50.7	51.1	51.5

15. Total Annual Production Cost
[MMUS\$](*)

	2007	2010	2015	2020	2026
Variable O&M	6445.0	7564.6	8638.5	9720.0	11284.0
Fixed O&M	29001.0	29956.0	32404.7	35342.1	37891.2
Fuel	46212.7	48141.6	52937.6	56828.8	61226.7
Capital	619.1	2464.3	6276.0	13425.2	26149.8
Total	82277.8	88126.5	100256.8	115316.1	136551.7
Sales Revenue	0.0	0.0	0.0	0.0	0.0

(*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)

15a Total Annual Resource Cost
[MMUS\$](*)

	2007	2010	2015	2020	2026
Variable O&M	6445.0	7564.6	8638.5	9720.0	11284.0
Fixed O&M	29001.0	29956.0	32404.7	35342.1	37891.2
Fuel Total	95240.8	98270.1	103494.6	108347.9	112125.9
Fuel Elect.+Steam	38962.0	41123.7	45430.0	48804.0	51680.9
Capital	619.1	2464.3	6276.0	13425.2	26149.8
Total IPM	131305.9	138255.0	150813.9	166835.2	187450.9
Total Elec.+Steam	75027.1	81108.7	92749.3	107291.3	127005.9
Sales Revenue	0.0	0.0	0.0	0.0	0.0

(*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)

16. Emissions

	2007	2010	2015	2020	2026
SO2 [MTons]	8172.0327	6343.5479	4991.6265	4281.8906	3819.7456
NOX [MTons]	3612.8228	2439.2041	1994.2343	2002.1351	2045.4301
TSP [MTons]	0.0000	0.0000	0.0000	0.0000	0.0000
CO2 [MMTonnes]	2369.4656	2445.3191	2568.5818	2758.3794	3101.9563
Carbon [MMTonnes]	646.2179	666.9052	700.5223	752.2853	845.9881
MER [Tons]	47.3573	35.3438	31.9148	28.7386	23.4173

Fuel Consumption by Fuel and Fuel Type [TBtu]

Fuel	2007	2010	2015	2020	2026
Coal	22145.8	22530.7	22979.4	24326.0	27849.4
Oil	0.0	0.0	0.0	0.0	0.0
Nuclear	8276.8	8417.2	8543.8	8518.1	8394.5
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	5276.6	6123.4	7703.2	8943.5	9202.0
Other	131.2	134.5	177.4	184.7	185.2
None	591.7	606.5	619.5	619.5	619.5
Biomass	103.5	107.3	111.3	110.6	108.6
Grand Total	36525.5	37919.5	40134.6	42702.3	46359.1

Fuel Costs by Fuel and Fuel Type [MMUS\$]

Fuel	2007	2010	2015	2020	2026
Coal	24407.8	23689.8	22528.8	22680.2	25367.4
Oil	0.0	0.0	0.0	0.0	0.0
Nuclear	3410.0	3467.9	3477.3	3458.3	3408.2
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	18227.8	20812.3	26754.9	30516.9	32280.2
Other	0.0	0.0	0.0	0.0	0.0
None	0.0	0.0	0.0	0.0	0.0
Biomass	167.1	171.5	176.5	173.4	170.8

Fuel Costs by Fuel and Fuel Type [US\$/MMBtu]

Fuel	2007	2010	2015	2020	2026
Coal	1.10	1.05	0.98	0.93	0.91
Oil	0.00	0.00	0.00	0.00	0.00
Nuclear	0.41	0.41	0.41	0.41	0.41
Hydro	0.00	0.00	0.00	0.00	0.00
Gas	3.45	3.40	3.47	3.41	3.51
Other	0.00	0.00	0.00	0.00	0.00
None	0.00	0.00	0.00	0.00	0.00
Biomass	1.61	1.60	1.59	1.57	1.57

Environmental Measures Report

SO ₂ Policy Case Constraint					
	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Total Title IV Emissions	7940	6121	4772	4065	3610
MTons Banked	6446	0	0	0	0
MTons Withdrawn	0	0	-801	-488	0
Rate - [lb/MMBtu]	0.720	0.546	0.417	0.336	0.260
TBtu Consumed	21970	22400	22855	22932	22865
Non-CAIR Shadow Price (US\$/Ton)	590	392	367	422	521
CAIR Shadow Price (US\$/Ton)	590	616	892	1156	1428

Constraint Name: WRAP SO2 Policy Case Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 3

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.000	0.000	198.9	198.9
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	198.9	198.9
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	-0.7789E-08	-0.5300E-08
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.7938E-06	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-0.4961E-06
Total [MTons]	0.000	0.000	0.000	198.9	198.9
TBtu Consumed	0.000	0.000	0.000	1543.	1543.
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2578	0.2578
TWh Generated	0.000	0.000	0.000	148.8	148.8
TWh Generated Qualifying	0.000	0.000	0.000	148.8	148.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	1131.	1119.

Constraint Name: MER National Constraint
Constraint Type: Rate Cap [MTons]

Constraint #: 4

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [Lb]	0.2000E+09	0.7600E+05	0.7600E+05	0.3000E+05	0.3000E+05
-Emissions at Affected Plants [Lb]	0.000	0.6261E+05	0.5571E+05	0.4949E+05	0.3887E+05
-Less Allowances Purchased [Lb] MER	0.000	-0.8833E-08	-0.1146E-07	-0.1486E-07	-0.1280E-07
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.1339E+05	0.2029E+05	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	-0.1949E+05	-8868.
Total [Lb]	0.000	0.7600E+05	0.7600E+05	0.3000E+05	0.3000E+05
TBtu Consumed	0.000	0.2239E+05	0.2284E+05	0.2418E+05	0.2771E+05
Rate - [lb/MMBtu]	0.000	0.2797E-05	0.2439E-05	0.2046E-05	0.1403E-05
TWh Generated	0.000	2148.	2183.	2347.	2786.
TWh Generated Qualifying	0.000	2148.	2183.	2347.	2786.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.2320E+05	0.3010E+05	0.3904E+05	0.5451E+05

Constraint Name: NOx SIP CALL and Summer CAIR Constraint Constraint #: 5
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	528.0	581.4	484.5	484.5	484.5
-Emissions at Affected Plants [MTons]	528.0	548.4	467.7	469.9	478.0
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.7101E-06	19.34	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-0.2725	-6.758	-7.694
Total [MTons]	528.0	567.7	467.4	463.1	470.3
TBtu Consumed	6454.	7878.	8538.	9225.	0.1025E+05
Rate - [lb/MMBtu]	0.1636	0.1392	0.1096	0.1019	0.9329E-01
TWh Generated	646.7	799.1	880.4	974.0	1107.
TWh Generated Qualifying	646.7	799.1	880.4	974.0	1107.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2187.	0.1100E-04	0.1375E-04	0.1707E-04	0.2218E-04

Constraint Name: NOx CAIR Annual Constraint

Constraint #: 6

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	1505.	1254.	1254.	1254.
-Emissions at Affected Plants [MTons]	0.000	1505.	1254.	1254.	1254.
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.4019E-05	0.000	0.6654E-06	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-0.2993E-05	0.000	-0.1057E-05
Total [MTons]	0.000	1505.	1254.	1254.	1254.
TBtu Consumed	0.000	0.2106E+05	0.2257E+05	0.2447E+05	0.2656E+05
Rate - [lb/MMBtu]	0.000	0.1429	0.1111	0.1025	0.9445E-01
TWh Generated	0.000	2137.	2350.	2607.	2888.
TWh Generated Qualifying	0.000	2137.	2350.	2607.	2888.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1206.	1481.	1321.	1161.

Constraint Name: NOx SIPCall Rhode Island Constraint (Separated fr. Constraint #: 7
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.9970	0.9970	0.9970	0.9970
-Emissions at Affected Plants [MTons]	0.000	0.1917	0.1917	0.1917	0.1917
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.5315	0.3377	0.6542E-01	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-0.5841
Total [MTons]	0.000	0.7232	0.5294	0.2571	-0.3925
TBtu Consumed	0.000	11.85	11.85	11.85	11.85
Rate - [lb/MMBtu]	0.000	0.3235E-01	0.3235E-01	0.3235E-01	0.3235E-01
TWh Generated	0.000	1.457	1.457	1.457	1.457
TWh Generated Qualifying	0.000	1.457	1.457	1.457	1.457
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.5595E-04	0.4355E-04	0.3320E-04	0.1559E-04

Constraint Name: NOX Policy for State of Illinois
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Constraint #: 8

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	27.64	26.23	25.60	26.03	25.56
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	27.64	26.23	25.60	26.03	25.56
TBtu Consumed	431.8	452.5	481.1	487.2	478.4
Rate - [lb/MMBtu]	0.1280	0.1159	0.1064	0.1069	0.1069
TWh Generated	41.10	42.80	45.41	45.97	45.17
TWh Generated Qualifying	41.10	42.80	45.41	45.97	45.17
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2130E-05	0.9810E-06	0.1742E-05	0.2563E-05	0.2071E-05

Constraint Name: NOX Policy for State of Massachusetts
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 9

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	6.382	12.35	12.56	12.56	12.69
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.382	12.35	12.56	12.56	12.69
TBtu Consumed	89.73	159.0	161.8	161.9	163.5
Rate - [lb/MMBtu]	0.1422	0.1553	0.1552	0.1552	0.1553
TWh Generated	8.509	16.47	16.75	16.75	16.92
TWh Generated Qualifying	8.509	16.47	16.75	16.75	16.92
Constraint Shadow Price [US\$/Ton]	425.0	1318.	0.6529E-02	0.4259E-02	201.6

Constraint Name: SO2 Policy for State of Massachusetts
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 10

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	7.618	17.13	17.40	17.40	17.56
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.618	17.13	17.40	17.40	17.56
TBtu Consumed	88.52	125.0	127.1	127.1	128.3
Rate - [lb/MMBtu]	0.1721	0.2741	0.2738	0.2738	0.2737
TWh Generated	8.400	11.42	11.60	11.60	11.71
TWh Generated Qualifying	8.400	11.42	11.60	11.60	11.71
Constraint Shadow Price [US\$/Ton]	1276.	598.2	790.5	797.1	447.3

Constraint Name: CO2 Policy for State of Massachusetts Constraint #: 11
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	7658.	0.1482E+05	0.1508E+05	0.1508E+05	0.1523E+05
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7658.	0.1482E+05	0.1508E+05	0.1508E+05	0.1523E+05
TBtu Consumed	89.73	159.0	161.8	161.9	163.5
Rate - [lb/MMBtu]	170.7	186.4	186.3	186.3	186.3
TWh Generated	8.509	16.47	16.75	16.75	16.92
TWh Generated Qualifying	8.509	16.47	16.75	16.75	16.92
Constraint Shadow Price [US\$/Ton]	33.44	3.178	0.4704	0.5753	2.059

Constraint Name: NOx Policy for State of North Carolina Progressive Constraint #: 12
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	25.00	25.00	25.00	25.00	25.00
-Emissions at Affected Plants [MTons]	20.85	19.98	17.83	17.16	16.46
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	20.85	19.98	17.83	17.16	16.46
TBtu Consumed	394.2	399.1	411.4	406.9	402.3
Rate - [lb/MMBtu]	0.1058	0.1001	0.8669E-01	0.8436E-01	0.8181E-01
TWh Generated	35.82	36.23	37.08	36.70	36.31
TWh Generated Qualifying	35.82	36.23	37.08	36.70	36.31
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3719E-04	0.3015E-05	0.1837E-05	0.2326E-05	0.1861E-05

Constraint Name: NOx Policy for State of North Carolina Duke
Constraint Type: Rate Cap [MTons] Constraint #: 13
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	35.00	31.80	31.00	31.00	31.00
-Emissions at Affected Plants [MTons]	35.00	31.80	23.04	23.18	22.80
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	35.00	31.80	23.04	23.18	22.80
TBtu Consumed	545.2	532.0	579.9	584.8	579.1
Rate - [lb/MMBtu]	0.1284	0.1195	0.7946E-01	0.7926E-01	0.7873E-01
TWh Generated	50.18	48.94	53.01	53.30	52.80
TWh Generated Qualifying	50.18	48.94	53.01	53.30	52.80
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	326.5	35.50	0.1633E-05	0.2056E-05	0.1750E-05

Constraint Name: SO2 Policy for State of North Carolina Progressive Constraint #: 14

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	100.0	50.00	50.00	50.00
-Emissions at Affected Plants [MTons]	0.000	95.67	28.80	25.74	21.38
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	95.67	28.80	25.74	21.38
TBtu Consumed	0.000	399.1	411.4	406.9	402.3
Rate - [lb/MMBtu]	0.000	0.4794	0.1400	0.1265	0.1063
TWh Generated	0.000	36.23	37.08	36.70	36.31
TWh Generated Qualifying	0.000	36.23	37.08	36.70	36.31
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.2824E-05	0.6447E-05	0.4739E-05	0.1005E-05

Constraint Name: SO2 Policy for State of North Carolina Duke
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	150.0	80.00	80.00	80.00
-Emissions at Affected Plants [MTons]	0.000	150.0	80.00	44.04	42.73
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	150.0	80.00	44.04	42.73
TBtu Consumed	0.000	532.0	579.9	584.8	579.1
Rate - [lb/MMBtu]	0.000	0.5639	0.2759	0.1506	0.1476
TWh Generated	0.000	48.94	53.01	53.30	52.80
TWh Generated Qualifying	0.000	48.94	53.01	53.30	52.80
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	187.0	42.32	0.1724E-05	0.8935E-06

Constraint Name: NOx Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 16

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	3.644	3.644	3.644	3.644	3.644
-Emissions at Affected Plants [MTons]	2.000	2.074	2.126	2.100	2.100
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.9470	1.035	0.6831	0.1223	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-1.269
Total [MTons]	2.947	3.109	2.809	2.222	0.8314
TBtu Consumed	42.57	43.28	43.78	43.53	43.53
Rate - [lb/MMBtu]	0.9397E-01	0.9585E-01	0.9714E-01	0.9650E-01	0.9650E-01
TWh Generated	3.915	3.971	4.010	3.990	3.990
TWh Generated Qualifying	3.915	3.971	4.010	3.990	3.990
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.8485E-04	0.2148E-04	0.1691E-04	0.1280E-04	0.5599E-05

Constraint Name: NOx Policy for State of New Hampshire - Hillsborou Constraint #: 17
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.153	1.153	1.153	1.153	1.153
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	1.434	1.587	1.066	0.1482	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-1.930
Total [MTons]	2.587	2.740	2.218	1.301	-0.7770
TBtu Consumed	48.71	48.71	48.71	48.71	48.71
Rate - [lb/MMBtu]	0.4734E-01	0.4734E-01	0.4734E-01	0.4734E-01	0.4734E-01
TWh Generated	5.987	5.987	5.987	5.987	5.987
TWh Generated Qualifying	5.987	5.987	5.987	5.987	5.987
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.5483E-04	0.1685E-04	0.1310E-04	0.9832E-05	0.4405E-05

Constraint Name: NOx Policy for State of New Hampshire Remaining Co Constraint #: 18
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2000	0.2000	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]

Constraint #: 19

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	7.289	7.289	7.289	7.289	7.289
-Emissions at Affected Plants [MTons]	7.289	7.152	7.426	7.289	7.289
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.1299E-06	0.1370	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-0.1370	-0.3943E-07	-0.1004E-06
Total [MTons]	7.289	7.289	7.289	7.289	7.289
TBtu Consumed	42.54	43.24	43.74	43.49	43.49
Rate - [lb/MMBtu]	0.3427	0.3308	0.3395	0.3352	0.3352
TWh Generated	3.913	3.968	4.007	3.987	3.987
TWh Generated Qualifying	3.913	3.968	4.007	3.987	3.987
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	627.0	232.4	301.4	299.2	233.0

Constraint Name: CO2 Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]

Constraint #: 20

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	5426.	5426.	5426.	5426.	5426.
-Emissions at Affected Plants [MTons]	4368.	4441.	4492.	4467.	4467.
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	818.2	329.6	135.5	36.74	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-415.9
Total [MTons]	5187.	4771.	4628.	4503.	4051.
TBtu Consumed	42.57	43.28	43.78	43.53	43.53
Rate - [lb/MMBtu]	205.2	205.2	205.2	205.2	205.2
TWh Generated	3.915	3.971	4.010	3.990	3.990
TWh Generated Qualifying	3.915	3.971	4.010	3.990	3.990
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3984E-06	0.1348E-06	0.1621E-06	0.1996E-06	0.1605E-06

Constraint Name: NOx Policy for State of New York
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER
Run Year, Seasons Included: 2010 WINTER
Run Year, Seasons Included: 2015 WINTER
Run Year, Seasons Included: 2020 WINTER
Run Year, Seasons Included: 2026 WINTER

Constraint #: 21

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	39.91	39.91	39.91	39.91	39.91
-Emissions at Affected Plants [MTons]	28.52	20.32	11.78	12.22	12.34
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	6.023	11.95	13.99	4.300	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-19.65
Total [MTons]	34.55	32.27	25.77	16.52	-7.317
TBtu Consumed	330.1	329.6	351.8	410.0	457.9
Rate - [lb/MMBtu]	0.1728	0.1233	0.6699E-01	0.5962E-01	0.5389E-01
TWh Generated	37.68	39.49	44.35	52.59	59.40
TWh Generated Qualifying	37.68	39.49	44.35	52.59	59.40
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.5460E-04	0.2182E-05	0.1565E-05	0.1259E-05	0.6981E-06

Constraint Name: SO2 Policy for State of New York
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 22

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	197.0	131.4	131.4	131.4	131.4
-Emissions at Affected Plants [MTons]	197.0	90.75	40.61	41.70	36.09
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.1816E-03	26.18	50.62	15.72	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-57.82
Total [MTons]	197.0	116.9	91.23	57.41	-21.73
TBtu Consumed	270.4	241.7	241.7	354.9	425.4
Rate - [lb/MMBtu]	1.457	0.7508	0.3361	0.2349	0.1697
TWh Generated	26.76	24.24	24.03	39.81	50.07
TWh Generated Qualifying	26.76	24.24	24.03	39.81	50.07
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2.410	0.1667E-05	0.7137E-06	0.5006E-06	0.1308E-06

Constraint Name: NOx Policy for State of Wisconsin
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 23

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.2500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	13.34	9.026	9.026	8.609
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	13.34	9.026	9.026	8.609
TBtu Consumed	0.000	202.2	202.5	202.5	197.3
Rate - [lb/MMBtu]	0.000	0.1320	0.8916E-01	0.8916E-01	0.8726E-01
TWh Generated	0.000	19.25	19.16	19.16	18.68
TWh Generated Qualifying	0.000	19.25	19.16	19.16	18.68
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1329E-05	0.4534E-05	0.7291E-05	0.6131E-05

Constraint Name: SO2 Policy for State of Wisconsin
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 24

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.7000	0.4500	0.4500	0.4500
-Emissions at Affected Plants [MTons]	0.000	36.16	24.48	24.48	23.22
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	36.16	24.48	24.48	23.22
TBtu Consumed	0.000	202.2	202.5	202.5	197.3
Rate - [lb/MMBtu]	0.000	0.3577	0.2418	0.2418	0.2353
TWh Generated	0.000	19.25	19.16	19.16	18.68
TWh Generated Qualifying	0.000	19.25	19.16	19.16	18.68
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.4436E-06	0.1473E-05	0.2350E-05	0.1932E-05

Constraint Name: NOx Policy for Houston Texas

Constraint #: 25

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	8.450	8.450	8.450	8.450	8.450
-Emissions at Affected Plants [MTons]	8.450	8.450	8.450	8.450	8.450
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8.450	8.450	8.450	8.450	8.450
TBtu Consumed	286.5	293.5	263.2	278.3	284.3
Rate - [lb/MMBtu]	0.5899E-01	0.5758E-01	0.6422E-01	0.6073E-01	0.5945E-01
TWh Generated	31.23	31.92	27.15	29.27	30.85
TWh Generated Qualifying	31.23	31.92	27.15	29.27	30.85
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1908E+05	0.1783E+05	0.1308E+05	9693.	4899.

Constraint Name: NOx Policy for Dallas/Fort Texas
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 26

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	2.164	2.164	2.164	2.164	2.164
-Emissions at Affected Plants [MTons]	0.9841	1.050	0.6233	0.5655	0.5091
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9841	1.050	0.6233	0.5655	0.5091
TBtu Consumed	32.96	40.21	23.71	18.61	16.77
Rate - [lb/MMBtu]	0.5972E-01	0.5222E-01	0.5258E-01	0.6078E-01	0.6072E-01
TWh Generated	3.131	3.830	2.258	1.766	1.594
TWh Generated Qualifying	3.131	3.830	2.258	1.766	1.594
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2799E-03	0.3406E-04	0.4245E-04	0.5899E-04	0.4110E-04

Constraint Name: NOx Policy for East Central Texas
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 27

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	123.5	123.5	123.5	123.5	123.5
-Emissions at Affected Plants [MTons]	118.8	123.5	115.1	104.1	89.96
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	118.8	123.5	115.1	104.1	89.96
TBtu Consumed	1689.	1817.	1586.	1488.	1271.
Rate - [lb/MMBtu]	0.1407	0.1360	0.1452	0.1400	0.1416
TWh Generated	179.5	191.2	163.5	152.8	129.9
TWh Generated Qualifying	179.5	191.2	163.5	152.8	129.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3970E-04	585.7	0.1488E-05	0.9677E-06	0.5393E-06

Constraint Name: SO2 Policy for Texas East (Senate Bill 7) Constraint #: 28
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	111.2	111.2	111.2	111.2	111.2
-Emissions at Affected Plants [MTons]	85.64	85.64	85.64	8.560	8.560
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	85.64	85.64	85.64	8.560	8.560
TBtu Consumed	171.3	171.3	171.3	171.2	171.2
Rate - [lb/MMBtu]	1.000	1.000	1.000	0.1000	0.1000
TWh Generated	16.98	16.98	16.98	16.62	16.62
TWh Generated Qualifying	16.98	16.98	16.98	16.62	16.62
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2560E-05	0.4768E-06	0.5090E-06	0.2206E-06	0.1895E-06

Constraint Name: NOx Policy for Rest of Texas East
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 29

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	58.37	58.37	58.37	58.37	58.37
-Emissions at Affected Plants [MTons]	24.70	33.14	26.75	22.33	20.96
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	24.70	33.14	26.75	22.33	20.96
TBtu Consumed	314.5	438.2	349.2	290.8	266.4
Rate - [lb/MMBtu]	0.1571	0.1513	0.1532	0.1535	0.1573
TWh Generated	30.88	42.24	33.82	27.97	25.84
TWh Generated Qualifying	30.88	42.24	33.82	27.97	25.84
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3271E-05	0.6824E-06	0.7422E-06	0.8299E-06	0.6317E-06

Constraint Name: NOx Policy for Texas West
Constraint Type: Rate Cap [MTons]

Constraint #: 30

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	18.03	18.03	18.03	18.03	18.03
-Emissions at Affected Plants [MTons]	6.259	6.366	3.868	3.327	1.890
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.259	6.366	3.868	3.327	1.890
TBtu Consumed	63.97	65.07	41.72	34.24	17.51
Rate - [lb/MMBtu]	0.1957	0.1957	0.1855	0.1943	0.2159
TWh Generated	5.914	6.005	3.868	3.189	1.684
TWh Generated Qualifying	5.914	6.005	3.868	3.189	1.684
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1693E-04	0.1797E-05	0.2685E-05	0.3880E-05	0.2678E-05

Constraint Name: NOx Policy for El Paso Texas	Constraint #: 31
Constraint Type: Rate Cap [MTons]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	1.058	1.058	1.058	1.058	1.058
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.8006E-04	0.1503E-04	0.1992E-04	0.2619E-04	0.2112E-04

Constraint Name: CFR Connecticut NOx Facility Specific Constraint Constraint #: 32
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	2.113	2.113	2.113	2.113	2.113
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.113	2.113	2.113	2.113	2.113
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	2.820	2.810	2.810	2.810	2.810
TWh Generated Qualifying	2.820	2.810	2.810	2.810	2.810
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1385E+05	0.6265	0.9107	2.164	1.382

Constraint Name: CDU Connecticut NOx Facility Specific Constraint Constraint #: 33
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BSM Connecticut NOx Facility Specific Constraint Constraint #: 34
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1852	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1852	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01
TBtu Consumed	2.485	1.165	1.165	1.165	1.165
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.2632	0.1234	0.1234	0.1234	0.1234
TWh Generated Qualifying	0.2632	0.1234	0.1234	0.1234	0.1234
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLR Connecticut NOx Facility Specific Constraint Constraint #: 35
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1403.	1000.	861.5	858.9	788.8

Constraint Name: BLQ Connecticut NOx Facility Specific Constraint Constraint #: 36
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut NOx Facility Specific Constraint Constraint #: 37
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	5703.	3091.	3115.	1992.

Constraint Name: BKA Connecticut NOx Facility Specific Constraint Constraint #: 38
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut NOx Facility Specific Constraint Constraint #: 39
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	5122.	2492.	1739.	1756.	1376.

Constraint Name: BJD Connecticut NOx Facility Specific Constraint Constraint #: 40
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ATH Connecticut NOx Facility Specific Constraint Constraint #: 41
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.856	4.017	3.861	3.283	3.681
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.856	4.017	3.861	3.283	3.681
TBtu Consumed	65.18	53.91	51.83	44.07	49.41
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	8.955	7.407	7.120	6.055	6.789
TWh Generated Qualifying	8.955	7.407	7.120	6.055	6.789
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIO Connecticut NOx Facility Specific Constraint Constraint #: 42
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4016E-01	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4016E-01	0.000	0.000
TBtu Consumed	0.000	0.000	0.5391	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.1490	0.000	0.000
TWh Generated	0.000	0.000	0.4289E-01	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.4289E-01	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIN Connecticut NOx Facility Specific Constraint Constraint #: 43
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.5639E-01	0.5639E-01	0.5639E-01	0.2408E-01	0.2408E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5639E-01	0.5639E-01	0.5639E-01	0.2408E-01	0.2408E-01
TBtu Consumed	0.7569	0.7569	0.7569	0.3232	0.3232
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.7099E-01	0.7099E-01	0.7099E-01	0.3031E-01	0.3031E-01
TWh Generated Qualifying	0.7099E-01	0.7099E-01	0.7099E-01	0.3031E-01	0.3031E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIM Connecticut NOx Facility Specific Constraint Constraint #: 44
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.3984	0.3886	0.2119	0.1327	0.1327
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3984	0.3886	0.2119	0.1327	0.1327
TBtu Consumed	5.348	5.216	2.844	1.782	1.782
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.6147	0.5996	0.3269	0.2048	0.2048
TWh Generated Qualifying	0.6147	0.5996	0.3269	0.2048	0.2048
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIL Connecticut NOx Facility Specific Constraint Constraint #: 45
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIK Connecticut NOx Facility Specific Constraint Constraint #: 46
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01
TBtu Consumed	0.2342	0.2342	0.2342	0.2342	0.2342
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01
TWh Generated Qualifying	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut SO2 Facility Specific Constraint Constraint #: 47
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	4.649	2.113	2.113	2.113	2.113
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.649	2.113	2.113	2.113	2.113
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.3300	0.1500	0.1500	0.1500	0.1500
TWh Generated	2.820	2.810	2.810	2.810	2.810
TWh Generated Qualifying	2.820	2.810	2.810	2.810	2.810
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	485.1	0.3797E-05	0.5092E-05	0.6922E-05	0.6262E-05

Constraint Name: CDU Connecticut SO2 Facility Specific Constraint Constraint #: 48
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	1.788	1.788	1.788	1.788	1.788
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.788	1.788	1.788	1.788	1.788
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.2310	0.2310	0.2310	0.2310	0.2310
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.9868E-04	0.1452E-04	0.1885E-04	0.2472E-04	0.2134E-04

Constraint Name: BLR Connecticut SO2 Facility Specific Constraint Constraint #: 49
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLQ Connecticut SO2 Facility Specific Constraint Constraint #: 50
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut SO2 Facility Specific Constraint Constraint #: 51
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKA Connecticut SO2 Facility Specific Constraint Constraint #: 52
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut SO2 Facility Specific Constraint Constraint #: 53
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJD Connecticut SO2 Facility Specific Constraint Constraint #: 54
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut Hg Facility Specific Constraint Constraint #: 55
 Constraint Type: Required Removal Level
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	133.2	49.60	49.60	49.60	49.60
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	133.2	49.60	49.60	49.60	49.60
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.4728E-05	0.1761E-05	0.1761E-05	0.1761E-05	0.1761E-05
TWh Generated	2.820	2.810	2.810	2.810	2.810
TWh Generated Qualifying	2.820	2.810	2.810	2.810	2.810
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut Hg Facility Specific Constraint Constraint #: 56
Constraint Type: Required Removal Level
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	128.3	28.51	28.51	28.51	28.51
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	128.3	28.51	28.51	28.51	28.51
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.8289E-05	0.1842E-05	0.1842E-05	0.1842E-05	0.1842E-05
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCV Illinois NOx Facility Specific Constraint Constraint #: 57
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
TBtu Consumed	14.32	14.32	14.32	14.32	14.32
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.648	1.648	1.648	1.648	1.648
TWh Generated Qualifying	1.648	1.648	1.648	1.648	1.648
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ASU Illinois NOx Facility Specific Constraint Constraint #: 58
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.9835	1.453	1.453	1.453	1.453
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9835	1.453	1.453	1.453	1.453
TBtu Consumed	7.900	11.67	11.67	11.67	11.67
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	1.069	1.580	1.580	1.580	1.580
TWh Generated Qualifying	1.069	1.580	1.580	1.580	1.580
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFF Illinois NOx Facility Specific Constraint Constraint #: 59
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFE Illinois NOx Facility Specific Constraint Constraint #: 60
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3396	0.7928	1.461	1.658	1.413
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3396	0.7928	1.461	1.658	1.413
TBtu Consumed	2.728	6.368	11.73	13.32	11.35
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	0.2579	0.6020	1.109	1.259	1.073
TWh Generated Qualifying	0.2579	0.6020	1.109	1.259	1.073
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CKT Maine NOx Facility Specific Constraint Constraint #: 61
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.6637	0.6637	0.6636	0.6636	0.6637
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6637	0.6637	0.6636	0.6636	0.6637
TBtu Consumed	6.033	6.033	6.033	6.033	6.033
Rate - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
TWh Generated	0.5659	0.5659	0.5659	0.5659	0.5659
TWh Generated Qualifying	0.5659	0.5659	0.5659	0.5659	0.5659
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3515E+05	1256.	770.7	685.2	304.2

Constraint Name: BLS Maine NOx Facility Specific Constraint Constraint #: 62
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1370.	269.6	165.8	197.5	167.5

Constraint Name: BJG Maine NOx Facility Specific Constraint Constraint #: 63
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2424.	896.2	913.3	1032.	1063.

Constraint Name: BJF Maine NOx Facility Specific Constraint Constraint #: 64
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1370.	555.3	562.6	630.3	658.6

Constraint Name: BEB Maine NOx Facility Specific Constraint Constraint #: 65
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1278.	716.6	676.2	674.5	641.9

Constraint Name: CZV New Source Review NOX Facility Specific Constr Constraint #: 66
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9436	0.9436	0.9436	0.9436
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9436	0.9436	0.9436	0.9436
TBtu Consumed	0.000	31.45	31.45	31.45	31.45
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	3.202	3.202	3.202	3.202
TWh Generated Qualifying	0.000	3.202	3.202	3.202	3.202
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.5385E-02	0.3710E-02	0.3856E-02	0.2963E-02

Constraint Name: CZU New Source Review NOX Facility Specific Constr Constraint #: 67
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9373	0.9373	0.9373	0.9071
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9373	0.9373	0.9373	0.9071
TBtu Consumed	0.000	30.24	30.24	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6000E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	669.3	100.7	54.13	0.2263E-02

Constraint Name: CZT New Source Review NOX Facility Specific Constr Constraint #: 68
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9718	0.9718	0.9718	0.9405
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9718	0.9718	0.9718	0.9405
TBtu Consumed	0.000	31.35	31.35	31.35	31.35
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6000E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	538.6	47.73	22.74	0.2330E-02

Constraint Name: CPX New Source Review NOX Facility Specific Constr Constraint #: 69
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4476.	3146.	2298.

Constraint Name: CPW New Source Review NOX Facility Specific Constr Constraint #: 70
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4472.	3139.	2293.

Constraint Name: CPV New Source Review NOX Facility Specific Constr Constraint #: 71
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1893.	1282.	943.5

Constraint Name: CPS New Source Review NOX Facility Specific Constr Constraint #: 72
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1823.	1238.	928.8

Constraint Name: CNM New Source Review NOX Facility Specific Constr Constraint #: 73
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7273	0.7273	0.7273
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7273	0.7273	0.7273
TBtu Consumed	0.000	0.000	23.46	23.46	23.46
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.285	2.285	2.285
TWh Generated Qualifying	0.000	0.000	2.285	2.285	2.285
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	6970.	5258.	3021.

Constraint Name: CNL New Source Review NOX Facility Specific Constr Constraint #: 74
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6808	0.6808	0.6808
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6808	0.6808	0.6808
TBtu Consumed	0.000	0.000	21.96	21.96	21.96
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.184	2.184	2.184
TWh Generated Qualifying	0.000	0.000	2.184	2.184	2.184
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4319.	2441.	1373.

Constraint Name: CNK New Source Review NOX Facility Specific Constr Constraint #: 75
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6130	0.6130	0.6130
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6130	0.6130	0.6130
TBtu Consumed	0.000	0.000	19.77	19.77	19.77
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.936	1.936	1.936
TWh Generated Qualifying	0.000	0.000	1.936	1.936	1.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3671.	1392.	2074.

Constraint Name: CNJ New Source Review NOX Facility Specific Constr Constraint #: 76
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5955	0.5955	0.5955
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5955	0.5955	0.5955
TBtu Consumed	0.000	0.000	19.21	19.21	19.21
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.914	1.914	1.914
TWh Generated Qualifying	0.000	0.000	1.914	1.914	1.914
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4154.	1665.	1423.

Constraint Name: CLT New Source Review NOX Facility Specific Constr Constraint #: 77
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5363	0.5194	0.5194
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5363	0.5194	0.5194
TBtu Consumed	0.000	0.000	17.30	17.31	17.31
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.581	1.582	1.582
TWh Generated Qualifying	0.000	0.000	1.581	1.582	1.582
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	55.48	0.1562E-01	0.1259E-01

Constraint Name: CLS New Source Review NOX Facility Specific Constr Constraint #: 78
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	1.505	1.505	1.505
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.505	1.505	1.505
TBtu Consumed	0.000	0.000	55.05	55.05	55.05
Rate - [lb/MMBtu]	0.000	0.000	0.5467E-01	0.5467E-01	0.5467E-01
TWh Generated	0.000	0.000	5.213	5.213	5.213
TWh Generated Qualifying	0.000	0.000	5.213	5.213	5.213
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.8009E-03	0.8806E-03	0.6715E-03

Constraint Name: CLR New Source Review NOX Facility Specific Constr Constraint #: 79
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7803	0.7803	0.7803
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7803	0.7803	0.7803
TBtu Consumed	0.000	0.000	26.01	26.01	26.01
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.377	2.377	2.377
TWh Generated Qualifying	0.000	0.000	2.377	2.377	2.377
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1212E-01	0.1198E-01	0.8640E-02

Constraint Name: CLQ New Source Review NOX Facility Specific Constr Constraint #: 80
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3572	0.3457	0.3457
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3572	0.3457	0.3457
TBtu Consumed	0.000	0.000	11.52	11.52	11.52
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.161	1.137	1.137
TWh Generated Qualifying	0.000	0.000	1.161	1.137	1.137
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	151.7	0.6263E-01	0.6562E-01

Constraint Name: CLP New Source Review NOX Facility Specific Constr Constraint #: 81
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3843	0.3719	0.3719
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3843	0.3719	0.3719
TBtu Consumed	0.000	0.000	12.40	12.40	12.40
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.236	1.210	1.210
TWh Generated Qualifying	0.000	0.000	1.236	1.210	1.210
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	88.86	0.6853E-01	0.6349E-01

Constraint Name: CJG New Source Review NOX Facility Specific Constr Constraint #: 82
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
-Emissions at Affected Plants [MTons]	0.000	1.169	1.169	1.169	1.169
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.169	1.169	1.169	1.169
TBtu Consumed	0.000	38.98	38.98	38.98	38.98
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	3.880	3.880	3.880	3.880
TWh Generated Qualifying	0.000	3.880	3.880	3.880	3.880
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.2940E+05	0.2935E+05	0.3489E+05	0.2866E+05

Constraint Name: CGW New Source Review NOX Facility Specific Constr Constraint #: 83
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	1.484	1.484	1.485	1.485	1.485
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.484	1.484	1.485	1.485	1.485
TBtu Consumed	47.87	47.88	47.89	47.89	47.89
Rate - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	4.466	4.466	4.468	4.468	4.468
TWh Generated Qualifying	4.466	4.466	4.468	4.468	4.468
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	129.8	940.7	1558.	657.3	476.4

Constraint Name: CFI New Source Review NOX Facility Specific Constr Constraint #: 84
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.9845	0.9527	0.9527	0.9527	0.9527
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9845	0.9527	0.9527	0.9527	0.9527
TBtu Consumed	31.76	31.76	31.76	31.76	31.76
Rate - [lb/MMBtu]	0.6200E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	3.269	3.269	3.269	3.269	3.269
TWh Generated Qualifying	3.269	3.269	3.269	3.269	3.269
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1141.	0.4707E-02	0.3331E-02	0.3421E-02	0.2590E-02

Constraint Name: CSD New Source Review SO2 Facility Specific Constr Constraint #: 85
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.827	0.6993	0.6957	0.6824
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.827	0.6993	0.6957	0.6824
TBtu Consumed	0.000	20.88	21.05	21.05	21.05
Rate - [lb/MMBtu]	0.000	0.1750	0.6643E-01	0.6609E-01	0.6482E-01
TWh Generated	0.000	1.956	1.968	1.968	1.968
TWh Generated Qualifying	0.000	1.956	1.968	1.968	1.968
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	144.9	0.9132E-04	0.1167E-03	0.7660E-04

Constraint Name: CSC New Source Review SO2 Facility Specific Constr Constraint #: 86
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.827	0.6993	0.6957	0.6824
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.827	0.6993	0.6957	0.6824
TBtu Consumed	0.000	20.88	21.05	21.05	21.05
Rate - [lb/MMBtu]	0.000	0.1750	0.6643E-01	0.6609E-01	0.6482E-01
TWh Generated	0.000	1.956	1.968	1.968	1.968
TWh Generated Qualifying	0.000	1.956	1.968	1.968	1.968
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	144.9	0.9132E-04	0.1167E-03	0.7660E-04

Constraint Name: CPX New Source Review SO2 Facility Specific Constr Constraint #: 87
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1341E+05	0.1721E+05	0.1475E+05

Constraint Name: CPW New Source Review SO2 Facility Specific Constr Constraint #: 88
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1344E+05	0.1723E+05	0.1478E+05

Constraint Name: CPV New Source Review SO2 Facility Specific Constr Constraint #: 89
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1258E+05	0.1574E+05	0.1334E+05

Constraint Name: CPS New Source Review SO2 Facility Specific Constr Constraint #: 90
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1487E+05	0.1796E+05	0.1569E+05

Constraint Name: CNM New Source Review SO2 Facility Specific Constr Constraint #: 91
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.924	1.924	1.924
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.924	1.924	1.924
TBtu Consumed	0.000	0.000	23.46	23.46	23.46
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	2.285	2.285	2.285
TWh Generated Qualifying	0.000	0.000	2.285	2.285	2.285
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2846.	1894.	1619.

Constraint Name: CNL New Source Review SO2 Facility Specific Constr Constraint #: 92
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.801	1.801	1.801
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.801	1.801	1.801
TBtu Consumed	0.000	0.000	21.96	21.96	21.96
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	2.184	2.184	2.184
TWh Generated Qualifying	0.000	0.000	2.184	2.184	2.184
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2742.	2076.	1775.

Constraint Name: CNK New Source Review SO2 Facility Specific Constr Constraint #: 93
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.621	1.621	1.621
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.621	1.621	1.621
TBtu Consumed	0.000	0.000	19.77	19.77	19.77
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.936	1.936	1.936
TWh Generated Qualifying	0.000	0.000	1.936	1.936	1.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2376.	1891.	1894.

Constraint Name: CNJ New Source Review SO2 Facility Specific Constr Constraint #: 94
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.575	1.575	1.575
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.575	1.575	1.575
TBtu Consumed	0.000	0.000	19.21	19.21	19.21
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.914	1.914	1.914
TWh Generated Qualifying	0.000	0.000	1.914	1.914	1.914
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2460.	2161.	1719.

Constraint Name: CMY New Source Review SO2 Facility Specific Constr Constraint #: 95
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1600	0.1600	0.1600	0.1600	0.1600
-Emissions at Affected Plants [MTons]	3.689	3.817	3.854	3.854	3.603
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.689	3.817	3.854	3.854	3.603
TBtu Consumed	46.12	47.71	48.18	48.18	45.04
Rate - [lb/MMBtu]	0.1600	0.1600	0.1600	0.1600	0.1600
TWh Generated	4.165	4.309	4.351	4.351	4.068
TWh Generated Qualifying	4.165	4.309	4.351	4.351	4.068
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2001.	832.7	547.3	237.2	151.3

Constraint Name: CLS New Source Review SO2 Facility Specific Constr Constraint #: 96
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	3.372	3.633	3.633	3.633
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.372	3.633	3.633	3.633
TBtu Consumed	0.000	51.09	55.05	55.05	55.05
Rate - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
TWh Generated	0.000	4.838	5.213	5.213	5.213
TWh Generated Qualifying	0.000	4.838	5.213	5.213	5.213
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.3832E+05	0.1368E+05	0.1547E+05	0.1568E+05

Constraint Name: CLR New Source Review SO2 Facility Specific Constr Constraint #: 97
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	0.000	1.561	1.561	1.561
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.561	1.561	1.561
TBtu Consumed	0.000	0.000	26.01	26.01	26.01
Rate - [lb/MMBtu]	0.000	0.000	0.1200	0.1200	0.1200
TWh Generated	0.000	0.000	2.377	2.377	2.377
TWh Generated Qualifying	0.000	0.000	2.377	2.377	2.377
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.6891E-03	0.6007E-03	0.4213E-03

Constraint Name: CGQ New Source Review SO2 Facility Specific Constr Constraint #: 98
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.914	1.914	1.914
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.914	1.914	1.914
TBtu Consumed	0.000	0.000	25.53	25.53	25.53
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.334	2.334	2.334
TWh Generated Qualifying	0.000	0.000	2.334	2.334	2.334
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	211.9	152.7	45.76

Constraint Name: CGP New Source Review SO2 Facility Specific Constr Constraint #: 99
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.893	1.914	1.914	1.914
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.893	1.914	1.914	1.914
TBtu Consumed	0.000	25.25	25.53	25.53	25.53
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	2.309	2.334	2.334	2.334
TWh Generated Qualifying	0.000	2.309	2.334	2.334	2.334
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	139.8	207.7	152.3	45.65

Constraint Name: NOx DE NJ AR Dummy Winter Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007
Run Year, Seasons Included: 2010 WINTER
Run Year, Seasons Included: 2015 WINTER
Run Year, Seasons Included: 2020 WINTER
Run Year, Seasons Included: 2026 WINTER

Constraint #: 100

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.1000E+09	0.1000E+09	0.1000E+09	0.1000E+09
-Emissions at Affected Plants [MTons]	0.000	34.82	35.68	36.16	47.62
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	121.0	0.000	30.01	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-7.579	0.000	-89.62
Total [MTons]	0.000	155.8	28.10	66.17	-42.00
TBtu Consumed	0.000	390.4	398.9	415.0	809.4
Rate - [lb/MMBtu]	0.000	0.1784	0.1789	0.1743	0.1177
TWh Generated	0.000	36.34	36.72	38.59	84.87
TWh Generated Qualifying	0.000	36.34	36.72	38.59	84.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.2121E-11	0.2747E-11	0.3573E-11	0.3120E-11

Constraint Name: BART Dummy Annual NOx Constraint Coal >200mw & BAR Constraint #: 101
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.000	0.1000E+06	0.1000E+06	0.1000E+06
-Emissions at Affected Plants [MTons]	0.000	0.000	366.2	366.2	366.1
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	128.6	2116.	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	-1403.
Total [MTons]	0.000	0.000	494.7	2482.	-1036.
TBtu Consumed	0.000	0.000	3217.	3217.	3215.
Rate - [lb/MMBtu]	0.000	0.000	0.2277	0.2276	0.2278
TWh Generated	0.000	0.000	300.1	300.0	299.8
TWh Generated Qualifying	0.000	0.000	300.1	300.0	299.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2756E-08	0.1688E-08	0.3069E-08

Constraint Name: CBU BART Plant Specific SO2 Constraint	Constraint #: 102
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	15.74	15.74	2.962	2.962	2.962
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	15.74	15.74	2.962	2.962	2.962
 TBtu Consumed	 39.50	 39.50	 39.49	 39.49	 39.49
Rate - [lb/MMBtu]	0.7970	0.7970	0.1500	0.1500	0.1500
TWh Generated	3.760	3.760	3.691	3.691	3.691
TWh Generated Qualifying	3.760	3.760	3.691	3.691	3.691
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1293.	329.0	806.4

Constraint Name: CCO BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 103

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	19.26	19.26	2.888	2.888	2.888
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	19.26	19.26	2.888	2.888	2.888
TBtu Consumed	38.52	38.52	38.50	38.50	38.50
Rate - [lb/MMBtu]	1.000	1.000	0.1500	0.1500	0.1500
TWh Generated	3.425	3.425	3.361	3.361	3.361
TWh Generated Qualifying	3.425	3.425	3.361	3.361	3.361
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1125.	463.4	249.9

Constraint Name: CCQ BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 104

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.153	4.153	1.205	1.205	1.205
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.153	4.153	1.205	1.205	1.205
TBtu Consumed	16.07	16.07	16.06	16.06	16.06
Rate - [lb/MMBtu]	0.5170	0.5170	0.1500	0.1500	0.1500
TWh Generated	1.549	1.549	1.523	1.523	1.523
TWh Generated Qualifying	1.549	1.549	1.523	1.523	1.523
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3608.	2577.	1827.

Constraint Name: CEI BART Plant Specific SO2 Constraint Constraint #: 105
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.789	3.676	4.196	4.196	3.680
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.789	3.676	4.196	4.196	3.680
TBtu Consumed	39.16	83.54	83.54	83.54	83.54
Rate - [lb/MMBtu]	0.2446	0.8800E-01	0.1005	0.1005	0.8811E-01
TWh Generated	3.589	7.633	7.633	7.633	7.633
TWh Generated Qualifying	3.589	7.633	7.633	7.633	7.633
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.4949E-04	0.5449E-04	0.3173E-04

Constraint Name: CEQ BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 106

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	11.80	11.80	3.671	3.671	3.671
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	11.80	11.80	3.671	3.671	3.671
TBtu Consumed	48.96	48.96	48.94	48.94	48.94
Rate - [lb/MMBtu]	0.4820	0.4820	0.1500	0.1500	0.1500
TWh Generated	4.207	4.207	4.138	4.138	4.138
TWh Generated Qualifying	4.207	4.207	4.138	4.138	4.138
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3665.	2757.	2135.

Constraint Name: CFA BART Plant Specific SO2 Constraint

Constraint #: 107

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	28.48	28.48	8.805	8.805	8.805
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	28.48	28.48	8.805	8.805	8.805
TBtu Consumed	117.4	117.4	117.4	117.4	117.4
Rate - [lb/MMBtu]	0.4850	0.4850	0.1500	0.1500	0.1500
TWh Generated	11.39	11.39	11.21	11.21	11.21
TWh Generated Qualifying	11.39	11.39	11.21	11.21	11.21
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2024.	1899.	1943.

Constraint Name: CFB BART Plant Specific SO2 Constraint	Constraint #: 108
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	19.87	19.87	5.983	5.983	5.983
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	19.87	19.87	5.983	5.983	5.983
 TBtu Consumed	 79.79	 79.79	 79.77	 79.77	 79.77
Rate - [lb/MMBtu]	0.4980	0.4980	0.1500	0.1500	0.1500
TWh Generated	7.446	7.446	7.328	7.328	7.323
TWh Generated Qualifying	7.446	7.446	7.328	7.328	7.323
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1911.	1808.	1838.

Constraint Name: CFC BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 109

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	7.265	7.265	1.911	1.911	1.911
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.265	7.265	1.911	1.911	1.911
TBtu Consumed	25.49	25.49	25.48	25.48	25.48
Rate - [lb/MMBtu]	0.5700	0.5700	0.1500	0.1500	0.1500
TWh Generated	2.495	2.495	2.451	2.451	2.451
TWh Generated Qualifying	2.495	2.495	2.451	2.451	2.451
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2356.	1017.	1717.

Constraint Name: CFD BART Plant Specific SO2 Constraint	Constraint #: 110
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	7.131	7.131	1.976	1.976	1.976
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.131	7.131	1.976	1.976	1.976
 TBtu Consumed	 26.36	 26.36	 26.35	 26.35	 26.35
Rate - [lb/MMBtu]	0.5410	0.5410	0.1500	0.1500	0.1500
TWh Generated	2.420	2.420	2.379	2.379	2.379
TWh Generated Qualifying	2.420	2.420	2.379	2.379	2.379
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2398.	1127.	1791.

Constraint Name: CFR BART Plant Specific SO2 Constraint	Constraint #: 111
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.649	2.113	2.113	2.113	2.113
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.649	2.113	2.113	2.113	2.113
 TBtu Consumed	 28.17	 28.17	 28.17	 28.17	 28.17
Rate - [lb/MMBtu]	0.3300	0.1500	0.1500	0.1500	0.1500
TWh Generated	2.820	2.810	2.810	2.810	2.810
TWh Generated Qualifying	2.820	2.810	2.810	2.810	2.810
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	318.6	412.6	612.4

Constraint Name: CFZ BART Plant Specific SO2 Constraint	Constraint #: 112
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	25.99	25.99	5.016	5.016	5.016
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	25.99	25.99	5.016	5.016	5.016
 TBtu Consumed	 66.90	 66.90	 66.88	 66.88	 66.88
Rate - [lb/MMBtu]	0.7770	0.7770	0.1500	0.1500	0.1500
TWh Generated	6.389	6.389	6.272	6.272	6.272
TWh Generated Qualifying	6.389	6.389	6.272	6.272	6.272
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1807.	1713.	209.9

Constraint Name: CGI BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 113

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	5.227	5.227	1.479	1.479	1.479
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	5.227	5.227	1.479	1.479	1.479
TBtu Consumed	19.72	19.72	19.72	19.72	19.72
Rate - [lb/MMBtu]	0.5300	0.5300	0.1500	0.1500	0.1500
TWh Generated	1.921	1.921	1.889	1.889	1.889
TWh Generated Qualifying	1.921	1.921	1.889	1.889	1.889
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3756.	3026.	2061.

Constraint Name: CMT BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 114

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	20.24	3.366	3.366	3.366
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	20.24	3.366	3.366	3.366
TBtu Consumed	0.000	43.71	58.04	58.04	58.04
Rate - [lb/MMBtu]	0.000	0.9264	0.1160	0.1160	0.1160
TWh Generated	0.000	3.838	5.030	5.030	5.030
TWh Generated Qualifying	0.000	3.838	5.030	5.030	5.030
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.9124E-04	0.1036E-03	0.7611E-04

Constraint Name: CMU BART Plant Specific SO2 Constraint	Constraint #: 115
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	8.869	8.869	1.318	1.330	1.330
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8.869	8.869	1.318	1.330	1.330
 TBtu Consumed	 17.74	 17.74	 17.58	 17.73	 17.73
Rate - [lb/MMBtu]	1.000	1.000	0.1500	0.1500	0.1500
TWh Generated	1.564	1.564	1.521	1.535	1.535
TWh Generated Qualifying	1.564	1.564	1.521	1.535	1.535
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	848.9	835.3	643.4

Constraint Name: COB BART Plant Specific SO2 Constraint	Constraint #: 116
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	18.87	18.87	4.639	4.639	4.639
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	18.87	18.87	4.639	4.639	4.639
 TBtu Consumed	 61.88	 61.88	 61.85	 61.85	 61.85
Rate - [lb/MMBtu]	0.6100	0.6100	0.1500	0.1500	0.1500
TWh Generated	5.957	5.957	5.853	5.853	5.853
TWh Generated Qualifying	5.957	5.957	5.853	5.853	5.853
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1663.	1481.	1516.

Constraint Name: COC BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 117

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	14.65	14.65	3.916	3.916	3.916
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	14.65	14.65	3.916	3.916	3.916
TBtu Consumed	52.23	52.23	52.21	52.21	52.21
Rate - [lb/MMBtu]	0.5610	0.5610	0.1500	0.1500	0.1500
TWh Generated	4.952	4.952	4.859	4.859	4.859
TWh Generated Qualifying	4.952	4.952	4.859	4.859	4.859
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2457.	2569.	1684.

Constraint Name: COE BART Plant Specific SO2 Constraint	Constraint #: 118
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	14.78	14.78	4.166	4.166	4.166
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	14.78	14.78	4.166	4.166	4.166
 TBtu Consumed	 55.56	 55.56	 55.54	 55.54	 55.54
Rate - [lb/MMBtu]	0.5320	0.5320	0.1500	0.1500	0.1500
TWh Generated	5.212	5.212	5.116	5.116	5.116
TWh Generated Qualifying	5.212	5.212	5.116	5.116	5.116
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1874.	2673.	981.0

Constraint Name: COF BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 119

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	10.50	10.50	2.559	2.593	2.593
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	10.50	10.50	2.559	2.593	2.593
TBtu Consumed	34.58	34.58	34.12	34.57	34.57
Rate - [lb/MMBtu]	0.6070	0.6070	0.1500	0.1500	0.1500
TWh Generated	3.366	3.366	3.264	3.307	3.307
TWh Generated Qualifying	3.366	3.366	3.264	3.307	3.307
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1528.	1399.	1206.

Constraint Name: COH BART Plant Specific SO2 Constraint	Constraint #: 120
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	9.001	9.001	1.350	1.350	1.350
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	9.001	9.001	1.350	1.350	1.350
 TBtu Consumed	 18.00	 18.00	 18.00	 18.00	 18.00
Rate - [lb/MMBtu]	1.000	1.000	0.1500	0.1500	0.1500
TWh Generated	1.750	1.750	1.717	1.717	1.717
TWh Generated Qualifying	1.750	1.750	1.717	1.717	1.717
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	870.0	747.4	735.7

Constraint Name: CRK BART Plant Specific SO2 Constraint	Constraint #: 121
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	17.77	17.77	3.872	3.872	3.872
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	17.77	17.77	3.872	3.872	3.872
TBtu Consumed	51.65	51.65	51.63	51.63	51.63
Rate - [lb/MMBtu]	0.6880	0.6880	0.1500	0.1500	0.1500
TWh Generated	4.974	4.974	4.879	4.879	4.879
TWh Generated Qualifying	4.974	4.974	4.879	4.879	4.879
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1503.	1439.	1032.

Constraint Name: CSA BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 122

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.972	1.446	1.446	1.446	1.446
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.972	1.446	1.446	1.446	1.446
TBtu Consumed	32.87	32.87	32.87	32.87	32.87
Rate - [lb/MMBtu]	0.1200	0.8800E-01	0.8800E-01	0.8800E-01	0.8800E-01
TWh Generated	3.157	3.157	3.157	3.157	3.157
TWh Generated Qualifying	3.157	3.157	3.157	3.157	3.157
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2226E-03	0.2713E-03	0.2047E-03

Constraint Name: CZI BART Plant Specific SO2 Constraint	Constraint #: 123
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	10.14	10.14	2.691	2.691	2.691
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	10.14	10.14	2.691	2.691	2.691
 TBtu Consumed	 35.89	 35.89	 35.88	 35.88	 35.88
Rate - [lb/MMBtu]	0.5650	0.5650	0.1500	0.1500	0.1500
TWh Generated	3.574	3.574	3.513	3.513	3.513
TWh Generated Qualifying	3.574	3.574	3.513	3.513	3.513
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1191.	723.3	1013.

Constraint Name: CZE BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 124

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	72.28	72.28	20.10	20.10	20.10
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	72.28	72.28	20.10	20.10	20.10
TBtu Consumed	268.2	268.2	268.1	268.1	268.1
Rate - [lb/MMBtu]	0.5390	0.5390	0.1500	0.1500	0.1500
TWh Generated	24.85	24.85	24.33	24.33	24.33
TWh Generated Qualifying	24.85	24.85	24.33	24.33	24.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	6319.	5944.	4273.

Constraint Name: CAX BART Plant Specific SO2 Constraint
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 125

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	14.18	15.81	2.557	2.557	2.557
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	14.18	15.81	2.557	2.557	2.557
TBtu Consumed	25.78	28.74	34.09	34.09	34.09
Rate - [lb/MMBtu]	1.100	1.100	0.1500	0.1500	0.1500
TWh Generated	2.255	2.514	2.922	2.922	2.922
TWh Generated Qualifying	2.255	2.514	2.922	2.922	2.922
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	663.0	443.5	69.35