

**SULFUR DIOXIDE AND NITROGEN OXIDES  
COMPLIANCE AND SULFUR DIOXIDE  
RELATIVE ACCURACY TEST  
AUDIT REPORT**

**FOR**

**HUNT REFINING**  
*No. 2 Sulfur Plant*  
*Tuscaloosa, Alabama*

*April 27 and 28, 2010*

**TABLE OF CONTENTS**

INTRODUCTION .....	1
DESCRIPTION OF SAMPLING PROGRAM.....	2
Volumetric Flow Rate Testing .....	2
Oxygen, Nitrogen Oxides, and Sulfur Dioxide Testing .....	2
Relative Accuracy Test Audit .....	3
SUMMARY AND DISCUSSION OF RESULTS .....	4
PROCESS DESCRIPTION.....	15
SAMPLE POINT LOCATION .....	16
VELOCITY SAMPLING PROCEDURE .....	17
OXYGEN, SULFUR DIOXIDE, AND NITROGEN OXIDES SAMPLING PROCEDURE .....	19
Sample Recovery & Analysis .....	21
QUALITY ASSURANCE .....	22
Calibrations .....	22
Pitot Tubes .....	23
Differential Pressure Gauges.....	23
Orifice.....	23
Dry Gas Meter .....	24
Temperature Sensors .....	24
Nozzles .....	25
APPENDIX A QUALITY CONTROL OF VOLUMETRIC FLOW RATE TESTING EQUIPMENT .....	26
APPENDIX B FIELD DATA SHEETS .....	31
APPENDIX C GAS CERTIFICATIONS .....	34
APPENDIX D POLLUTANT MONITOR CONCENTRATIONS.....	40
APPENDIX E SAMPLE CALCULATIONS.....	47
APPENDIX F SULFUR DIOXIDE RATA AND COMPLIANCE APRIL 27, 2010.....	52

**LIST OF TABLES**

TABLE I.	NITROGEN OXIDES EMISSIONS TEST RESULTS APRIL 27, 2010.....	5
TABLE II.	NITROGEN OXIDES TESTING QUALITY ASSURANCE .....	7
TABLE III.	VOLUMETRIC FLOW RATE TEST RESULTS .....	8
TABLE IV.	SULFUR DIOXIDE COMPLIANCE EMISSIONS TEST RESULTS.....	9
TABLE V.	SULFUR DIOXIDE RELATIVE ACCURACY TEST AUDIT EMISSIONS TEST RESULTS.....	10
TABLE VI.	SULFUR DIOXIDE RELATIVE ACCURACY TEST AUDIT.....	11
TABLE VII.	OXYGEN TESTING QUALITY ASSURANCE .....	13
TABLE VIII.	SULFUR DIOXIDE TESTING QUALITY ASSURANCE .....	14

**ILLUSTRATIONS**

FIGURE 1.	NITROGEN OXIDES STACK GAS CONCENTRATIONS .....	6
FIGURE 2.	NO. 2 SULFUR RECOVERY UNIT STACK GAS CONCENTRATIONS – RATA TESTING.....	12
FIGURE 3.	SAMPLE POINT LOCATIONS .....	16
FIGURE 4.	VELOCITY SAMPLING TRAIN.....	17
FIGURE 5.	OXYGEN, SULFUR DIOXIDE, AND NITROGEN OXIDES SAMPLING TRAIN .....	19

## 1. INTRODUCTION

Sanders Engineering & Analytical Services, Inc. (SEAS) performed volumetric flow rate, oxygen, sulfur dioxide, and nitrogen oxides compliance emissions testing for Hunt Refining on the No. 2 Sulfur Plant located at the Tuscaloosa, Alabama facility. A sulfur dioxide relative accuracy test audit was performed on the Continuous Emissions Monitoring System (CEMS). The testing was conducted April 27 and 28, 2010. The testing was performed in accordance with the applicable U.S. EPA procedures specified at **40 CFR, Part 60, Appendix A, Methods 1, 2, 3a, 4, 6c, 7e** and **40 CFR, Part 60, Appendix B, Performance Specification II**. Further discussions of the test methods are included later in the report.

The purpose of the testing was to demonstrate compliance with the rules and regulations of the U. S. Environmental Protection Agency, and to meet the necessary requirements contained in the permit to operate issued by the Alabama Department of Environmental Management. The tests were conducted by Mr. Eric Jones and Mr. Brett Horton of Sanders Engineering & Analytical Services, Inc., and were coordinated with Ms. Casey Frederick of Hunt Refining. Mr. David Oliver of the Alabama Department of Environmental Management was present to observe the testing.

## **2. DESCRIPTION OF SAMPLING PROGRAM**

The sampling program consisted of volumetric flow rate, oxygen, nitrogen oxides, and sulfur dioxide emissions testing in compliance with US EPA methods. The following is a brief description of these types of tests.

### ***2.1. Volumetric Flow Rate Testing***

The quantitative determination of flow rate was made in accordance with **40 CFR, Part 60, Appendix A, Method 2**. This test procedure generally requires the insertion of a pitot tube into the stack at a series of points. The data from the pitot tube was recorded on the field data sheet. The diameter of the stack at the test ports was measured, the area calculated, and the product of area times velocity gave flow rate (cubic feet per minute or other denominations). Calibrations of the volumetric flow rate testing equipment are included in Appendix A. The completed field data sheets are presented in Appendix B. A detailed description of the testing procedures and schematic of the sampling train is presented in Section 6.

### ***2.2. Oxygen, Nitrogen Oxides, and Sulfur Dioxide Testing***

Oxygen, nitrogen oxides, and sulfur dioxide testing was accomplished by withdrawing a sample of the stack gas through a stainless steel probe, a moisture removal system, and into instruments specifically designed for the measurement of the particular pollutants of interest. These instruments responded linearly to concentrations of the pollutants. The output of these instruments is a continuous analog voltage which is digitized and input into a PC based data acquisition system. The PC data acquisition system polls the instruments 1000 times per second. The computer averages these readings into one-second averages during calibrations and one minute averages at other times. These one second and one minute averages are written to the hard disk each minute to ensure no data loss due to power failure or other inadvertent occurrence. The computer stores in memory all calibration and

stack gas analyses during each run. The averages for each calibration and for each independent run were averaged for the time of the runs. A description of the testing procedures is included in Section 7. The gas certifications are included in Appendix C. The pollutant monitor concentrations as supplied by a representative of Hunt Refining are included in Appendix D. Sample calculations of Run 1 on are presented in Appendix E.

### ***2.3. Relative Accuracy Test Audit***

The sulfur dioxide relative accuracy was calculated from the simultaneous measurement of stack gas concentrations by the CEMS and SEAS reference monitors. The calculations and equations are those specified by the U. S. EPA at **40 CFR, Part 60, Appendix B**.

### **3. SUMMARY AND DISCUSSION OF RESULTS**

After the completion of the testing on April 27, 2010, it was discovered the sulfur dioxide RATA did not meet the requirements of **40 CFR, Part 60, Appendix B, Performance Specification II**. The sulfur dioxide compliance and relative accuracy test audit was performed again on April 28, 2010. The results of the sulfur dioxide compliance and relative accuracy test audit performed on April 27, 2010 are included in Appendix F. There were no additional problems experienced during the performance of the testing.

The results of the nitrogen emissions testing performed on April 27, 2010 are presented in Table I. Graphical representations of the stack gas concentrations are presented in Figure 1. The nitrogen oxides testing quality assurance are presented in Table II. The results of the volumetric flow rate testing are presented in Table III.


The results of the oxygen and sulfur dioxide compliance testing performed on April 28, 2010 are presented in Table IV. The results of the sulfur dioxide compliance RATA emissions performed on April 28, 2010 are presented in Table V. Graphical representations of the stack gas concentrations are presented in Figure 2. The results of the sulfur dioxide relative accuracy test audit are presented in Table VI. The sulfur dioxide and oxygen testing quality assurance are presented in Tables VII and VIII.



**TABLE I. NITROGEN OXIDES EMISSIONS  
TEST RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

TEST	Start Time Military	Stop Time Military	Stack Gas Flow Rate (Standard Dry Cubic Feet per Minute)	Water Vapor in Stack Gas (Percent)	Nitrogen Oxides Emissions (ppm-dry)	Nitrogen Oxides Emissions (Lbs/hour)
RUN 1	7:14	8:17	3,618	6.0	4.9	0.13
RUN 2	8:30	9:33	3,487	6.7	5.3	0.13
RUN 3	9:45	10:48	3,407	6.9	5.6	0.14
Average			3,504	6.5	5.3	0.13
Allowable						0.8

Figure 1. Nitrogen Oxides Stack Gas Concentrations



**TABLE II. NITROGEN OXIDES TESTING QUALITY ASSURANCE  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

Analyzer Calibration Data				
INITIAL ANALYZER SPAN (PPM) =		122	ANALYZER ID.	NITROGEN OXIDES
	CYLINDER VALUE PPM	ANALYZER RESPONSE (PPM)	DIFFERENCE (PPM)	DIFFERENCE % SPAN (ALLOWED 2%)
Zero Gas	0.00	0.00	0.0	0.0
High Range Gas	122.00	122.00	0.0	0.0
Mid Range Gas	49.10	47.60	1.5	1.2
NO2 Converter Efficiency	46.63	45.70	Allowed >90%	98.0%

**Test Results & Analyzer Calibration Bias and Drift Data**

data & calculation entry						
START TIME OF RUN	STOP TIME OF RUN	RUN #	ANALYZER STACK GAS CONCENTRATION UNCORRECTED (PPM)	SYSTEM ZERO (PPM)	SYSTEM UPSCALE (PPM)	CYLINDER CONCENTRATION UPSCALE CALIBRATION GAS (PPM)
			INITIAL SYSTEM	0.60	47.30	
7:14	7:35	RUN 1	5.90	1.00	47.20	49.1
7:35	7:56	RUN 2	5.40	1.00	47.20	49.1
7:56	8:17	RUN 3	5.10	1.00	47.20	49.1
8:30	8:51	RUN 4	5.70	0.60	47.80	49.1
8:51	9:12	RUN 5	5.80	0.60	47.80	49.1
9:12	9:33	RUN 6	5.90	0.60	47.80	49.1
9:45	10:06	RUN 7	5.90	1.10	47.40	49.1
10:06	10:27	RUN 8	6.30	1.10	47.40	49.1
10:27	10:48	RUN 9	6.40	1.10	47.40	49.1

system zero bias & drift			system upscale bias & drift			test results	RUN #
INITIAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	ZERO DRIFT % SPAN (ALLOWED 3%)	INITIAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	UPSCALE DRIFT % SPAN (ALLOWED 3%)	NITROGEN DIOXIDE CONCENTRATION (PPM-Dry)	
0.49	0.82	0.33	-0.25	-0.33	-0.1	<b>5.4</b>	RUN 1
0.49	0.82	0.33	-0.25	-0.33	-0.1	<b>4.9</b>	RUN 2
0.49	0.82	0.33	-0.25	-0.33	-0.1	<b>4.5</b>	RUN 3
0.82	0.49	-0.33	-0.33	0.16	0.5	<b>5.2</b>	RUN 4
0.82	0.49	-0.33	-0.33	0.16	0.5	<b>5.3</b>	RUN 5
0.82	0.49	-0.33	-0.33	0.16	0.5	<b>5.4</b>	RUN 6
0.49	0.90	0.41	0.16	-0.16	-0.3	<b>5.3</b>	RUN 7
0.49	0.90	0.41	0.16	-0.16	-0.3	<b>5.7</b>	RUN 8
0.49	0.90	0.41	0.16	-0.16	-0.3	<b>5.8</b>	RUN 9

**TABLE III. VOLUMETRIC FLOW RATE TEST RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

<b>Title of Run</b>		<b><u>RUN 1</u></b>	<b><u>RUN 2</u></b>	<b><u>RUN 3</u></b>
<b>Date</b>	Month/Day/Year	4/27/2010	4/27/2010	4/27/2010
<b>Sampling Time -Start</b>	Military	0714	0830	0945
<b>Sampling Time -Stop</b>	Military	0814	0930	1045
<b>Number of Ports</b>	dimensionless	2	2	2
<b>Number of Points per Port</b>	dimensionless	6	6	6
<b>Stack Static Pressure</b>	Inches Water	-0.45	-0.45	-0.45
<b>Barometric Pressure</b>	Inches Mercury	29.80	29.80	29.80
<b>Standard Orifice Pressure <math>\Delta H</math>@</b>	Inches Water	2.001	2.001	2.001
<b>Meter Correction Factor</b>	dimensionless	0.974	0.974	0.974
<b>Oxygen Concentration</b>	Mole Percent O <sub>2</sub>	5.72	5.70	5.67
<b>Carbon Dioxide Concentration</b>	Mole Percent CO <sub>2</sub>	0.5	0.5	0.5
<b>Volume of Gas Metered</b>	Actual Cubic Feet	40.805	40.600	40.920
<b>Volume of Water Collected</b>	Milliliters	54.4	60.2	61.7
<b>Sampling Time</b>	Minutes	60	60	60
<b>Area of Stack</b>	Square Feet	5.585	5.585	5.585
<b>Avg. Sqr. Root Velocity Pressure</b>	Inches Water	0.2773	0.2675	0.2635
<b>Average Orifice Pressure (<math>\Delta H</math>)</b>	Inches Water	1.5	1.5	1.5
<b>Average Stack Temperature</b>	Degrees F	546	535	548
<b>Average Meter Temperature</b>	Degrees F	62	68	74

### Calculations

		<b><u>RUN 1</u></b>	<b><u>RUN 2</u></b>	<b><u>RUN 3</u></b>	<b><u>AVERAGE</u></b>
<b>Volume of Gas Sampled</b>	Standard Dry Cubic Feet	40.182	39.507	39.426	39.705
<b>Molecular Wt. of Stack Gas (dry)</b>	LB/LB-MOLE	28.31	28.31	28.31	28.31
<b>Water vapor in Stack Gas</b>	Percent	6.0	6.7	6.9	6.5 0
<b>Average Stack Gas Velocity</b>	Feet per second	22.0	21.1	21.0	21.4
<b>Stack Gas Flow Rate</b>	Actual Cubic Feet Per Minute	7,369	7,080	7,024	7,158
<b>Stack Gas Flow Rate</b>	Standard Wet Cubic Feet Per Minute	3,848	3,737	3,658	3,748
<b>Stack Gas Flow Rate</b>	Standard Dry Cubic Feet Per Minute	3,618	3,487	3,407	3,504
<b>Post Test Meter Correction Check</b>	dimensionless	0.96	0.97	0.97	0.97
<b>Percent Difference</b>	Allowed 5% Average	-1.2	-0.2	-0.5	-0.6

**TABLE IV. SULFUR DIOXIDE COMPLIANCE EMISSIONS  
TEST RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Wednesday, April 28, 2010**

<b>TEST</b>	<b>Start Time Military</b>	<b>Stop Time Military</b>	<b>Oxygen ( Dry) (measured) (Percent)</b>	<b>Sulfur Dioxide Emissions (ppm-dry)</b>	<b>Sulfur Dioxide Concentration Corrected to 0.0% O2 (ppm-dry)</b>
<b>RUN 1</b>	9:58	11:02	7.4	55.0	84.9
<b>RUN 2</b>	11:13	12:16	7.1	53.0	80.4
<b>RUN 3</b>	12:26	13:51	7.0	49.4	74.1
<b>Average</b>			<b>7.2</b>	<b>52.5</b>	<b>79.8</b>
<b>Allowable</b>					<b>250</b>

**TABLE V. SULFUR DIOXIDE RATA EMISSIONS TEST  
RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Wednesday, April 28, 2010**

TEST	Start Time Military	Stop Time Military	Oxygen ( Dry) (measured) (Percent)	Sulfur Dioxide Emissions (ppm-dry)	Sulfur Dioxide Concentration Corrected to 0.0% O2 (ppm-dry)
RUN 1	9:58	10:19	7.4	50.9	78.7
RUN 2	10:19	10:40	7.3	55.4	85.0
RUN 3	10:41	11:02	7.4	58.8	90.9
RUN 4	11:13	11:34	7.0	52.2	78.6
RUN 5	11:34	11:55	7.2	54.3	82.8
RUN 6	11:55	12:16	7.2	52.4	79.9
RUN 7	12:26	12:47	7.0	57.8	87.1
RUN 8	13:09	13:30	6.8	45.9	68.2
RUN 9	13:30	13:51	7.0	44.5	67.1
Average			7.2	52.5	79.8

**TABLE VI. SULFUR DIOXIDE RELATIVE ACCURACY TEST AUDIT  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Wednesday, April 28, 2010**

USE	RUN	START TIME Military	STOP TIME Military	Reference Method Sulfur Dioxide Concentration Corrected to 0% O2 (ppm-dry)	Pollutant Monitor Sulfur Dioxide Concentration Corrected to 0% O2 (ppm-dry)	Difference
Y	RUN 1	9:58	10:19	78.7	64.1	14.6
Y	RUN 2	10:19	10:40	85.0	67.5	17.5
Y	RUN 3	10:41	11:02	90.9	72.6	18.3
Y	RUN 4	11:13	11:34	78.6	66.0	12.6
Y	RUN 5	11:34	11:55	82.8	72.9	9.9
Y	RUN 6	11:55	12:16	79.9	69.5	10.4
Y	RUN 7	12:26	12:47	87.1	58.9	28.2
Y	RUN 8	13:09	13:30	68.2	53.8	14.4
Y	RUN 9	13:30	13:51	67.1	49.9	17.2

STD = Emission Standard = 250

$$\text{Average Difference} = \bar{d} = \frac{1}{N} \sum_{i=1}^N d_i = 15.895$$

$$\text{Reference Method Average} = \bar{RM} = \frac{1}{N} \sum_{i=1}^N RM_i = 79.803$$

$$\text{Pollutant Monitor Average} = PR_{ave} = \frac{1}{N} \sum_{i=1}^N PR_i = 63.908$$

$$\text{Standard Deviation} = S_d = \sqrt{\frac{1}{N-1} \left\{ \sum_{i=1}^n d_i^2 - n\bar{d}^2 \right\}} = 5.510$$

$$\text{Confidence Coefficient} = |cc| = t_{0.975} \frac{S_d}{\sqrt{N}} = 4.236$$

$$\text{Relative Accuracy} = \frac{|\bar{d}| + |cc|}{\text{STD. Allowable}} \times 100 = 8.052$$

Allowable = 10.000

Figure 2. No. 2 SRU Stack Gas Concentrations - RATA Testing






TABLE VII. OXYGEN TESTING QUALITY ASSURANCE  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Wednesday, April 28, 2010

**Analyzer Calibration Data**

INITIAL ANALYZER SPAN (Percent) =		21	ANALYZER ID.		OXYGEN
	CYLINDER VALUE Percent	ANALYZER RESPONSE (Percent)	DIFFERENCE (Percent)		DIFFERENCE % SPAN (ALLOWED 2%)
Zero Gas	0.00	0.00	0.0		0.0
High Range Gas	20.90	20.90	0.0		0.0
Mid Range Gas	10.60	10.60	0.0		0.0

**Test Results & Analyzer Calibration Bias and Drift Data**

data & calculation entry						
START TIME OF RUN	STOP TIME OF RUN	RUN #	ANALYZER STACK GAS CONCENTRATION UNCORRECTED (Percent)	SYSTEM ZERO (Percent)	SYSTEM UPSCALE (Percent)	CYLINDER CONCENTRATION UPSCALE CALIBRATION GAS (Percent)
			INITIAL SYSTEM	-0.10	10.50	
9:58	10:19	RUN 1	7.30	0.00	10.50	10.6
10:19	10:40	RUN 2	7.20	0.00	10.50	10.6
10:41	11:02	RUN 3	7.30	0.00	10.50	10.6
11:13	11:34	RUN 4	7.00	0.00	10.70	10.6
11:34	11:55	RUN 5	7.20	0.00	10.70	10.6
11:55	12:16	RUN 6	7.20	0.00	10.70	10.6
12:26	12:47	RUN 7	7.10	0.00	10.70	10.6
13:09	13:30	RUN 8	6.90	0.00	10.70	10.6
13:30	13:51	RUN 9	7.10	0.00	10.70	10.6

system zero bias & drift			system upscale bias & drift			test results	RUN #
INITIAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	ZERO DRIFT % SPAN (ALLOWED 3%)	INITIAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	UPSCALE DRIFT % SPAN (ALLOWED 3%)	OXYGEN CONCENTRATION (Percent-Dry)	
-0.48	0.00	0.48	-0.48	-0.48	0.0	7.4	RUN 1
-0.48	0.00	0.48	-0.48	-0.48	0.0	7.3	RUN 2
-0.48	0.00	0.48	-0.48	-0.48	0.0	7.4	RUN 3
0.00	0.00	0.00	-0.48	0.48	1.0	7.0	RUN 4
0.00	0.00	0.00	-0.48	0.48	1.0	7.2	RUN 5
0.00	0.00	0.00	-0.48	0.48	1.0	7.2	RUN 6
0.00	0.00	0.00	0.48	0.48	0.0	7.0	RUN 7
0.00	0.00	0.00	0.48	0.48	0.0	6.8	RUN 8
0.00	0.00	0.00	0.48	0.48	0.0	7.0	RUN 9

**TABLE VIII. SULFUR DIOXIDE TESTING QUALITY ASSURANCE  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Wednesday, April 28, 2010**

**Analyzer Calibration Data**

INITIAL ANALYZER SPAN (PPM) =		125	ANALYZER ID.	SULFUR DIOXIDE
	CYLINDER VALUE PPM	ANALYZER RESPONSE (PPM)	DIFFERENCE (PPM)	DIFFERENCE % SPAN (ALLOWED 2%)
Zero Gas	0.00	0.00	0.0	0.0
High Range Gas	125.00	125.00	0.0	0.0
Mid Range Gas	50.03	49.00	1.0	0.8

**Test Results & Analyzer Calibration Bias and Drift Data**

data & calculation entry						
START TIME OF RUN	STOP TIME OF RUN	RUN #	ANALYZER STACK GAS CONCENTRATION UNCORRECTED (PPM)	SYSTEM ZERO (PPM)	SYSTEM UPSCALE (PPM)	CYLINDER CONCENTRATION UPSCALE CALIBRATION GAS (PPM)
			INITIAL SYSTEM	2.50	46.00	
9:58	10:19	RUN 1	46.30	3.50	45.10	50.03
10:19	10:40	RUN 2	50.10	3.50	45.10	50.03
10:41	11:02	RUN 3	53.00	3.50	45.10	50.03
11:13	11:34	RUN 4	47.00	3.10	45.20	50.03
11:34	11:55	RUN 5	48.70	3.10	45.20	50.03
11:55	12:16	RUN 6	47.10	3.10	45.20	50.03
12:26	12:47	RUN 7	51.80	1.30	45.10	50.03
13:09	13:30	RUN 8	41.60	1.30	45.10	50.03
13:30	13:51	RUN 9	40.40	1.30	45.10	50.03

system zero bias & drift			system upscale bias & drift			test results	RUN #
INITIAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	ZERO DRIFT % SPAN (ALLOWED 3%)	INITIAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	UPSCALE DRIFT % SPAN (ALLOWED 3%)	SULFUR DIOXIDE CONCENTRATION (PPM-Dry)	
2.00	2.80	0.80	-2.40	-3.12	-0.7	<b>50.9</b>	RUN 1
2.00	2.80	0.80	-2.40	-3.12	-0.7	<b>55.4</b>	RUN 2
2.00	2.80	0.80	-2.40	-3.12	-0.7	<b>58.8</b>	RUN 3
2.80	2.48	-0.32	-3.12	-3.04	0.1	<b>52.2</b>	RUN 4
2.80	2.48	-0.32	-3.12	-3.04	0.1	<b>54.3</b>	RUN 5
2.80	2.48	-0.32	-3.12	-3.04	0.1	<b>52.4</b>	RUN 6
2.48	1.04	-1.44	-3.04	-3.12	-0.1	<b>57.8</b>	RUN 7
2.48	1.04	-1.44	-3.04	-3.12	-0.1	<b>45.9</b>	RUN 8
2.48	1.04	-1.44	-3.04	-3.12	-0.1	<b>44.5</b>	RUN 9


#### **4. PROCESS DESCRIPTION**

The process consists of a crude oil refinery. Hydrogen sulfide is removed from various locations in the refining process. The hydrogen sulfide is fed to the three-stage modified Claus plant where a portion of the sulfur is oxidized to sulfur dioxide. The products of the combustion are passed through the Claus process for the conversion of sulfur to elemental sulfur, which is stored as a liquid in the sulfur pit. The gases from the Claus plant are fed to a Scot Tail Gas Unit for absorption of the remaining sulfur dioxide and hydrogen sulfide gases which are recycled back to the beginning of the Claus Plant. The remaining gases are fed to an incinerator for complete oxidation of any uncollected hydrogen sulfide to sulfur dioxide before discharge into the atmosphere. The test ports were located in the stack.

## 5. SAMPLE POINT LOCATION

The sample point locations and outlet duct schematic for Hunt Refining, No. 2 Sulfur Recovery Unit, are presented in Figure 3.

**Figure 3. Sample Point Locations**




## 6. VELOCITY SAMPLING PROCEDURE (EPA Methods 1, 2, 3, and 4)

The sampling procedure utilized is that specified in **40 CFR, Part 60, Appendix A, Methods 1, 2, 3, and 4**. A brief description of this procedure is as follows:

The first two impingers were partially filled with 100 milliliters of deionized water. The next impinger was left empty to act as a moisture trap. Prew weighed 6 to 16 mesh indication silica gel was added to the last impinger. The sampling equipment manufactured by Lear Siegler (Model 100) or Sanders Engineering (Model 200) was assembled as shown in the attached drawing. The system was leak checked by plugging

**Figure 4. Velocity Sampling Train**



the inlet to the nozzle and pulling a 15 inch mercury vacuum. A leakage rate not in excess of 0.02 cubic feet per minute was considered acceptable.

The inside dimensions of the stack liner were measured and recorded. The required number of measurement points was marked on the probe for easy visibility. Crushed ice was placed around the impingers. The S-type pitot was placed on the first traverse point with the tip pointing directly into the gas stream.

The pump was started and the flow was adjusted to approximately 0.75 cubic feet per minute sampling rate or a delta H of 1.5 inches of water. The probe was repositioned to the next traverse point for measurement of velocity pressure and stack temperature. This was performed for each point until the run was completed. Readings were taken at each point and recorded on the field data sheet. At the conclusion of each run, the pump was turned off, final readings were recorded, and final system leak checks were performed.

Care was exercised in moving the collection train to the sample recovery area to minimize the loss of collected sample, or the gain of extraneous water. The volume of water in the impingers was measured, the silica gel impinger was weighed, and these data recorded on the field data sheet. The S-type pitot tube was inspected to ensure that it continued to meet the geometric specifications of construction necessary to maintain its calibration.


## 7. OXYGEN, SULFUR DIOXIDE, AND NITROGEN OXIDES SAMPLING PROCEDURE (EPA Methods 3a, 6c, and 7e)

The sampling procedures utilized are those specified in **40 CFR, Part 60, Appendix A, Methods 3a, 6c, and 7e** as modified by the governing regulatory agency. A brief description of these procedures is as follows:

The sample was removed from the stack through a stainless steel probe and passed through a three-way valve and condenser moisture removal system. Teflon® line was used to transport the sample through a transport pump and a flow control valve. From this point the sample was routed into a manifold with a bypass valve, an analyzer sample flow control valve, and to an analyzer specific for the pollutant of interest. Each analyzer produces a voltage analogue output proportional to the concentration of pollutant present in the gas. A schematic of the sampling train is presented in the attached drawing.

Each instrument was allowed to warm up for at least 30 minutes before it was initially calibrated. Zero air was introduced directly to each instrument to establish a baseline and check the zero reading of the instrument. A high range

**Figure 5. Oxygen, Sulfur Dioxide, and Nitrogen Oxides Sampling Train**



calibration gas was introduced directly to each instrument. The instrument was allowed to fully respond to the calibration gas. Each analyzer was adjusted, if needed, to the correct value. A linear calibration curve was calculated from this data and stored on computer. Next, a mid-range calibration gas was introduced directly to each instrument. The percent error between each measured value and the corresponding calibration value was calculated. If any of the readings indicated a difference of more than  $\pm 2$  percent of the span the analyzer was recalibrated.

The high or mid gas and zero gas were then introduced to the system at the three-way valve before the condenser. The response value for each of these gases was recorded. If these measured values differed significantly from the calibration values the sampling system was checked and repaired until the system check met EPA specifications.

To begin sampling, the three-way valve was switched to allow the instrument to sample the stack gas. Twice the system response time was allowed to elapse before the data recorder was marked for the beginning of the run. After the required sampling time, the data recorder was marked for the end of the run. At the end of each run the three-way valve was switched to allow introduction of the zero and calibration gas to the system. From these data the calibration bias and drift were calculated. If the bias values were greater than  $\pm 5$  percent of the span, or the drift was greater than three percent of the span, the run was invalidated. To begin the next run the three-way valve was switched to allow sampling of the stack gas and the next run was started. This procedure was repeated until all runs were complete.



### ***7.1. Sample Recovery & Analysis***

After the tests were completed the data was reduced to give an average concentration in parts per million for each run. This average concentration was then corrected for the analyzer zero and span bias and drift using the equation:

$$C_{\text{gas}} = \frac{(C - C_o) C_{\text{ma}}}{(C_m - C_o)}$$

Where:

$C_{\text{gas}}$  = Effluent gas Concentration, dry basis, ppm.

$C$  = Average gas concentration indicated by the gas analyzer, dry basis, ppm.

$C_o$  = Average of Initial and final system calibration responses for the zero gas, ppm.

$C_m$  = Average of initial and final calibration responses for the upscale calibration gas, ppm.

$C_{\text{ma}}$  = Actual concentration of the scale calibration gas, ppm.

## **8. QUALITY ASSURANCE**

In order to ensure the accuracy of all the data collected in the field and at the laboratory, SEAS has instituted a comprehensive quality assurance and quality control program. New or repaired items requiring calibration are calibrated before their initial use in the field. Equipment with calibration that may change with use is calibrated before and after each use. When an item is found to be out of calibration the unit is either discarded or repaired and recalibrated before being returned to service. All equipment is periodically recalibrated in full regardless of the results of the regular inspections or its present calibration status. Calibrations are performed in a manner consistent with the EPA reference methods recommended in the “Quality Assurance Handbook for Air Pollution Measurement Systems” published by the US Environmental Protection Agency. To the maximum degree possible all calibrations are traceable to the National Institute of Standards & Technology (NIST). SEAS is a LELAP certified laboratory.

In order to ensure that the testing will be performed in a timely manner without undue delays, SEAS sampling vans are equipped with duplicate sampling devices for almost every device needed to perform the test. If a particular device is broken or does not pass inspection a second device is available immediately at the site for use. Any device which appears to be outside calibration, or is in need of repair, is tagged in the field and repaired, calibrated, or discarded immediately upon return to the laboratory.

### ***8.1. Calibrations***

Certain pieces of equipment need to be calibrated before and after each test. Those items include pitot tubes, differential pressure gauges, dry gas meter, and nozzles used for the particulate testing. The following is a brief description of the calibration procedures for each of these important devices.

### ***8.1.1. Pitot Tubes***

All pitot tubes are the S-type as required by EPA Reference Method 2 (**40 CFR, Part 60, Appendix A, Method 2**). This method contains certain geometric standards for the construction of S-type pitot tubes. All of SEAS pitot tubes are constructed according to these standards. According to the EPA, any pitot tube constructed to these standards will have a coefficient of  $0.84 \pm 0.02$ . To ensure the exact value of SEAS pitot tubes all pitot tubes are initially calibrated in SEAS wind tunnel to determine the exact pitot coefficient. This coefficient should not change unless the pitot is physically damaged. Each pitot tube is checked before going to the field to make sure it meets the geometry as specified. Any pitot tube that fails to meet the specifications is not used in the test.

### ***8.1.2. Differential Pressure Gauges***

SEAS uses several different types of pressure gauges, including oil tube manometers, water tube manometers, magnehelics, and current output electronic load cells. Each of these devices are inspected before taken to the field and are inspected for leaks during each test. The magnehelics and load cells are tested against an incline manometer water gauge to ensure accuracy.

### ***8.1.3. Orifice***

The flow meter orifice is used to establish isokinetic sampling rates during the test. The orifice is calibrated with the dry gas meter at the same time under the same conditions. The orifice is calibrated over a wide range of flow rates and the arithmetic mean of the orifice calibration is used for sampling purposes. The orifice is recalibrated every time the gas meter is re-certified.

#### ***8.1.4. Dry Gas Meter***

The dry gas meter is calibrated every six months against a spirometer transfer standard. It is again calibrated before and after each use in the field. During the semiannual calibration, a five-point calibration is made at a minimum of one-half inch water column orifice pressure and up to four inches water column orifice pressure. Before and after each test, the dry gas meter is again recalibrated at three repetitions at a representative flow rate experienced during the test. If the final calibration does not agree with the initial calibration within five percent, the calibration which yields the lowest volume of sample pulled is used in the calculations and the dry gas meter is repaired and recalibrated.

#### ***8.1.5. Temperature Sensors***

All temperature sensors used in SEAS sampling program are either mercury in-glass thermometers or type K thermocouples. These thermocouples are physical devices which produce a voltage proportional to the temperature. The thermocouple reading device is calibrated before and after each series of tests to ensure accuracy of  $\pm 2$  percent. The calibration of the thermocouple is accomplished by a NIST traceable calibrated reference thermocouple potentiometer system.

#### ***8.1.6. Nozzles***

The inside diameter of each nozzle is measured to the nearest 0.001 inches prior to its initial use. Upon arriving in the field each nozzle is again measured with a micrometer on three different points on the diameter to ensure its original measurement and that the nozzle is perfectly round. If the difference between the maximum and minimum diameters measured does not exceed 0.003 inches the nozzle is acceptable; otherwise, this nozzle is discarded and another is selected. At the end of each test the nozzles are again remeasured on three different points on the diameter to ensure that during the test the nozzle has not become dented or deformed.

**APPENDIX A QUALITY CONTROL OF VOLUMETRIC FLOW RATE  
TESTING EQUIPMENT**

## INITIAL METER BOX CALIBRATION

Calibrated By: JEJ

**BOX #: S-102**

Date: 9/22/2008

			Orifice #:	1	Orifice #:	3	Orifice #:	8	Reference	33103	Unit	RUN 4	RUN 5					
		Unit	RUN 1	RUN 2	RUN 1	RUN 2	RUN 1	RUN 2	Field Meter	DH	In. H <sub>2</sub> O	3.40	3.28					
Meter	DH	In. H <sub>2</sub> O	0.73	0.73	1.20	1.20	1.70	1.70	Initial Gas Volume	Ft. <sup>3</sup>	807.000	813.800						
Initial Gas Volume		Ft. <sup>3</sup>	768.200	799.500	754.900	761.400	743.500	748.800			Final Gas Volume	Ft. <sup>3</sup>	813.215	819.200				
Final Gas Volume		Ft. <sup>3</sup>	799.200	805.300	761.200	767.700	748.600	753.900					Initial Temp. Out	°F	75	75		
Initial Temp. Out		°F	75	74	75	75	74	75			Final Temp. Out	°F			75	75		
Final Temp. Out		°F	74	75	75	75	75	75					Reference Meter	Y	Dimensionless	0.952	0.952	
	Vacuum	In. Hg	20.0	20.0	18.0	18.0	17.0	17.0			Initial Gas Volume	Ft. <sup>3</sup>				467.650	474.370	
	Ambient Temp.	°F	74	72	73	75	72	73								Final Gas Volume	Ft. <sup>3</sup>	473.793
Barometric Pressure		In. Hg	30.15	30.15	30.15	30.15	30.15	30.15			Initial Temp.	°F						75
	Time	sec	4003	747	634	634	427	428	Final Temp.	°F						75	75	
	K'		0.3499	0.3499	0.4443	0.4443	0.5237	0.5237			Barometric Pressure					In. Hg	30.15	30.150
CALCULATIONS									Time		sec	366				330		
Total Meter Gas Volume		Actual Ft. <sup>3</sup>	31.000	5.800	6.300	6.300	5.100	5.100	Volume Field Meter		ACF	6.22				5.400		
	Time	Minutes	66.717	12.450	10.567	10.567	7.117	7.133	Volume Field Meter		SDCF	6.230	5.411					
Volume through the Meter		SDCF without Y	30.901	5.781	6.281	6.281	5.096	5.091	Volume Reference Meter		ACF	6.14	5.300					
Volume through the Orifice		SDCF	30.458	5.694	6.131	6.120	4.872	4.879	Volume Reference Meter		SDCF	6.107	5.269					
Calculated Y		Dimensionless	0.986	0.985	0.976	0.974	0.956	0.958				0.980	0.974	0.974				
	Difference	Allowable 0.02	0.012	0.011	0.002	0.001	-0.018	-0.015				0.007	0.000					
Calculated DH@			1.968	1.961	2.006	2.013	2.048	2.050				1.929	2.032	2.001				
	Difference	Allowable 0.2	-0.033	-0.040	0.005	0.012	0.047	0.049				-0.072	0.031					

## Magnehelic Calibrations

Device	Calibration	Delta P	
	Standard	Magnehelic	
Units	inches water	inches water	Percent
Reading	Reference	Sample	Error
1	1.79	1.85	3.4
2	0.92	0.96	4.3
3	0.44	0.46	4.5

Allowed Error = 5% of Reading

## Thermocouple Calibrations

Device	Calibration	Thermocouple	
	Standard	Detector	
Units	Degrees F.	Degrees F.	Percent
Reading	Reference	Sample	Error
1	750	758	0.7
2	400	405	0.6
3	100	103	0.5

Allowed Error = 1.5% of Absolute Temperature (Degrees Rankin);

Absolute Temperature = Temperature in Degrees Fahrenheit. + 460

Magnehelic Calibration												
serial number	101			102A			102C			103A		
Span (in H2O)	0.25	2	25	0.25	2	25	0.25	2	25	0.25	2	10
Reference Reading @ 0% Span (in H2O)	0.000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Device Reading (in H2O)	0.000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
% Difference (Allowed = 0.05)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Reference Reading @ 50% Span (in H2O)	0.120	0.95	4.73	0.125	1.00	9.64	0.131	0.90	9.30	0.12	0.95	5.15
Device Reading (in H2O)	0.122	0.96	4.90	0.126	0.98	9.75	0.129	0.88	9.00	0.12	0.92	5.20
% Difference (Allowed = 0.05)	1.67	1.05	3.59	0.80	2.00	1.14	1.53	2.22	3.23	2.56	3.16	0.97
Reference Reading @ 90% Span (in H2O)	0.220	1.88	23.50	2.32	1.85	23.30	0.250	2.00	22.80	0.248	1.91	9.50
Device Reading (in H2O)	0.222	1.83	24.20	2.300	1.90	24.00	0.243	1.97	23.30	0.240	1.95	9.20
% Difference (Allowed = 0.05)	0.91	2.66	2.98	0.86	2.70	3.00	2.80	1.50	2.19	3.23	2.09	3.16




serial number	103B						104		
Span (in H2O)	0.25	0.5	1	2	5	25	0.25	2	10
Reference Reading @ 0% Span (in H2O)	0.000	0.000	0.000	0.00	0.00	0.00	0.000	0.00	0.00
Device Reading (in H2O)	0.000	0.000	0.000	0.00	0.00	0.00	0.000	0.00	0.00
% Difference (Allowed = 0.05)	0.000	0.00	0.00	0.00	0.00	0.00	0.000	0.00	0.00
Reference Reading @ 50% Span (in H2O)	0.130	0.260	0.50	9.40	2.43	9.70	0.120	0.99	4.73
Device Reading (in H2O)	0.124	0.260	0.48	9.40	2.54	9.50	0.120	0.98	4.90
% Difference (Allowed = 0.05)	4.615	0.00	4.00	0.00	4.53	2.06	0.000	1.02	3.47
Reference Reading @ 90% Span (in H2O)	0.261	0.500	0.85	1.89	4.52	24.5	0.248	1.67	8.20
Device Reading (in H2O)	0.249	0.495	0.81	1.88	4.64	25.0	0.240	1.74	8.60
% Difference (Allowed = 0.05)	4.598	1.00	4.71	0.53	2.65	2.04	3.333	4.02	4.65

serial number	105			106		
Span (in H2O)	0.25	2	25	0.5	4	15
Reference Reading @ 0% Span (in H2O)	0.000	0.00	0.00	0.000	0.00	0.00
Device Reading (in H2O)	0.000	0.00	0.00	0.000	0.00	0.00
% Difference (Allowed = 0.05)	0.000	0.00	0.00	0.000	0.00	0.00
Reference Reading @ 50% Span (in H2O)	0.122	0.97	8.90	0.233	1.86	8.00
Device Reading (in H2O)	0.123	0.95	9.30	0.232	1.95	7.90
% Difference (Allowed = 0.05)	0.820	2.11	4.30	0.431	4.62	1.27
Reference Reading @ 90% Span (in H2O)	0.239	1.92	24.5	0.470	3.60	14.4
Device Reading (in H2O)	0.235	1.98	23.7	0.461	3.60	14.8
% Difference (Allowed = 0.05)	1.702	3.03	3.38	1.952	0.00	2.70
Calibration Date 12/30/2008 By MC						




### Type S pitot tube construction details:

- a) end view; face opening planes perpendicular to transverse axis.
- b) top view; face opening planes parallel to longitudinal axis.
- c) side view; both legs of equal length and centerlines coincident, when viewed from both sides.



## Sampling Nozzle, Thermocouple, and Probe Configuration



**APPENDIX B FIELD DATA SHEETS**

## Sanders Engineering &amp; Analytical Services, Inc.

Moisture - EPA Method 4

COMPANY Hunt DATE 4-27-10 BOX No. \_\_\_\_\_ DHa 2.001 Y .974  
 PLANT Tuscaloosa OPERATOR LS/BH UNIT #2 SRU  
 BALANCE No. 105 STD. WT. (gm) 2000 BALANCE RESPONSE (gm) 1997.6

Run # 1						Run # 2						Run # 3								
METER READING			LEAK CHECK			METER READING			LEAK CHECK			METER READING			LEAK CHECK					
099.905			Pre Post			140.800			Pre Post			181.920			Pre Post					
059.100			10 5			100.200			8 6			141.000			10					
40.805			0.00 0.00			40.600			0.00 0.00			40.920			0.00					
VOLUME OF LIQUID WATER COLLECTED ml. - gr.						VOLUME OF LIQUID WATER COLLECTED ml. - gr.						VOLUME OF LIQUID WATER COLLECTED ml. - gr.								
Imp 1	Imp 2	Imp 3	Imp 4	Imp 1	Imp 2	Imp 3	Imp 4	Imp 1	Imp 2	Imp 3	Imp 4	Imp 1	Imp 2	Imp 3	Imp 4					
140	0		1749.9	154	0		1756.1	152	0		1755.8	100	0		1756.1					
100	0		1735.5	100	0		1749.9	100	0		1756.1	52	0		9.7					
40	0		14.4	54	0		6.2	52	0		9.7									
Total 54.4				Total 60.2				Total 61.7												
Pressure			Gas Analysis			Pressure			Gas Analysis			Pressure			Gas Analysis					
STATIC	BAROMETRIC	O <sub>2</sub> %	CO <sub>2</sub> %	CO %		STATIC	BAROMETRIC	O <sub>2</sub> %	CO <sub>2</sub> %	CO %		STATIC	BAROMETRIC	O <sub>2</sub> %	CO <sub>2</sub> %	CO %				
-45	29.8		0.5	-		-45	29.8		0.5	-		-45	29.8		0.5	-				
Time			Gas Meter Volume	ΔH	Meter Temp	Imp. Temp	Time			Gas Meter Volume	ΔH	Meter Temp	Imp. Temp	Time			Gas Meter Volume	ΔH	Meter Temp	Imp. Temp
7:14	59.100	1.5	60	45	8:30	100.200	1.5	65	48	9:45	181.920	1.5	72	45	8:45	141.000	1.5	72	45	
6:19	62.1	1.5	60	45	7:38	103.5	1.5	65	48	8:50	144.4	1.5	72	45	8:55	147.8	1.5	72	45	
6:24	65.3	1.5	60	45	7:40	106.9	1.5	66	47	9:00	151.2	1.5	72	45	9:05	154.6	1.5	73	49	
6:29	068.8	1.5	60	45	7:45	110.3	1.5	67	47	9:10	158.0	1.5	73	48	9:15	161.4	1.5	73	50	
6:34	072.6	1.5	61	47	7:50	113.7	1.5	67	47	9:20	164.8	1.5	74	50	9:25	168.2	1.5	75	51	
6:39	076.0	1.5	61	47	7:55	117.1	1.5	68	48	9:30	171.6	1.5	75	52	9:35	175.0	1.5	76	52	
6:44	079.3	1.5	62	48	8:00	120.6	1.5	69	48	9:40	178.4	1.5	76	55	10:45	181.920				
6:49	082.7	1.5	63	48	8:05	124.0	1.5	69	48											
6:54	086.1	1.5	64	50	8:10	127.4	1.5	70	49											
6:59	089.5	1.5	64	52	8:15	130.8	1.5	71	50											
7:04	092.9	1.5	65	52	8:20	134.1	1.5	71	50											
7:09	096.2	1.5	65	54	8:25	137.4	1.5	72	50											
8:14	099.905				8:30	140.800														

Form Revised 2/15/10

Comments:

*Handwritten signature*  
 4/27/10  
 ADEM

## Velocity & Temperature Field Data Sheet

Company: Hunt Plant: Tuscola Unit: #2 SRU Date: 4-27-18

Run:	1		2		3			
Duct Dimensions:								
Start/Finish Time:	8:15 / 8:20		8:32 / 8:37		9:46 / 9:51		1	
% O <sub>2</sub> :		% CO <sub>2</sub> :		% CO <sub>2</sub> :		% CO <sub>2</sub> :		% CO <sub>2</sub> :
% H <sub>2</sub> O: Dry Bulb (°F)		Wet Bulb		Wet Bulb		Wet Bulb		Wet Bulb
Pbar:		Static: - .45		Static: - .45		Static: - .45		Static:
Team Members:	EJ / BH		EJ / BH		EJ / BH			
Post Leak check	✓		✓		✓			

[illegible]

Form Revised 8/24/02

duo  
Adam  
4/27/10

**APPENDIX C GAS CERTIFICATIONS**

## Certificate of Analysis

### EPA Protocol Gas Mixture

Component	Requested Concentration	Certified Concentration	Accuracy	Procedure
Nitrogen Dioxide	50 PPM	46.63 PPM	+/- 1 %	G1
Air	Balance	Balance		

Component		Standard Cylinder		Reference Number		Reference Concentration	
Nitrogen Dioxide		CAL015669		1684b		97.45 PPM	
Instrument Make-Model		Serial Number		Analytical Principle		Calibration date	
Eco Physics - CLD 700 EL		73236		Chemiluminescence		11 Mar 2008	
1st Analysis		Date: 02/29/08		2nd Analysis		Date: 03/11/08	
R 97.50	S 46.80	Z 0.00		R 97.50	S 46.50	Z 0.00	
S 46.80	Z 0.00	R 97.50		S 46.50	Z 0.00	R 97.50	
Z 0.00	R 97.50	S 46.80		Z 0.00	R 97.50	S 46.50	
1st Analysis						46.78	
2nd Analysis						46.48	
Relative Difference						0.64%	

Do not use this cylinder below 150 psig.

Authorizing Signature:

*Tuscaloosa, AL*

**SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.**

Phone: 251-633-4120

Fax: 251-633-2285

2255 Schillinger Road N.

Semmes, AL 36575

**RECERTIFICATION OF ANALYSIS**

<b>CUSTOMER</b>	<b>CYLINDER NO</b>	CC252285
	<b>EXPIRATION DATE</b>	9/12/2010
<b>Sanders Engineering</b>	<b>ORIGINAL CERTIFICATION DATE</b>	3/12/2008
2255 Schillinger Rd. N	<b>RECERTIFICATION DATE</b>	3/12/2010
Mobile, AL 36575	<b>PART NUMBER</b>	NA
	<b>REFERENCE NUMBER</b>	NA

Do not use this cylinder below 150 psig. i.e. 1.0 Megapascal

**Analytical Results**

<b><u>Component</u></b>	<b><u>Certified Concentration on 03/12/08</u></b>	<b>46.63 ppm</b>
Nitrogen Dioxide	<b><u>Reanalyzed Concentration on 3/12/10</u></b>	<b>45.26 ppm</b>

Reanalysis is within 5 % of Original Certification. Certified Concentration is the Original Value.

**Analytical Instruments Used in Assay**

<b><u>Instrument/Make/Model</u></b>	<b><u>Analytical Principle</u></b>	<b><u>Last Multipoint Calibration Check</u></b>
TEMET Gasmet DX4000	FTIR	3/12/2010



IWS Gas and Supply  
111 Buras Drive  
Belle Chasse, LA 70037  
504-392-2400

### Certificate of Analysis EPA Protocol Gas Mixture

Cylinder Number	EB0016156	Customer	Southern Gas & Supply	Certification Date	30 Mar 2009
Cylinder Size	150AL			Expiration Date	30 Mar 2011
Cylinder Pressure	2000 psig			Lot Number	0903180419
Cylinder Contents	148 ft3	PO Number	327047-1	Part Number	GSPE5NB150AG05C
Cylinder CGA	660				

Component	Requested Concentration	Certified Concentration	Accuracy	Procedure
Carbon Monoxide	50 PPM	49.79 PPM	+/- 1 %	G1
Nitric Oxide	50 PPM	49.10 PPM	+/- 1 %	G1
Sulfur Dioxide	50 PPM	50.03 PPM	+/- 1 %	G1
Carbon Dioxide	10 %	9.902 %	+/- 1 %	G1
Nitrogen	Balance	Balance	NOX conc. = 49.1 PPM	

Component	Standard Cylinder	Reference Number	Reference Concentration
Carbon Monoxide	CC250365	GMIS	247.8 PPM
Instrument Make-Model		Serial Number	
Siemens - Ultramat 6		N1-U5-0234	
Analytical Principle		Calibration date	
NDIR		16 Mar 2009	
1st Analysis		Date: 03/23/09	
2nd Analysis		Date: 03/30/09	
R 247.80 S 49.72 Z 0.00	R 247.80 S 49.85 Z 0.00	1st Analysis	49.72
S 49.72 Z 0.00 R 247.80	S 49.85 Z 0.00 R 247.80	2nd Analysis	49.85
Z 0.00 R 247.80 S 49.72	Z 0.00 R 247.80 S 49.85	Relative Difference	0.26%

Component	Standard Cylinder	Reference Number	Reference Concentration
Nitric Oxide	CC250374	GMIS	96.6 PPM
Instrument Make-Model		Serial Number	
Eco Physics - CLD 700 EL		73236	
Analytical Principle		Calibration date	
Chemiluminescence		16 Mar 2009	
1st Analysis		Date: 03/23/09	
2nd Analysis		Date: 03/30/09	
R 96.60 S 49.00 Z 0.00	R 96.60 S 49.20 Z 0.00	1st Analysis	49.00
S 49.00 Z 0.00 R 96.60	S 49.20 Z 0.00 R 96.60	2nd Analysis	49.20
Z 0.00 R 96.60 S 49.00	Z 0.00 R 96.60 S 49.20	Relative Difference	0.41%

Component	Standard Cylinder	Reference Number	Reference Concentration
Sulfur Dioxide	CC250503	GMIS	48.55 PPM
Instrument Make-Model		Serial Number	
Siemens - Ultramat 6		N1-U5-0236	
Analytical Principle		Calibration date	
NDIR		16 Mar 2009	
1st Analysis		Date: 03/23/09	
2nd Analysis		Date: 03/30/09	
R 48.55 S 50.00 Z 0.00	R 48.55 S 50.06 Z 0.00	1st Analysis	50.00
S 50.00 Z 0.00 R 48.55	S 50.06 Z 0.00 R 48.55	2nd Analysis	50.06
Z 0.00 R 48.55 S 50.00	Z 0.00 R 48.55 S 50.06	Relative Difference	0.12%

Component	Standard Cylinder	Reference Number	Reference Concentration
Carbon Dioxide	CAL016183	SRM2745	15.633 %
Instrument Make-Model		Serial Number	
Siemens - Ultramat/Oxymat 6		N1-U5-0235	
Analytical Principle		Calibration date	
NDIR/Paramagnetic		16 Mar 2009	
1st Analysis		Date: 03/30/09	
R 15.633 S 9.902 Z 0.000		1st Analysis	9.902
S 9.902 Z 0.000 R 15.633			
Z 0.000 R 15.633 S 9.902			

This calibration standard certified per the 1997 EPA Traceability Protocol (EPA-600/97/121), using procedure listed.  
All values, excluding NOX concentration, certified to be NIST traceable.

Do not use this cylinder below 150 psig.

Authorizing Signature: \_\_\_\_\_

IWS Specialty Gases  
111 Buras Drive  
Belle Chasse, LA 70037  
504-392-2400

### Certificate of Analysis EPA Protocol Gas Mixture

Cylinder Number	CC249422	Customer	Southern Gas & Supply	Certification Date	14 Jul 2009
Cylinder Size	150AL			Expiration Date	14 Jul 2011
Cylinder Pressure	2000 psig			Lot Number	0907011033
Cylinder Contents	145 ft3	PO Number	331500-1	Part Number	GSPE5NB150AG01C
Cylinder CGA	660				

Component	Requested Concentration	Certified Concentration	Accuracy	Procedure
Carbon Monoxide	125 PPM	122.9 PPM	+/- 1 %	G1
Nitric Oxide	125 PPM	122.0 PPM	+/- 1 %	G1
Sulfur Dioxide	125 PPM	125.0 PPM	+/- 1 %	G1
Carbon Dioxide	5 %	4.883 %	+/- 1 %	G1
Nitrogen	Balance	Balance	NOX conc. = 122 PPM	

Component	Standard Cylinder	Reference Number	Reference Concentration
Carbon Monoxide	CC250365	GMIS	247.8 PPM
Instrument Make-Model	Serial Number	Analytical Principle	Calibration date
Siemens - Ultramat 6	N1-U5-0234	NDIR	16 Jun 2009
1st Analysis	Date: 07/07/09	2nd Analysis	Date: 07/14/09
R 247.8 S 122.8 Z 0.00		R 247.8 S 122.9 Z 0.00	
S 122.8 Z 0.00 R 247.8		S 122.9 Z 0.00 R 247.8	
Z 0.00 R 247.8 S 122.8		Z 0.00 R 247.8 S 122.9	
1st Analysis		122.8	
2nd Analysis		122.9	
Relative Difference		0.08%	


Component	Standard Cylinder	Reference Number	Reference Concentration
Nitric Oxide	CC250469	GMIS	978.3 PPM
Instrument Make-Model	Serial Number	Analytical Principle	Calibration date
Eco Physics - CLD 700 EL	73236	Chemiluminescence	16 Jun 2009
1st Analysis	Date: 07/07/09	2nd Analysis	Date: 07/14/09
R 978.0 S 122.0 Z 0.00		R 978.0 S 122.0 Z 0.00	
S 122.0 Z 0.00 R 978.0		S 122.0 Z 0.00 R 978.0	
Z 0.00 R 978.0 S 122.0		Z 0.00 R 978.0 S 122.0	
1st Analysis		122.0	
2nd Analysis		122.0	
Relative Difference		0.00%	

Component	Standard Cylinder	Reference Number	Reference Concentration
Sulfur Dioxide	CC250501	GMIS	493.6 PPM
Instrument Make-Model	Serial Number	Analytical Principle	Calibration date
Siemens - Ultramat 6	N1-U5-0236	NDIR	16 Jun 2009
1st Analysis	Date: 07/07/09	2nd Analysis	Date: 07/14/09
R 493.6 S 125.0 Z 0.00		R 493.6 S 125.0 Z 0.00	
S 125.0 Z 0.00 R 493.6		S 125.0 Z 0.00 R 493.6	
Z 0.00 R 493.6 S 125.0		Z 0.00 R 493.6 S 125.0	
1st Analysis		125.0	
2nd Analysis		125.0	
Relative Difference		0.00%	

Component	Standard Cylinder	Reference Number	Reference Concentration
Carbon Dioxide	CAL016183	SRM2745	15.633 %
Instrument Make-Model	Serial Number	Analytical Principle	Calibration date
Siemens - Ultramat/Oxymat 6	N1-U5-0235	NDIR/Paramagnetic	16 Jun 2009
1st Analysis	Date: 07/14/09		
R 15.630 S 4.882 Z 0.000			
S 4.882 Z 0.000 R 15.630			
Z 0.000 R 15.630 S 4.882			
1st Analysis		4.883	

This calibration standard certified per the 1997 EPA Traceability Protocol (EPA-600/97/121), using procedure listed.  
All values, excluding NOX concentration, certified to be NIST traceable.

Do not use this cylinder below 150 psig.

Authorizing Signature: 

**AIR LIQUIDE**  
 11428 Fairmont Pkwy, LaPorte, TX 77571 (281)474-4400

**EPA Protocol**  
 EPA-600/R-97/121  
 Section 2.2 Procedure G-1

**Customer:** Sanders Engineering

**S.O. #:** 33140356  
**Trnsf. #:** 33140356  
**P.O. #:** 09-0407-JCS  
**Item#:**

**Cylinder #:** CC90535      **Lot #:** LPX251109      **Valve:** CGA590

Component	Concentration (Mole)
Nitrogen	Balance
Oxygen	10.6 ±0.1 %

**Assay Date:** 28-Apr-09      **Expiration Date:** 27-Apr-12      **\*Cyl. Press:** 1800psig

\*Cylinder should not be used when gas pressure is below 150 psig

Mid-Range Stack Testing  
 AIF 88080

**APPENDIX D POLLUTANT MONITOR CONCENTRATIONS**

SO2 (Compensated)						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_C.1	4/27/10 7:14	41.7	4/27/10 8:30	42.1	4/27/10 9:45	42
S201877-AT_C.1	4/27/10 7:15	41.6	4/27/10 8:31	42.1	4/27/10 9:46	42
S201877-AT_C.1	4/27/10 7:16	41.4	4/27/10 8:32	42.1	4/27/10 9:47	42
S201877-AT_C.1	4/27/10 7:17	41.3	4/27/10 8:33	42	4/27/10 9:48	42
S201877-AT_C.1	4/27/10 7:18	41.2	4/27/10 8:34	42	4/27/10 9:49	42
S201877-AT_C.1	4/27/10 7:19	41.1	4/27/10 8:35	42	4/27/10 9:50	42
S201877-AT_C.1	4/27/10 7:20	41	4/27/10 8:36	42	4/27/10 9:51	42
S201877-AT_C.1	4/27/10 7:21	41	4/27/10 8:37	42	4/27/10 9:52	42
S201877-AT_C.1	4/27/10 7:22	40.9	4/27/10 8:38	42	4/27/10 9:53	42
S201877-AT_C.1	4/27/10 7:23	40.9	4/27/10 8:39	42.2	4/27/10 9:54	42.1
S201877-AT_C.1	4/27/10 7:24	40.8	4/27/10 8:40	42.4	4/27/10 9:55	42.4
S201877-AT_C.1	4/27/10 7:25	40.7	4/27/10 8:41	42.6	4/27/10 9:56	42.7
S201877-AT_C.1	4/27/10 7:26	40.7	4/27/10 8:42	42.7	4/27/10 9:57	43
S201877-AT_C.1	4/27/10 7:27	40.6	4/27/10 8:43	42.7	4/27/10 9:58	43.4
S201877-AT_C.1	4/27/10 7:28	40.6	4/27/10 8:44	42.7	4/27/10 9:59	43.7
S201877-AT_C.1	4/27/10 7:29	40.5	4/27/10 8:45	42.6	4/27/10 10:00	44
S201877-AT_C.1	4/27/10 7:30	40.5	4/27/10 8:46	42.6	4/27/10 10:01	50.4
S201877-AT_C.1	4/27/10 7:31	40.5	4/27/10 8:47	42.5	4/27/10 10:02	59.7
S201877-AT_C.1	4/27/10 7:32	40.6	4/27/10 8:48	42.5	4/27/10 10:03	53.6
S201877-AT_C.1	4/27/10 7:33	40.7	4/27/10 8:49	42.5	4/27/10 10:04	47.7
S201877-AT_C.1	4/27/10 7:34	40.7	4/27/10 8:50	42.4	4/27/10 10:05	44.5
S201877-AT_C.1	4/27/10 7:35	40.8	4/27/10 8:51	42.3	4/27/10 10:06	44.4
S201877-AT_C.1	4/27/10 7:36	40.9	4/27/10 8:52	42.2	4/27/10 10:07	44.4
S201877-AT_C.1	4/27/10 7:37	40.9	4/27/10 8:53	42	4/27/10 10:08	44.3
S201877-AT_C.1	4/27/10 7:38	41	4/27/10 8:54	41.8	4/27/10 10:09	44.3
S201877-AT_C.1	4/27/10 7:39	41	4/27/10 8:55	41.6	4/27/10 10:10	44.3
S201877-AT_C.1	4/27/10 7:40	40.8	4/27/10 8:56	41.4	4/27/10 10:11	44.3
S201877-AT_C.1	4/27/10 7:41	40.6	4/27/10 8:57	41.2	4/27/10 10:12	44.3
S201877-AT_C.1	4/27/10 7:42	40.4	4/27/10 8:58	41.1	4/27/10 10:13	44.3
S201877-AT_C.1	4/27/10 7:43	40.3	4/27/10 8:59	40.9	4/27/10 10:14	44.2
S201877-AT_C.1	4/27/10 7:44	40.1	4/27/10 9:00	40.8	4/27/10 10:15	44.2
S201877-AT_C.1	4/27/10 7:45	39.9	4/27/10 9:01	40.9	4/27/10 10:16	44
S201877-AT_C.1	4/27/10 7:46	39.7	4/27/10 9:02	41	4/27/10 10:17	43.9
S201877-AT_C.1	4/27/10 7:47	39.5	4/27/10 9:03	41.1	4/27/10 10:18	43.7
S201877-AT_C.1	4/27/10 7:48	39.5	4/27/10 9:04	41.2	4/27/10 10:19	43.6
S201877-AT_C.1	4/27/10 7:49	39.7	4/27/10 9:05	41.3	4/27/10 10:20	43.4
S201877-AT_C.1	4/27/10 7:50	39.9	4/27/10 9:06	41.4	4/27/10 10:21	43.3
S201877-AT_C.1	4/27/10 7:51	40.1	4/27/10 9:07	41.5	4/27/10 10:22	43.1
S201877-AT_C.1	4/27/10 7:52	40.3	4/27/10 9:08	41.6	4/27/10 10:23	43
S201877-AT_C.1	4/27/10 7:53	40.5	4/27/10 9:09	41.7	4/27/10 10:24	43
S201877-AT_C.1	4/27/10 7:54	40.7	4/27/10 9:10	41.8	4/27/10 10:25	43.3
S201877-AT_C.1	4/27/10 7:55	40.9	4/27/10 9:11	41.8	4/27/10 10:26	43.6
S201877-AT_C.1	4/27/10 7:56	41.1	4/27/10 9:12	41.9	4/27/10 10:27	43.9
S201877-AT_C.1	4/27/10 7:57	42.4	4/27/10 9:13	42	4/27/10 10:28	44.2
S201877-AT_C.1	4/27/10 7:58	44.5	4/27/10 9:14	42	4/27/10 10:29	44.5
S201877-AT_C.1	4/27/10 7:59	44.3	4/27/10 9:15	42.1	4/27/10 10:30	44.8
S201877-AT_C.1	4/27/10 8:00	43.5	4/27/10 9:16	42.2	4/27/10 10:31	45.1
S201877-AT_C.1	4/27/10 8:01	41.7	4/27/10 9:17	42.2	4/27/10 10:32	45.4
S201877-AT_C.1	4/27/10 8:02	40.5	4/27/10 9:18	42.2	4/27/10 10:33	45.5
S201877-AT_C.1	4/27/10 8:03	40.5	4/27/10 9:19	41.9	4/27/10 10:34	45.2
S201877-AT_C.1	4/27/10 8:04	40.6	4/27/10 9:20	41.7	4/27/10 10:35	44.8
S201877-AT_C.1	4/27/10 8:05	40.6	4/27/10 9:21	41.5	4/27/10 10:36	44.5
S201877-AT_C.1	4/27/10 8:06	40.7	4/27/10 9:22	41.2	4/27/10 10:37	44.1
S201877-AT_C.1	4/27/10 8:07	40.7	4/27/10 9:23	41	4/27/10 10:38	43.8
S201877-AT_C.1	4/27/10 8:08	40.8	4/27/10 9:24	40.8	4/27/10 10:39	43.5
S201877-AT_C.1	4/27/10 8:09	40.8	4/27/10 9:25	40.5	4/27/10 10:40	43.1
S201877-AT_C.1	4/27/10 8:10	40.9	4/27/10 9:26	40.3	4/27/10 10:41	42.8
S201877-AT_C.1	4/27/10 8:11	40.9	4/27/10 9:27	40.2	4/27/10 10:42	42.8
S201877-AT_C.1	4/27/10 8:12	40.8	4/27/10 9:28	40.3	4/27/10 10:43	43.5
S201877-AT_C.1	4/27/10 8:13	40.7	4/27/10 9:29	40.4	4/27/10 10:44	44.2
S201877-AT_C.1	4/27/10 8:14	40.7	4/27/10 9:30	40.5	4/27/10 10:45	44.9
S201877-AT_C.1	4/27/10 8:15	40.6	4/27/10 9:31	40.6	4/27/10 10:46	45.6
S201877-AT_C.1	4/27/10 8:16	40.5	4/27/10 9:32	40.7	4/27/10 10:47	45.9
S201877-AT_C.1	4/27/10 8:17	40.4	4/27/10 9:33	40.8	4/27/10 10:48	45.5

O2						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_D.1	4/27/10 7:14	3.8	4/27/10 8:30	3.8	4/27/10 9:45	3.9
S201877-AT_D.1	4/27/10 7:15	3.8	4/27/10 8:31	3.8	4/27/10 9:46	3.9
S201877-AT_D.1	4/27/10 7:16	3.8	4/27/10 8:32	3.8	4/27/10 9:47	3.9
S201877-AT_D.1	4/27/10 7:17	3.8	4/27/10 8:33	3.8	4/27/10 9:48	3.9
S201877-AT_D.1	4/27/10 7:18	3.8	4/27/10 8:34	3.8	4/27/10 9:49	3.9
S201877-AT_D.1	4/27/10 7:19	3.8	4/27/10 8:35	3.8	4/27/10 9:50	3.9
S201877-AT_D.1	4/27/10 7:20	3.8	4/27/10 8:36	3.8	4/27/10 9:51	3.9
S201877-AT_D.1	4/27/10 7:21	3.8	4/27/10 8:37	3.8	4/27/10 9:52	3.9
S201877-AT_D.1	4/27/10 7:22	3.8	4/27/10 8:38	3.8	4/27/10 9:53	3.9
S201877-AT_D.1	4/27/10 7:23	3.8	4/27/10 8:39	3.8	4/27/10 9:54	3.9
S201877-AT_D.1	4/27/10 7:24	3.8	4/27/10 8:40	3.8	4/27/10 9:55	3.9
S201877-AT_D.1	4/27/10 7:25	3.8	4/27/10 8:41	3.8	4/27/10 9:56	3.9
S201877-AT_D.1	4/27/10 7:26	3.8	4/27/10 8:42	3.8	4/27/10 9:57	3.9
S201877-AT_D.1	4/27/10 7:27	3.8	4/27/10 8:43	3.8	4/27/10 9:58	3.9
S201877-AT_D.1	4/27/10 7:28	3.8	4/27/10 8:44	3.8	4/27/10 9:59	3.9
S201877-AT_D.1	4/27/10 7:29	3.8	4/27/10 8:45	3.8	4/27/10 10:00	3.9
S201877-AT_D.1	4/27/10 7:30	3.8	4/27/10 8:46	3.8	4/27/10 10:01	3.9
S201877-AT_D.1	4/27/10 7:31	3.8	4/27/10 8:47	3.8	4/27/10 10:02	3.9
S201877-AT_D.1	4/27/10 7:32	3.8	4/27/10 8:48	3.8	4/27/10 10:03	3.9
S201877-AT_D.1	4/27/10 7:33	3.8	4/27/10 8:49	3.8	4/27/10 10:04	3.9
S201877-AT_D.1	4/27/10 7:34	3.8	4/27/10 8:50	3.8	4/27/10 10:05	3.9
S201877-AT_D.1	4/27/10 7:35	3.8	4/27/10 8:51	3.8	4/27/10 10:06	3.9
S201877-AT_D.1	4/27/10 7:36	3.8	4/27/10 8:52	3.8	4/27/10 10:07	3.9
S201877-AT_D.1	4/27/10 7:37	3.8	4/27/10 8:53	3.8	4/27/10 10:08	3.9
S201877-AT_D.1	4/27/10 7:38	3.8	4/27/10 8:54	3.8	4/27/10 10:09	3.9
S201877-AT_D.1	4/27/10 7:39	3.8	4/27/10 8:55	3.8	4/27/10 10:10	3.9
S201877-AT_D.1	4/27/10 7:40	3.8	4/27/10 8:56	3.8	4/27/10 10:11	3.9
S201877-AT_D.1	4/27/10 7:41	3.8	4/27/10 8:57	3.8	4/27/10 10:12	3.9
S201877-AT_D.1	4/27/10 7:42	3.8	4/27/10 8:58	3.8	4/27/10 10:13	3.9
S201877-AT_D.1	4/27/10 7:43	3.8	4/27/10 8:59	3.8	4/27/10 10:14	3.9
S201877-AT_D.1	4/27/10 7:44	3.8	4/27/10 9:00	3.8	4/27/10 10:15	3.9
S201877-AT_D.1	4/27/10 7:45	3.8	4/27/10 9:01	3.8	4/27/10 10:16	3.9
S201877-AT_D.1	4/27/10 7:46	3.8	4/27/10 9:02	3.8	4/27/10 10:17	3.9
S201877-AT_D.1	4/27/10 7:47	3.8	4/27/10 9:03	3.8	4/27/10 10:18	3.9
S201877-AT_D.1	4/27/10 7:48	3.8	4/27/10 9:04	3.8	4/27/10 10:19	3.9
S201877-AT_D.1	4/27/10 7:49	3.8	4/27/10 9:05	3.8	4/27/10 10:20	3.9
S201877-AT_D.1	4/27/10 7:50	3.8	4/27/10 9:06	3.8	4/27/10 10:21	3.9
S201877-AT_D.1	4/27/10 7:51	3.8	4/27/10 9:07	3.8	4/27/10 10:22	3.9
S201877-AT_D.1	4/27/10 7:52	3.8	4/27/10 9:08	3.8	4/27/10 10:23	3.9
S201877-AT_D.1	4/27/10 7:53	3.8	4/27/10 9:09	3.8	4/27/10 10:24	3.9
S201877-AT_D.1	4/27/10 7:54	3.8	4/27/10 9:10	3.8	4/27/10 10:25	3.9
S201877-AT_D.1	4/27/10 7:55	3.8	4/27/10 9:11	3.8	4/27/10 10:26	3.9
S201877-AT_D.1	4/27/10 7:56	3.8	4/27/10 9:12	3.8	4/27/10 10:27	3.9
S201877-AT_D.1	4/27/10 7:57	3.8	4/27/10 9:13	3.8	4/27/10 10:28	3.9
S201877-AT_D.1	4/27/10 7:58	3.8	4/27/10 9:14	3.8	4/27/10 10:29	3.9
S201877-AT_D.1	4/27/10 7:59	3.8	4/27/10 9:15	3.8	4/27/10 10:30	3.9
S201877-AT_D.1	4/27/10 8:00	3.8	4/27/10 9:16	3.8	4/27/10 10:31	3.9
S201877-AT_D.1	4/27/10 8:01	3.8	4/27/10 9:17	3.8	4/27/10 10:32	3.9
S201877-AT_D.1	4/27/10 8:02	3.8	4/27/10 9:18	3.8	4/27/10 10:33	3.9
S201877-AT_D.1	4/27/10 8:03	3.8	4/27/10 9:19	3.8	4/27/10 10:34	3.9
S201877-AT_D.1	4/27/10 8:04	3.8	4/27/10 9:20	3.8	4/27/10 10:35	3.9
S201877-AT_D.1	4/27/10 8:05	3.8	4/27/10 9:21	3.8	4/27/10 10:36	3.9
S201877-AT_D.1	4/27/10 8:06	3.8	4/27/10 9:22	3.8	4/27/10 10:37	3.9
S201877-AT_D.1	4/27/10 8:07	3.8	4/27/10 9:23	3.8	4/27/10 10:38	3.9
S201877-AT_D.1	4/27/10 8:08	3.8	4/27/10 9:24	3.8	4/27/10 10:39	3.9
S201877-AT_D.1	4/27/10 8:09	3.8	4/27/10 9:25	3.8	4/27/10 10:40	3.9
S201877-AT_D.1	4/27/10 8:10	3.8	4/27/10 9:26	3.8	4/27/10 10:41	3.9
S201877-AT_D.1	4/27/10 8:11	3.8	4/27/10 9:27	3.8	4/27/10 10:42	3.9
S201877-AT_D.1	4/27/10 8:12	3.8	4/27/10 9:28	3.8	4/27/10 10:43	3.9
S201877-AT_D.1	4/27/10 8:13	3.8	4/27/10 9:29	3.8	4/27/10 10:44	3.9
S201877-AT_D.1	4/27/10 8:14	3.8	4/27/10 9:30	3.8	4/27/10 10:45	3.9
S201877-AT_D.1	4/27/10 8:15	3.8	4/27/10 9:31	3.8	4/27/10 10:46	3.9
S201877-AT_D.1	4/27/10 8:16	3.8	4/27/10 9:32	3.8	4/27/10 10:47	3.9
S201877-AT_D.1	4/27/10 8:17	3.8	4/27/10 9:33	3.8	4/27/10 10:48	3.9

SO2 (Uncompensated)						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_A.1	4/27/10 7:14	33.5	4/27/10 8:30	33.2	4/27/10 9:45	33.9
S201877-AT_A.1	4/27/10 7:15	33.1	4/27/10 8:31	33.2	4/27/10 9:46	34
S201877-AT_A.1	4/27/10 7:16	32.8	4/27/10 8:32	33.3	4/27/10 9:47	34
S201877-AT_A.1	4/27/10 7:17	32.5	4/27/10 8:33	33.3	4/27/10 9:48	34.1
S201877-AT_A.1	4/27/10 7:18	32.3	4/27/10 8:34	33.4	4/27/10 9:49	34.1
S201877-AT_A.1	4/27/10 7:19	32.2	4/27/10 8:35	33.4	4/27/10 9:50	34.2
S201877-AT_A.1	4/27/10 7:20	32	4/27/10 8:36	33.5	4/27/10 9:51	34.2
S201877-AT_A.1	4/27/10 7:21	31.9	4/27/10 8:37	33.5	4/27/10 9:52	34.1
S201877-AT_A.1	4/27/10 7:22	31.7	4/27/10 8:38	33.6	4/27/10 9:53	34
S201877-AT_A.1	4/27/10 7:23	31.6	4/27/10 8:39	33.6	4/27/10 9:54	33.9
S201877-AT_A.1	4/27/10 7:24	31.4	4/27/10 8:40	33.6	4/27/10 9:55	33.9
S201877-AT_A.1	4/27/10 7:25	31.3	4/27/10 8:41	33.5	4/27/10 9:56	33.8
S201877-AT_A.1	4/27/10 7:26	31.2	4/27/10 8:42	33.5	4/27/10 9:57	33.7
S201877-AT_A.1	4/27/10 7:27	31.2	4/27/10 8:43	33.5	4/27/10 9:58	33.6
S201877-AT_A.1	4/27/10 7:28	31.2	4/27/10 8:44	33.4	4/27/10 9:59	33.5
S201877-AT_A.1	4/27/10 7:29	31.2	4/27/10 8:45	33.4	4/27/10 10:00	34
S201877-AT_A.1	4/27/10 7:30	31.2	4/27/10 8:46	33.4	4/27/10 10:01	39.9
S201877-AT_A.1	4/27/10 7:31	31.2	4/27/10 8:47	33.3	4/27/10 10:02	47.5
S201877-AT_A.1	4/27/10 7:32	31.2	4/27/10 8:48	33.3	4/27/10 10:03	43
S201877-AT_A.1	4/27/10 7:33	31.2	4/27/10 8:49	33.3	4/27/10 10:04	38.2
S201877-AT_A.1	4/27/10 7:34	31.2	4/27/10 8:50	33.3	4/27/10 10:05	35
S201877-AT_A.1	4/27/10 7:35	31.2	4/27/10 8:51	33.3	4/27/10 10:06	34.9
S201877-AT_A.1	4/27/10 7:36	31.2	4/27/10 8:52	33.3	4/27/10 10:07	34.9
S201877-AT_A.1	4/27/10 7:37	31.2	4/27/10 8:53	33.3	4/27/10 10:08	34.8
S201877-AT_A.1	4/27/10 7:38	31.2	4/27/10 8:54	33.3	4/27/10 10:09	34.8
S201877-AT_A.1	4/27/10 7:39	31.2	4/27/10 8:55	33.3	4/27/10 10:10	34.7
S201877-AT_A.1	4/27/10 7:40	31.2	4/27/10 8:56	33.3	4/27/10 10:11	34.7
S201877-AT_A.1	4/27/10 7:41	31.2	4/27/10 8:57	33.3	4/27/10 10:12	34.6
S201877-AT_A.1	4/27/10 7:42	31.2	4/27/10 8:58	33.4	4/27/10 10:13	34.6
S201877-AT_A.1	4/27/10 7:43	31.2	4/27/10 8:59	33.5	4/27/10 10:14	34.5
S201877-AT_A.1	4/27/10 7:44	31.2	4/27/10 9:00	33.6	4/27/10 10:15	34.5
S201877-AT_A.1	4/27/10 7:45	31.3	4/27/10 9:01	33.7	4/27/10 10:16	34.4
S201877-AT_A.1	4/27/10 7:46	31.3	4/27/10 9:02	33.8	4/27/10 10:17	34.3
S201877-AT_A.1	4/27/10 7:47	31.4	4/27/10 9:03	33.9	4/27/10 10:18	34.2
S201877-AT_A.1	4/27/10 7:48	31.4	4/27/10 9:04	34.1	4/27/10 10:19	34.1
S201877-AT_A.1	4/27/10 7:49	31.5	4/27/10 9:05	34.2	4/27/10 10:20	34.1
S201877-AT_A.1	4/27/10 7:50	31.5	4/27/10 9:06	34.2	4/27/10 10:21	34
S201877-AT_A.1	4/27/10 7:51	31.6	4/27/10 9:07	34.1	4/27/10 10:22	33.9
S201877-AT_A.1	4/27/10 7:52	31.6	4/27/10 9:08	34	4/27/10 10:23	33.8
S201877-AT_A.1	4/27/10 7:53	31.6	4/27/10 9:09	33.9	4/27/10 10:24	33.8
S201877-AT_A.1	4/27/10 7:54	31.6	4/27/10 9:10	33.9	4/27/10 10:25	34.1
S201877-AT_A.1	4/27/10 7:55	31.5	4/27/10 9:11	33.8	4/27/10 10:26	34.3
S201877-AT_A.1	4/27/10 7:56	31.4	4/27/10 9:12	33.7	4/27/10 10:27	34.5
S201877-AT_A.1	4/27/10 7:57	31.4	4/27/10 9:13	33.6	4/27/10 10:28	34.7
S201877-AT_A.1	4/27/10 7:58	31.3	4/27/10 9:14	33.5	4/27/10 10:29	34.9
S201877-AT_A.1	4/27/10 7:59	31.3	4/27/10 9:15	33.4	4/27/10 10:30	35.1
S201877-AT_A.1	4/27/10 8:00	31.2	4/27/10 9:16	33.2	4/27/10 10:31	35.4
S201877-AT_A.1	4/27/10 8:01	31.1	4/27/10 9:17	33	4/27/10 10:32	35.6
S201877-AT_A.1	4/27/10 8:02	31.1	4/27/10 9:18	32.8	4/27/10 10:33	35.6
S201877-AT_A.1	4/27/10 8:03	31.1	4/27/10 9:19	32.7	4/27/10 10:34	35.4
S201877-AT_A.1	4/27/10 8:04	31.3	4/27/10 9:20	32.5	4/27/10 10:35	35.1
S201877-AT_A.1	4/27/10 8:05	31.5	4/27/10 9:21	32.3	4/27/10 10:36	34.9
S201877-AT_A.1	4/27/10 8:06	31.8	4/27/10 9:22	32.1	4/27/10 10:37	34.6
S201877-AT_A.1	4/27/10 8:07	32	4/27/10 9:23	31.9	4/27/10 10:38	34.4
S201877-AT_A.1	4/27/10 8:08	32.2	4/27/10 9:24	31.8	4/27/10 10:39	34.1
S201877-AT_A.1	4/27/10 8:09	32.4	4/27/10 9:25	31.9	4/27/10 10:40	33.9
S201877-AT_A.1	4/27/10 8:10	32.6	4/27/10 9:26	32	4/27/10 10:41	33.6
S201877-AT_A.1	4/27/10 8:11	32.9	4/27/10 9:27	32	4/27/10 10:42	33.5
S201877-AT_A.1	4/27/10 8:12	33	4/27/10 9:28	32.1	4/27/10 10:43	33.6
S201877-AT_A.1	4/27/10 8:13	33	4/27/10 9:29	32.2	4/27/10 10:44	33.8
S201877-AT_A.1	4/27/10 8:14	33	4/27/10 9:30	32.2	4/27/10 10:45	33.9
S201877-AT_A.1	4/27/10 8:15	33	4/27/10 9:31	32.3	4/27/10 10:46	34
S201877-AT_A.1	4/27/10 8:16	33	4/27/10 9:32	32.4	4/27/10 10:47	34.2
S201877-AT_A.1	4/27/10 8:17	33	4/27/10 9:33	32.5	4/27/10 10:48	34.3

SO2 (Compensated)						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_C.1	4/28/10 9:58	64.6	4/28/10 11:13	65.2	4/28/10 12:26	56.2
S201877-AT_C.1	4/28/10 9:59	64.8	4/28/10 11:14	62.2	4/28/10 12:27	56.6
S201877-AT_C.1	4/28/10 10:00	65	4/28/10 11:15	60.6	4/28/10 12:28	57
S201877-AT_C.1	4/28/10 10:01	65.2	4/28/10 11:16	61.6	4/28/10 12:29	57.9
S201877-AT_C.1	4/28/10 10:02	65.4	4/28/10 11:17	62.5	4/28/10 12:30	59.5
S201877-AT_C.1	4/28/10 10:03	65.4	4/28/10 11:18	63.1	4/28/10 12:31	60.5
S201877-AT_C.1	4/28/10 10:04	65.2	4/28/10 11:19	63.7	4/28/10 12:32	60.1
S201877-AT_C.1	4/28/10 10:05	64.9	4/28/10 11:20	64.3	4/28/10 12:33	59.7
S201877-AT_C.1	4/28/10 10:06	64.7	4/28/10 11:21	65	4/28/10 12:34	59.3
S201877-AT_C.1	4/28/10 10:07	64.4	4/28/10 11:22	65.9	4/28/10 12:35	58.9
S201877-AT_C.1	4/28/10 10:08	64.2	4/28/10 11:23	66.8	4/28/10 12:36	58.5
S201877-AT_C.1	4/28/10 10:09	63.9	4/28/10 11:24	67.3	4/28/10 12:37	58.1
S201877-AT_C.1	4/28/10 10:10	63.7	4/28/10 11:25	67.4	4/28/10 12:38	57.7
S201877-AT_C.1	4/28/10 10:11	63.4	4/28/10 11:26	67.4	4/28/10 12:39	57.2
S201877-AT_C.1	4/28/10 10:12	63.2	4/28/10 11:27	67.5	4/28/10 12:40	56.8
S201877-AT_C.1	4/28/10 10:13	63.3	4/28/10 11:28	67.5	4/28/10 12:41	56.4
S201877-AT_C.1	4/28/10 10:14	63.3	4/28/10 11:29	67.5	4/28/10 12:42	55.9
S201877-AT_C.1	4/28/10 10:15	63.3	4/28/10 11:30	67.6	4/28/10 12:43	55.8
S201877-AT_C.1	4/28/10 10:16	63.3	4/28/10 11:31	67.6	4/28/10 12:44	56.1
S201877-AT_C.1	4/28/10 10:17	63.3	4/28/10 11:32	68.3	4/28/10 12:45	56.5
S201877-AT_C.1	4/28/10 10:18	63.3	4/28/10 11:33	70.4	4/28/10 12:46	60.2
S201877-AT_C.1	4/28/10 10:19	63.4	4/28/10 11:34	72.4	4/28/10 12:47	80.4
S201877-AT_C.1	4/28/10 10:20	62.7	4/28/10 11:35	74.5	4/28/10 13:09	70.7
S201877-AT_C.1	4/28/10 10:21	60.8	4/28/10 11:36	76.6	4/28/10 13:10	67.1
S201877-AT_C.1	4/28/10 10:22	60.4	4/28/10 11:37	78.4	4/28/10 13:11	63.5
S201877-AT_C.1	4/28/10 10:23	63.2	4/28/10 11:38	80	4/28/10 13:12	59.9
S201877-AT_C.1	4/28/10 10:24	65.2	4/28/10 11:39	80.6	4/28/10 13:13	57.1
S201877-AT_C.1	4/28/10 10:25	65.6	4/28/10 11:40	79.7	4/28/10 13:14	56
S201877-AT_C.1	4/28/10 10:26	66	4/28/10 11:41	78.8	4/28/10 13:15	54.9
S201877-AT_C.1	4/28/10 10:27	68.4	4/28/10 11:42	77.9	4/28/10 13:16	53.7
S201877-AT_C.1	4/28/10 10:28	72.2	4/28/10 11:43	76.9	4/28/10 13:17	52.6
S201877-AT_C.1	4/28/10 10:29	71.2	4/28/10 11:44	75.5	4/28/10 13:18	51.8
S201877-AT_C.1	4/28/10 10:30	70.1	4/28/10 11:45	73.3	4/28/10 13:19	51.5
S201877-AT_C.1	4/28/10 10:31	69.4	4/28/10 11:46	71	4/28/10 13:20	51.3
S201877-AT_C.1	4/28/10 10:32	69.4	4/28/10 11:47	69.2	4/28/10 13:21	51.1
S201877-AT_C.1	4/28/10 10:33	69.4	4/28/10 11:48	68.3	4/28/10 13:22	50.8
S201877-AT_C.1	4/28/10 10:34	69.5	4/28/10 11:49	67.5	4/28/10 13:23	50.6
S201877-AT_C.1	4/28/10 10:35	69.5	4/28/10 11:50	66.9	4/28/10 13:24	50.3
S201877-AT_C.1	4/28/10 10:36	69.5	4/28/10 11:51	66.8	4/28/10 13:25	49.7
S201877-AT_C.1	4/28/10 10:37	69.6	4/28/10 11:52	66.7	4/28/10 13:26	48.5
S201877-AT_C.1	4/28/10 10:38	69.6	4/28/10 11:53	66.6	4/28/10 13:27	47.7
S201877-AT_C.1	4/28/10 10:39	69.7	4/28/10 11:54	67.2	4/28/10 13:28	48.1
S201877-AT_C.1	4/28/10 10:40	69.7	4/28/10 11:55	69.2	4/28/10 13:29	48.4
S201877-AT_C.1	4/28/10 10:41	70	4/28/10 11:56	70.8	4/28/10 13:30	48.8
S201877-AT_C.1	4/28/10 10:42	70.8	4/28/10 11:57	71.9	4/28/10 13:31	49.1
S201877-AT_C.1	4/28/10 10:43	71.6	4/28/10 11:58	73	4/28/10 13:32	49.5
S201877-AT_C.1	4/28/10 10:44	72.4	4/28/10 11:59	74.2	4/28/10 13:33	49.7
S201877-AT_C.1	4/28/10 10:45	73.2	4/28/10 12:00	74.9	4/28/10 13:34	49.7
S201877-AT_C.1	4/28/10 10:46	74	4/28/10 12:01	74.4	4/28/10 13:35	49.7
S201877-AT_C.1	4/28/10 10:47	74.8	4/28/10 12:02	73.9	4/28/10 13:36	49.6
S201877-AT_C.1	4/28/10 10:48	75.6	4/28/10 12:03	73	4/28/10 13:37	49.6
S201877-AT_C.1	4/28/10 10:49	76.4	4/28/10 12:04	71.5	4/28/10 13:38	49.6
S201877-AT_C.1	4/28/10 10:50	76.4	4/28/10 12:05	70.1	4/28/10 13:39	50
S201877-AT_C.1	4/28/10 10:51	75.2	4/28/10 12:06	68.7	4/28/10 13:40	50.1
S201877-AT_C.1	4/28/10 10:52	74.3	4/28/10 12:07	67.4	4/28/10 13:41	50.1
S201877-AT_C.1	4/28/10 10:53	73.8	4/28/10 12:08	66.1	4/28/10 13:42	50.2
S201877-AT_C.1	4/28/10 10:54	73.3	4/28/10 12:09	64	4/28/10 13:43	50.2
S201877-AT_C.1	4/28/10 10:55	72.8	4/28/10 12:10	62.3	4/28/10 13:44	50.2
S201877-AT_C.1	4/28/10 10:56	72.4	4/28/10 12:11	63.6	4/28/10 13:45	50.2
S201877-AT_C.1	4/28/10 10:57	71.9	4/28/10 12:12	65.1	4/28/10 13:46	50.2
S201877-AT_C.1	4/28/10 10:58	71.4	4/28/10 12:13	66.5	4/28/10 13:47	50.2
S201877-AT_C.1	4/28/10 10:59	69.4	4/28/10 12:14	67.9	4/28/10 13:48	50.2
S201877-AT_C.1	4/28/10 11:00	66.7	4/28/10 12:15	69.4	4/28/10 13:49	50.2
S201877-AT_C.1	4/28/10 11:01	68.6	4/28/10 12:16	70.2	4/28/10 13:50	50.2
S201877-AT_C.1	4/28/10 11:02	72.4			4/28/10 13:51	50.2



O2						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_D.1	4/28/10 9:58	5.5	4/28/10 11:13	5.3	4/28/10 12:26	5.2
S201877-AT_D.1	4/28/10 9:59	5.5	4/28/10 11:14	5.3	4/28/10 12:27	5.2
S201877-AT_D.1	4/28/10 10:00	5.5	4/28/10 11:15	5.3	4/28/10 12:28	5.2
S201877-AT_D.1	4/28/10 10:01	5.5	4/28/10 11:16	5.3	4/28/10 12:29	5.2
S201877-AT_D.1	4/28/10 10:02	5.5	4/28/10 11:17	5.3	4/28/10 12:30	5.2
S201877-AT_D.1	4/28/10 10:03	5.5	4/28/10 11:18	5.3	4/28/10 12:31	5.2
S201877-AT_D.1	4/28/10 10:04	5.5	4/28/10 11:19	5.3	4/28/10 12:32	5.2
S201877-AT_D.1	4/28/10 10:05	5.4	4/28/10 11:20	5.3	4/28/10 12:33	5.1
S201877-AT_D.1	4/28/10 10:06	5.4	4/28/10 11:21	5.3	4/28/10 12:34	5.1
S201877-AT_D.1	4/28/10 10:07	5.4	4/28/10 11:22	5.3	4/28/10 12:35	5.1
S201877-AT_D.1	4/28/10 10:08	5.4	4/28/10 11:23	5.3	4/28/10 12:36	5.1
S201877-AT_D.1	4/28/10 10:09	5.4	4/28/10 11:24	5.3	4/28/10 12:37	5.1
S201877-AT_D.1	4/28/10 10:10	5.4	4/28/10 11:25	5.3	4/28/10 12:38	5.1
S201877-AT_D.1	4/28/10 10:11	5.4	4/28/10 11:26	5.3	4/28/10 12:39	5.1
S201877-AT_D.1	4/28/10 10:12	5.4	4/28/10 11:27	5.3	4/28/10 12:40	5.1
S201877-AT_D.1	4/28/10 10:13	5.4	4/28/10 11:28	5.3	4/28/10 12:41	5.1
S201877-AT_D.1	4/28/10 10:14	5.4	4/28/10 11:29	5.3	4/28/10 12:42	5.1
S201877-AT_D.1	4/28/10 10:15	5.4	4/28/10 11:30	5.3	4/28/10 12:43	5.1
S201877-AT_D.1	4/28/10 10:16	5.4	4/28/10 11:31	5.3	4/28/10 12:44	5
S201877-AT_D.1	4/28/10 10:17	5.4	4/28/10 11:32	5.3	4/28/10 12:45	5
S201877-AT_D.1	4/28/10 10:18	5.4	4/28/10 11:33	5.3	4/28/10 12:46	5
S201877-AT_D.1	4/28/10 10:19	5.4	4/28/10 11:34	5.3	4/28/10 12:47	5
S201877-AT_D.1	4/28/10 10:20	5.4	4/28/10 11:35	5.3	4/28/10 13:09	4.8
S201877-AT_D.1	4/28/10 10:21	5.4	4/28/10 11:36	5.3	4/28/10 13:10	4.8
S201877-AT_D.1	4/28/10 10:22	5.4	4/28/10 11:37	5.3	4/28/10 13:11	4.8
S201877-AT_D.1	4/28/10 10:23	5.4	4/28/10 11:38	5.3	4/28/10 13:12	4.8
S201877-AT_D.1	4/28/10 10:24	5.4	4/28/10 11:39	5.3	4/28/10 13:13	4.8
S201877-AT_D.1	4/28/10 10:25	5.4	4/28/10 11:40	5.3	4/28/10 13:14	4.8
S201877-AT_D.1	4/28/10 10:26	5.4	4/28/10 11:41	5.3	4/28/10 13:15	4.8
S201877-AT_D.1	4/28/10 10:27	5.4	4/28/10 11:42	5.3	4/28/10 13:16	4.8
S201877-AT_D.1	4/28/10 10:28	5.4	4/28/10 11:43	5.3	4/28/10 13:17	4.8
S201877-AT_D.1	4/28/10 10:29	5.4	4/28/10 11:44	5.3	4/28/10 13:18	4.8
S201877-AT_D.1	4/28/10 10:30	5.4	4/28/10 11:45	5.3	4/28/10 13:19	4.8
S201877-AT_D.1	4/28/10 10:31	5.4	4/28/10 11:46	5.3	4/28/10 13:20	4.8
S201877-AT_D.1	4/28/10 10:32	5.4	4/28/10 11:47	5.3	4/28/10 13:21	4.8
S201877-AT_D.1	4/28/10 10:33	5.4	4/28/10 11:48	5.3	4/28/10 13:22	4.9
S201877-AT_D.1	4/28/10 10:34	5.4	4/28/10 11:49	5.3	4/28/10 13:23	4.9
S201877-AT_D.1	4/28/10 10:35	5.4	4/28/10 11:50	5.3	4/28/10 13:24	4.9
S201877-AT_D.1	4/28/10 10:36	5.4	4/28/10 11:51	5.3	4/28/10 13:25	4.9
S201877-AT_D.1	4/28/10 10:37	5.4	4/28/10 11:52	5.3	4/28/10 13:26	4.9
S201877-AT_D.1	4/28/10 10:38	5.4	4/28/10 11:53	5.3	4/28/10 13:27	4.9
S201877-AT_D.1	4/28/10 10:39	5.4	4/28/10 11:54	5.3	4/28/10 13:28	4.9
S201877-AT_D.1	4/28/10 10:40	5.4	4/28/10 11:55	5.3	4/28/10 13:29	5
S201877-AT_D.1	4/28/10 10:41	5.4	4/28/10 11:56	5.3	4/28/10 13:30	5
S201877-AT_D.1	4/28/10 10:42	5.4	4/28/10 11:57	5.3	4/28/10 13:31	5
S201877-AT_D.1	4/28/10 10:43	5.4	4/28/10 11:58	5.3	4/28/10 13:32	5
S201877-AT_D.1	4/28/10 10:44	5.4	4/28/10 11:59	5.3	4/28/10 13:33	5
S201877-AT_D.1	4/28/10 10:45	5.4	4/28/10 12:00	5.3	4/28/10 13:34	5
S201877-AT_D.1	4/28/10 10:46	5.4	4/28/10 12:01	5.3	4/28/10 13:35	5
S201877-AT_D.1	4/28/10 10:47	5.4	4/28/10 12:02	5.3	4/28/10 13:36	5
S201877-AT_D.1	4/28/10 10:48	5.4	4/28/10 12:03	5.3	4/28/10 13:37	5.1
S201877-AT_D.1	4/28/10 10:49	5.4	4/28/10 12:04	5.3	4/28/10 13:38	5.1
S201877-AT_D.1	4/28/10 10:50	5.4	4/28/10 12:05	5.3	4/28/10 13:39	5
S201877-AT_D.1	4/28/10 10:51	5.4	4/28/10 12:06	5.3	4/28/10 13:40	5
S201877-AT_D.1	4/28/10 10:52	5.4	4/28/10 12:07	5.3	4/28/10 13:41	5
S201877-AT_D.1	4/28/10 10:53	5.4	4/28/10 12:08	5.3	4/28/10 13:42	5
S201877-AT_D.1	4/28/10 10:54	5.4	4/28/10 12:09	5.3	4/28/10 13:43	5
S201877-AT_D.1	4/28/10 10:55	5.4	4/28/10 12:10	5.3	4/28/10 13:44	5
S201877-AT_D.1	4/28/10 10:56	5.4	4/28/10 12:11	5.3	4/28/10 13:45	5
S201877-AT_D.1	4/28/10 10:57	5.4	4/28/10 12:12	5.3	4/28/10 13:46	5
S201877-AT_D.1	4/28/10 10:58	5.4	4/28/10 12:13	5.3	4/28/10 13:47	5
S201877-AT_D.1	4/28/10 10:59	5.4	4/28/10 12:14	5.3	4/28/10 13:48	5
S201877-AT_D.1	4/28/10 11:00	5.4	4/28/10 12:15	5.3	4/28/10 13:49	5.1
S201877-AT_D.1	4/28/10 11:01	5.4	4/28/10 12:16	5.3	4/28/10 13:50	5.1
S201877-AT_D.1	4/28/10 11:02	5.4			4/28/10 13:51	5.1

SO2 (Uncompensated)						
tag	time	1m avg	time	1m avg	time	1m avg
S201877-AT_A.1	4/28/10 9:58	45.5	4/28/10 11:13	48	4/28/10 12:26	43.9
S201877-AT_A.1	4/28/10 9:59	45.6	4/28/10 11:14	47.5	4/28/10 12:27	43.8
S201877-AT_A.1	4/28/10 10:00	45.7	4/28/10 11:15	47.1	4/28/10 12:28	43.6
S201877-AT_A.1	4/28/10 10:01	45.8	4/28/10 11:16	46.6	4/28/10 12:29	43.5
S201877-AT_A.1	4/28/10 10:02	45.9	4/28/10 11:17	46.2	4/28/10 12:30	43.4
S201877-AT_A.1	4/28/10 10:03	45.9	4/28/10 11:18	46	4/28/10 12:31	43.2
S201877-AT_A.1	4/28/10 10:04	46	4/28/10 11:19	46.4	4/28/10 12:32	43.1
S201877-AT_A.1	4/28/10 10:05	46.1	4/28/10 11:20	46.8	4/28/10 12:33	42.8
S201877-AT_A.1	4/28/10 10:06	46.1	4/28/10 11:21	47.2	4/28/10 12:34	42.6
S201877-AT_A.1	4/28/10 10:07	46.2	4/28/10 11:22	47.6	4/28/10 12:35	42.4
S201877-AT_A.1	4/28/10 10:08	46.3	4/28/10 11:23	48	4/28/10 12:36	42.1
S201877-AT_A.1	4/28/10 10:09	46.3	4/28/10 11:24	48.4	4/28/10 12:37	41.9
S201877-AT_A.1	4/28/10 10:10	46.1	4/28/10 11:25	48.8	4/28/10 12:38	41.7
S201877-AT_A.1	4/28/10 10:11	46	4/28/10 11:26	49.2	4/28/10 12:39	41.5
S201877-AT_A.1	4/28/10 10:12	45.9	4/28/10 11:27	49.7	4/28/10 12:40	41.2
S201877-AT_A.1	4/28/10 10:13	45.7	4/28/10 11:28	50.2	4/28/10 12:41	41
S201877-AT_A.1	4/28/10 10:14	45.6	4/28/10 11:29	50.7	4/28/10 12:42	40.9
S201877-AT_A.1	4/28/10 10:15	45.5	4/28/10 11:30	51.2	4/28/10 12:43	41.1
S201877-AT_A.1	4/28/10 10:16	45.3	4/28/10 11:31	51.7	4/28/10 12:44	41.2
S201877-AT_A.1	4/28/10 10:17	45.2	4/28/10 11:32	52.2	4/28/10 12:45	41.4
S201877-AT_A.1	4/28/10 10:18	45.2	4/28/10 11:33	52.7	4/28/10 12:46	44.1
S201877-AT_A.1	4/28/10 10:19	45.4	4/28/10 11:34	53.2	4/28/10 12:47	58.7
S201877-AT_A.1	4/28/10 10:20	45.7	4/28/10 11:35	53.7	4/28/10 13:09	52.3
S201877-AT_A.1	4/28/10 10:21	45.9	4/28/10 11:36	53.9	4/28/10 13:10	49.3
S201877-AT_A.1	4/28/10 10:22	46.2	4/28/10 11:37	53.7	4/28/10 13:11	47.6
S201877-AT_A.1	4/28/10 10:23	46.4	4/28/10 11:38	53.4	4/28/10 13:12	46
S201877-AT_A.1	4/28/10 10:24	46.7	4/28/10 11:39	53.1	4/28/10 13:13	44.4
S201877-AT_A.1	4/28/10 10:25	47	4/28/10 11:40	52.9	4/28/10 13:14	42.8
S201877-AT_A.1	4/28/10 10:26	47.2	4/28/10 11:41	52.6	4/28/10 13:15	41.2
S201877-AT_A.1	4/28/10 10:27	47.4	4/28/10 11:42	52.3	4/28/10 13:16	39.5
S201877-AT_A.1	4/28/10 10:28	47.7	4/28/10 11:43	52.1	4/28/10 13:17	38.4
S201877-AT_A.1	4/28/10 10:29	47.9	4/28/10 11:44	51.8	4/28/10 13:18	38.1
S201877-AT_A.1	4/28/10 10:30	48.1	4/28/10 11:45	51.4	4/28/10 13:19	37.8
S201877-AT_A.1	4/28/10 10:31	48.3	4/28/10 11:46	50.7	4/28/10 13:20	37.6
S201877-AT_A.1	4/28/10 10:32	48.5	4/28/10 11:47	50.1	4/28/10 13:21	37.3
S201877-AT_A.1	4/28/10 10:33	48.7	4/28/10 11:48	49.5	4/28/10 13:22	37
S201877-AT_A.1	4/28/10 10:34	49	4/28/10 11:49	48.8	4/28/10 13:23	36.8
S201877-AT_A.1	4/28/10 10:35	49.2	4/28/10 11:50	48.2	4/28/10 13:24	36.5
S201877-AT_A.1	4/28/10 10:36	49.4	4/28/10 11:51	47.5	4/28/10 13:25	36.2
S201877-AT_A.1	4/28/10 10:37	49.7	4/28/10 11:52	46.9	4/28/10 13:26	36.1
S201877-AT_A.1	4/28/10 10:38	49.9	4/28/10 11:53	46.7	4/28/10 13:27	36.3
S201877-AT_A.1	4/28/10 10:39	50.2	4/28/10 11:54	47.2	4/28/10 13:28	36.5
S201877-AT_A.1	4/28/10 10:40	50.4	4/28/10 11:55	47.8	4/28/10 13:29	36.7
S201877-AT_A.1	4/28/10 10:41	50.7	4/28/10 11:56	48.4	4/28/10 13:30	36.9
S201877-AT_A.1	4/28/10 10:42	50.9	4/28/10 11:57	49	4/28/10 13:31	37.1
S201877-AT_A.1	4/28/10 10:43	51.2	4/28/10 11:58	49.6	4/28/10 13:32	37.3
S201877-AT_A.1	4/28/10 10:44	51.4	4/28/10 11:59	50.2	4/28/10 13:33	37.5
S201877-AT_A.1	4/28/10 10:45	51.6	4/28/10 12:00	50.8	4/28/10 13:34	37.7
S201877-AT_A.1	4/28/10 10:46	51.6	4/28/10 12:01	51.4	4/28/10 13:35	37.7
S201877-AT_A.1	4/28/10 10:47	51.6	4/28/10 12:02	52	4/28/10 13:36	37.2
S201877-AT_A.1	4/28/10 10:48	51.5	4/28/10 12:03	51.9	4/28/10 13:37	36.8
S201877-AT_A.1	4/28/10 10:49	51.5	4/28/10 12:04	50.7	4/28/10 13:38	36.3
S201877-AT_A.1	4/28/10 10:50	51.5	4/28/10 12:05	49.5	4/28/10 13:39	37.6
S201877-AT_A.1	4/28/10 10:51	51.5	4/28/10 12:06	48.3	4/28/10 13:40	37.5
S201877-AT_A.1	4/28/10 10:52	51.5	4/28/10 12:07	47	4/28/10 13:41	37.5
S201877-AT_A.1	4/28/10 10:53	51.5	4/28/10 12:08	45.8	4/28/10 13:42	37.4
S201877-AT_A.1	4/28/10 10:54	51.4	4/28/10 12:09	44.6	4/28/10 13:43	37.3
S201877-AT_A.1	4/28/10 10:55	51.4	4/28/10 12:10	44.1	4/28/10 13:44	37.3
S201877-AT_A.1	4/28/10 10:56	51.3	4/28/10 12:11	44.9	4/28/10 13:45	37.2
S201877-AT_A.1	4/28/10 10:57	51.2	4/28/10 12:12	45.7	4/28/10 13:46	37
S201877-AT_A.1	4/28/10 10:58	51.1	4/28/10 12:13	46.6	4/28/10 13:47	36.8
S201877-AT_A.1	4/28/10 10:59	51.1	4/28/10 12:14	47.5	4/28/10 13:48	36.6
S201877-AT_A.1	4/28/10 11:00	51	4/28/10 12:15	48.3	4/28/10 13:49	36.4
S201877-AT_A.1	4/28/10 11:01	50.9	4/28/10 12:16	49.2	4/28/10 13:50	36.3
S201877-AT_A.1	4/28/10 11:02	53.3			4/28/10 13:51	36.1

## **APPENDIX E SAMPLE CALCULATIONS**

**SAMPLE CALCULATIONS, RUN 1**  
**HUNT REFINING COMPANY**  
**NO. 2 SULFUR RECOVERY UNIT**  
**4/27/2010**

**Absolute Stack Pressure** (inches Mercury)

$$P_s = P_{bar} + \frac{\overline{P_g}}{13.6}$$

$$P_g = \text{Stack Static Pressure (inches Water)} = -0.45$$

$$P_{bar} = \text{Barometric Pressure (inches Mercury)} = 29.80$$

$$P_s = 29.77$$

**Absolute Pressure at the Dry Gas Meter** (inches Mercury)

$$P_m = P_{bar} + \frac{\Delta H}{13.6}$$

$$P_{bar} = \text{Barometric Pressure (inches Mercury)} = 29.80$$

$$\Delta H = \text{Average pressure difference of orifice (inches Water)} = 1.50$$

$$P_m = 29.91$$

**Average Stack Gas Velocity** (feet per second)

$$V_s = K_p C_p \sqrt{\Delta P} \sqrt{\frac{\overline{T_s}}{M_s P_s}}$$

$$K_p = \text{Pitot tube constant} \sqrt{\frac{(\text{lb/lb - mole}) (\text{inches Hg})}{(\text{°R}) (\text{inches H}_2\text{O})}} = 85.49$$

$$\sqrt{\Delta P} = C_p = \text{Pitot tube coefficient (dimensionless)} = 0.84$$

$$\text{Velocity head of stack gas (inches H}_2\text{O)} = 0.2773$$

$$T_s = \text{Average absolute temperature of stack, degrees Rankin} = 1,005.3$$

$$M_s = \text{Molecular weight of stack gas; wet basis (lb/lb mole)} = 27.69$$

$$P_s = \text{Absolute stack pressure (inches Mercury)} = 29.77$$

$$V_s = 22.0$$

**Volume of Gas Sampled Measured by Dry Gas Meter**

(corrected to standard conditions, SDCF)

$$V_m(\text{Std}) = K_1 V_m Y \left[ \frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right]$$

$$K_1 = \text{Degrees R/inches Mercury} = 17.64$$

$$V_m = \text{Volume of gas sample as measured by dry gas meter (actual cubic feet)} = 40.81$$

$$Y = \text{Dry gas meter calibration factor (dimensionless)} = 0.9740$$

$$P_{\text{bar}} = \text{Barometric Pressure (inches Mercury)} = 29.80$$

$$\Delta H = \text{Average pressure difference of orifice (inches H}_2\text{O)} = 1.50$$

$$T_m = \text{Average absolute temperature of the dry gas, degrees Rankin} = 521.8$$

$$V_m(\text{Std}) = 40.182$$

**Volume of Water Vapor in Gas Sample**

(corrected to standard conditions, SDCF)

$$V_w(\text{Std}) = 0.0470 / V_{lc}$$

$$V_{lc} = \text{Total volume of liquid collected in impingers and silica gel (milliliters)} = 54.4$$

$$V_w(\text{Std}) = 2.561$$

**Water Vapor in the Gas Stream** proportion by volume (dimensionless)

$$B_{ws} = \frac{V_w(\text{Std})}{V_m(\text{Std}) + V_w(\text{Std})}$$

$$V_w(\text{std}) = \text{Volume of water in gas sample (corrected to standard conditions)} = 2.561$$

$$V_m(\text{std}) = \text{Volume of sample measured by dry gas meter (standard conditions)} = 40.182$$

$$B_{ws} = 0.060$$

**Molecular Weight of Stack Gas** (dry basis, lb/lb mole)

$$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

$$\%CO_2 = \text{Number percent by volume (dry basis from gas analysis)} = 0.5$$

$$\%O_2 = \text{Number percent by volume (dry basis from gas analysis)} = 5.7$$

$$\%N_2 + \%CO = \text{Number percent by volume (dry basis from gas analysis)} = 93.8$$

$$M_d = 28.31$$

**Molecular Weight of Stack Gas** (wet basis, lb/lb mole)

$$M_s = M_d(1 - B_{ws}) + 18(B_{ws})$$

$$M_d = \text{Molecular weight of stack gas (dry basis, lb/lb mole)} = 28.31$$

$$B_{ws} = \text{Water vapor in the gas stream (proportion by volume, dimensionless)} = 0.060$$

$$M_s = 27.69$$

**Volumetric Flow Rate** (actual cubic feet per minute)

$$Q_a = (V_s)(A_s)(60)$$

$$V_s = \text{Average stack gas velocity (feet per second)} = 22.0$$

$$A_s = \text{Cross sectional area of stack (feet squared)} = 5.5851$$

$$Q_a = 7,369$$

**Volumetric Flow Rate** (standard dry cubic feet per minute)

$$Q_s = Q_a(1 - B_{ws}) \frac{(528)}{T_s} \frac{(P_s)}{29.92}$$

$$Q_a = \text{Volumetric flow rate (actual cubic feet per minute)} = 7,369$$

$$B_{ws} = \text{Water vapor in the gas stream (proportion by volume, dimensionless)} = 0.060$$

$$T_s = \text{Average absolute temperature of stack, degrees Rankin} = 1,005.3$$

$$P_s = \text{Absolute stack pressure (inches Mercury)} = 29.77$$

$$Q_s = 3,618$$

**Volumetric Flow Rate** (standard wet cubic feet per minute)

$$Q_{sw} = Q_a \frac{(528)}{T_s} \frac{(P_s)}{29.92}$$

$$Q_a = \text{Volumetric flow rate (actual cubic feet per minute)} = 7,369$$

$$T_s = \text{Average absolute temperature of stack, degrees Rankin} = 1,005.3$$

$$P_s = \text{Absolute stack pressure (inches Mercury)} = 29.77$$

$$Q_{sw} = 3,848$$

**Nitrogen Oxides Emission Rate in Pounds per Hour**

$$E_{\text{lb/hour}} = \frac{MW_x}{385,000,000} C_{\text{ppm}_x} Q_{\text{std}} 60$$

x = Compound of interest ( SO <sub>2</sub> NO <sub>x</sub> CO VOC TRS etc) =	NO <sub>x</sub>
MW <sub>x</sub> = Molecular weight of compound (dry basis, lb/lb mole) =	46.01
C <sub>ppm<sub>x</sub></sub> = Pollutant Concentration (parts per million, dry basis) =	4.9
Q <sub>std</sub> = Volumetric flow rate (standard dry cubic feet per minute) =	3,618
E <sub>lb/hour</sub> =	0.13

**SAMPLE CALCULATIONS, RUN 1**  
**HUNT REFINING COMPANY**  
**NO. 2 SULFUR RECOVERY UNIT**  
**4/28/2010**

**Sulfur Dioxide Concentration (adjusted to 0% Oxygen)**

$$C_{\text{ppm}_x 0\% \text{O}_2} = C_{\text{ppm}_x} \left( \frac{20.9 - 0.0}{20.9 - \% \text{O}_2} \right)$$

x = Compound of interest ( SO <sub>2</sub> NO <sub>x</sub> CO VOC TRS etc) =	SO <sub>2</sub>
C <sub>ppm<sub>x</sub></sub> = Pollutant Concentration (parts per million, dry basis) =	55.0
%O <sub>2</sub> = Number percent by volume (dry basis from gas analysis) =	7.4
C <sub>ppm<sub>x</sub> 0%O<sub>2</sub></sub> =	84.9

**APPENDIX F SULFUR DIOXIDE RATA AND COMPLIANCE**  
**APRIL 27, 2010**



**SULFUR DIOXIDE RELATIVE ACCURACY TEST AUDIT****HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT****Tuesday, April 27, 2010**

<b>USE</b>	<b>RUN</b>	<b>START TIME Military</b>	<b>STOP TIME Military</b>	<b>Reference Method Sulfur Dioxide Concentration Corrected to 0% O2 (ppm-dry)</b>	<b>Pollutant Monitor Sulfur Dioxide Concentration Corrected to 0% O2 (ppm-dry)</b>	<b>Difference</b>
Y	RUN 1	7:14	7:35	77.4	40.9	36.5
Y	RUN 2	7:35	7:56	73.4	40.4	33.0
Y	RUN 3	7:56	8:17	70.0	41.3	28.7
Y	RUN 4	8:30	8:51	72.2	42.3	29.9
Y	RUN 5	8:51	9:12	67.0	41.5	25.5
Y	RUN 6	9:12	9:33	66.1	41.2	24.9
Y	RUN 7	9:45	10:06	76.6	44.5	32.1
Y	RUN 8	10:06	10:27	73.8	43.9	30.0
Y	RUN 9	10:27	10:48	74.3	44.4	29.8

**STD = Emission Standard = 250**

$$\text{Average Difference} = \bar{d} = \frac{1}{N} \sum_{i=1}^N d_i = 30.036$$

$$\text{Reference Method Average} = \bar{RM} = \frac{1}{N} \sum_{i=1}^N RM_i = 72.304$$

$$\text{Pollutant Monitor Average} = PR_{ave} = \frac{1}{N} \sum_{i=1}^N PR_i = 42.268$$

$$\text{Standard Deviation} = S_d = \sqrt{\frac{1}{N-1} \left\{ \sum_{i=1}^n d_i^2 - n\bar{d}^2 \right\}} = 3.578$$

$$\text{Confidence Coefficient} = |cc| = t_{0.975} \frac{S_d}{\sqrt{N}} = 2.750$$

$$\text{Relative Accuracy} = \frac{|\bar{d}| + |cc|}{\text{STD. Allowable}} \times 100 = 13.114$$

**SULFUR DIOXIDE RATA EMISSIONS TEST  
RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

<b>TEST</b>	<b>Start Time Military</b>	<b>Stop Time Military</b>	<b>Oxygen ( Dry) (measured) (Percent)</b>	<b>Sulfur Dioxide Emissions (ppm-dry)</b>	<b>Sulfur Dioxide Concentration Corrected to 0.0% O2 (ppm-dry)</b>
<b>RUN 1</b>	7:14	7:35	5.7	56.2	77.4
<b>RUN 2</b>	7:35	7:56	5.7	53.3	73.4
<b>RUN 3</b>	7:56	8:17	5.7	50.8	70.0
<b>RUN 4</b>	8:30	8:51	5.7	52.5	72.2
<b>RUN 5</b>	8:51	9:12	5.7	48.7	67.0
<b>RUN 6</b>	9:12	9:33	5.7	48.1	66.1
<b>RUN 7</b>	9:45	10:06	5.7	55.8	76.6
<b>RUN 8</b>	10:06	10:27	5.7	53.8	73.8
<b>RUN 9</b>	10:27	10:48	5.7	54.1	74.3
<b>Average</b>			<b>5.7</b>	<b>52.6</b>	<b>72.3</b>

**SULFUR DIOXIDE COMPLIANCE EMISSIONS  
TEST RESULTS  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

<b>TEST</b>	<b>Start Time Military</b>	<b>Stop Time Military</b>	<b>Oxygen ( Dry) (measured) (Percent)</b>	<b>Sulfur Dioxide Emissions (ppm-dry)</b>	<b>Sulfur Dioxide Concentration Corrected to 0.0% O2 (ppm-dry)</b>
<b>RUN 1</b>	7:14	8:17	5.7	53.4	73.6
<b>RUN 2</b>	8:30	9:33	5.7	49.8	68.4
<b>RUN 3</b>	9:45	10:48	5.7	54.6	74.9
<b>Average</b>			5.7	52.6	72.3
<b>Allowable</b>					250

**OXYGEN TESTING QUALITY ASSURANCE  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

**Analyzer Calibration Data**

INITIAL ANALYZER SPAN (Percent) =		21	ANALYZER ID.		OXYGEN
	CYLINDER VALUE Percent	ANALYZER RESPONSE (Percent)	DIFFERENCE (Percent)		DIFFERENCE % SPAN (ALLOWED 2%)
Zero Gas	0.00	0.00	0.0		0.0
High Range Gas	20.90	20.90	0.0		0.0
Mid Range Gas	10.60	10.60	0.0		0.0

**Test Results & Analyzer Calibration Bias and Drift Data**

data & calculation entry						
START TIME OF RUN	STOP TIME OF RUN	RUN #	ANALYZER STACK GAS CONCENTRATION UNCORRECTED (Percent)	SYSTEM ZERO (Percent)	SYSTEM UPSCALE (Percent)	CYLINDER CONCENTRATION UPSCALE CALIBRATION GAS (Percent)
		INITIAL SYSTEM		0.10	10.70	
7:14	7:35	RUN 1	5.80	0.00	10.70	10.6
7:35	7:56	RUN 2	5.80	0.00	10.70	10.6
7:56	8:17	RUN 3	5.80	0.00	10.70	10.6
8:30	8:51	RUN 4	5.70	0.00	10.50	10.6
8:51	9:12	RUN 5	5.70	0.00	10.50	10.6
9:12	9:33	RUN 6	5.70	0.00	10.50	10.6
9:45	10:06	RUN 7	5.70	0.00	10.80	10.6
10:06	10:27	RUN 8	5.70	0.00	10.80	10.6
10:27	10:48	RUN 9	5.70	0.00	10.80	10.6

system zero bias & drift			system upscale bias & drift			test results	RUN #
INITIAL SYSTEM ZERO CAL BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM ZERO CAL BIAS RESPONSE % SPAN (ALLOWED 5%)	ZERO DRIFT % SPAN (ALLOWED 3%)	INITIAL SYSTEM UPSCALE CAL BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM UPSCALE CAL BIAS RESPONSE % SPAN (ALLOWED 5%)	UPSCALE DRIFT % SPAN (ALLOWED 3%)	OXYGEN CONCENTRATION (Percent-Dry)	
0.48	0.00	-0.48	0.48	0.48	0.0	5.7	RUN 1
0.48	0.00	-0.48	0.48	0.48	0.0	5.7	RUN 2
0.48	0.00	-0.48	0.48	0.48	0.0	5.7	RUN 3
0.00	0.00	0.00	0.48	-0.48	-1.0	5.7	RUN 4
0.00	0.00	0.00	0.48	-0.48	-1.0	5.7	RUN 5
0.00	0.00	0.00	0.48	-0.48	-1.0	5.7	RUN 6
0.00	0.00	0.00	-0.48	0.96	1.4	5.7	RUN 7
0.00	0.00	0.00	-0.48	0.96	1.4	5.7	RUN 8
0.00	0.00	0.00	-0.48	0.96	1.4	5.7	RUN 9

**SULFUR DIOXIDE TESTING QUALITY ASSURANCE  
HUNT REFINING COMPANY  
NO. 2 SULFUR RECOVERY UNIT  
Tuesday, April 27, 2010**

**Analyzer Calibration Data**

INITIAL ANALYZER SPAN (PPM) =		125	ANALYZER ID.	SULFUR DIOXIDE
	CYLINDER VALUE PPM	ANALYZER RESPONSE (PPM)	DIFFERENCE (PPM)	DIFFERENCE % SPAN (ALLOWED 2%)
Zero Gas	0.00	0.00	0.0	0.0
High Range Gas	125.00	125.00	0.0	0.0
Mid Range Gas	50.03	50.00	0.0	0.0

**Test Results & Analyzer Calibration Bias and Drift Data**

data & calculation entry						
START TIME OF RUN	STOP TIME OF RUN	RUN #	ANALYZER STACK GAS CONCENTRATION UNCORRECTED (PPM)	SYSTEM ZERO (PPM)	SYSTEM UPSCALE (PPM)	CYLINDER CONCENTRATION UPSCALE CALIBRATION GAS (PPM)
			INITIAL SYSTEM	0.30	48.30	
7:14	7:35	RUN 1	53.50	1.50	47.20	50.03
7:35	7:56	RUN 2	50.80	1.50	47.20	50.03
7:56	8:17	RUN 3	48.50	1.50	47.20	50.03
8:30	8:51	RUN 4	49.40	-0.40	47.00	50.03
8:51	9:12	RUN 5	45.90	-0.40	47.00	50.03
9:12	9:33	RUN 6	45.30	-0.40	47.00	50.03
9:45	10:06	RUN 7	52.00	0.10	46.20	50.03
10:06	10:27	RUN 8	50.10	0.10	46.20	50.03
10:27	10:48	RUN 9	50.40	0.10	46.20	50.03

system zero bias & drift			system upscale bias & drift			test results	RUN #
INITIAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM ZERO CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	ZERO DRIFT % SPAN (ALLOWED 3%)	INITIAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	FINAL SYSTEM UPSCALE CAL. BIAS RESPONSE % SPAN (ALLOWED 5%)	UPSCALE DRIFT % SPAN (ALLOWED 3%)	SULFUR DIOXIDE CONCENTRATION (PPM-Dry)	
0.24	1.20	0.96	-1.36	-2.24	-0.9	56.2	RUN 1
0.24	1.20	0.96	-1.36	-2.24	-0.9	53.3	RUN 2
0.24	1.20	0.96	-1.36	-2.24	-0.9	50.8	RUN 3
1.20	-0.32	-1.52	-2.24	-2.40	-0.2	52.5	RUN 4
1.20	-0.32	-1.52	-2.24	-2.40	-0.2	48.7	RUN 5
1.20	-0.32	-1.52	-2.24	-2.40	-0.2	48.1	RUN 6
-0.32	0.08	0.40	-2.40	-3.04	-0.6	55.8	RUN 7
-0.32	0.08	0.40	-2.40	-3.04	-0.6	53.8	RUN 8
-0.32	0.08	0.40	-2.40	-3.04	-0.6	54.1	RUN 9

