

**HYDROTREATER LO-CAT OXIDIZER STACK
VOC AND H₂S COMPLIANCE TEST REPORT
AMERICAN REFINING GROUP, INC.
BRADFORD, PENNSYLVANIA**

Plan Approval No. 42-004E

Testing Date: December 8, 2010

Report Date: January 27, 2011

Prepared for:

American Refining Group, Inc.
77 N. Kendall Avenue
Bradford, Pennsylvania 16701

Prepared by:

Air/Compliance Consultants, Inc.
1050 William Pitt Way
Pittsburgh, Pennsylvania 15238
(412) 826-3636

PA Laboratory Registration Number: 02-742

Project Number 09-160

SOURCE TEST REPORT STATEMENT

This statement signed by the on-site supervisor of the test team and the source owner/operator certifies that "to the best of their knowledge" the source test report has been checked for completeness, and that the results presented are accurate, error-free, legible, and representative of the actual emissions measured during testing.

**HYDROTREATER LO-CAT OXIDIZER STACK
VOC AND H₂S COMPLIANCE TEST REPORT
AMERICAN REFINING GROUP, INC.
BRADFORD, PENNSYLVANIA**


Plan Approval No. 42-004E

Testing Date: December 8, 2010


Project No. 09-160




Eric S. White, QSTI
Project Manager
Air/Compliance Consultants, Inc.



Date



Jason L. Goodling
Environmental Manager
American Refining Group, Inc.



Date

TABLE OF CONTENTS

	<u>Page</u>
1 TEST REPORT SUMMARY.....	1
2 INTRODUCTION	1
3 TEST DATE AND PERSONNEL	1
4 PROCESS DESCRIPTION	2
4.1 Hydrotreater Unit.....	2
4.2 Desulfurization Unit	2
5 TESTING PROCEDURES.....	3
5.1 Sampling and Traverse Locations – USEPA Method 1	3
5.2 Gas Flow and Temperature Measurements – USEPA Method 2	3
5.3 Carbon Dioxide and Oxygen Determination – USEPA Method 3A.....	4
5.4 Moisture Content Sampling – USEPA Method 4	4
5.5 Hydrogen Sulfide Emissions - USEPA Method 11.....	4
5.6 Methane and Ethane Emissions – USEPA Method 18.....	5
5.7 Total Gaseous Non-methane Organic Emissions– USEPA Method 25	5
5.8 Process Data	5
5.9 Calculations	5
5.10 Calibrations	6
6 TESTING SUMMARY	6
7 CONCLUSION.....	6

TABLES

1. VOC Test Results, Low Cat Desulfurization Unit (ID:1002), V-204 Vessel Outlet
2. H₂S Test Results, Low Cat Desulfurization Unit (ID:1002), V-204 Vessel Outlet
3. Table Nomenclature

APPENDICES

- A. Accepted PADEP Protocol and Agency Correspondence
- B. ACCI Field Data Sheets
- C. Laboratory Data
- D. Quality Assurance / Quality Control Data
- E. Plant Production Data
- F. Sample Calculations

**HYDROTREATER LO-CAT OXIDIZER STACK
VOC AND H₂S COMPLIANCE TEST REPORT
AMERICAN REFINING GROUP, INC.
BRADFORD, PENNSYLVANIA**

Plan Approval No. 42-004E

1 TEST REPORT SUMMARY

Plan Approval Number: 42-004E			
Source Name: Hydrotreater Lo-Cat Oxidizer Stack			Source ID: #1001
Pollutant	Average Result	Permit Limit	Compliant / Non-compliant
Non-Methane Non-Ethane Volatile Organic Compounds	1.53 lb/hr	NA	Compliant
Hydrogen Sulfide	0.011 lb/hr	NA	Compliant

2 INTRODUCTION

Air/Compliance Consultants, Inc. (ACCI) conducted a compliance emission evaluation program at the American Refining Group, Inc. (ARG) facility located in Bradford, Pennsylvania. The purpose of the testing was to determine the emissions from the LO-CAT oxidizer exhaust for volatile organic compounds (VOCs) as propane (C₃H₈) and hydrogen sulfide (H₂S). The LO-CAT oxidizer exhaust was tested as detailed in the Pennsylvania Department of Environmental Protection (PADEP) September 2009 submitted protocol. Copies of the original test protocol, PADEP response letter, and PADEP electronic mail confirmation of testing are contained in Appendix A.

3 TEST DATE AND PERSONNEL

Testing was conducted on December 8, 2010. ACCI testing personnel consisted of Mr. Eric S. White, QSTI, Project Manager; Mr. Todd Haas, QSTI, Project Scientist/M11 Analyst; and Messrs. Thomas Payne and Kenji Kinoshita, Scientists. Mr. Shawn Mosier of ARG served as the

liaison for the duration of the test program. The following tables details the contact personnel regarding this test program:

COMPANY	TESTING FIRM
Mr. Jason Goodling American Refining Group, Inc. 77 N. Kendall Avenue Bradford, Pennsylvania 16701 (814) 368-1223 – Telephone (814) 368-1427 – Facsimile jgoodling@amref.com	Mr. Eric S. White, QSTI Air/Compliance Consultants, Inc. 1050 William Pitt Way Pittsburgh, Pennsylvania 15238 (412) 826-3636 – Telephone (412) 826-3640 – Facsimile ewhite@air-comp.com

USEPA Methods 11, 18, and 25 were analyzed by the following laboratories:

USEPA Method 11	USEPA Method 18	USEPA Method 25
Air/Compliance Consultants, Inc. Mr. Todd Haas 1050 William Pitt Way Pittsburgh, Pennsylvania 15238 (412) 826-3636 – Telephone (412) 826-3640 – Facsimile thaas@air-comp.com PA Lab Registration #02-742	Air Quality Services Ms. Nancy Kotsko 4527 Clairton Blvd. Pittsburgh, Pennsylvania 15236 (412) 881-5630 –Telephone (412) 881-7925 –Facsimile aqs1@earthlink.net PA Lab Registration #02-711	Triangle Environmental Services Mr. Wayne Stollings 6661 S. Alston Avenue Durham, North Carolina 27713 (919) 361-2890 – Telephone (919) 361-3474 Facsimile Lab Registration # 68-3321

4 PROCESS DESCRIPTION

4.1 Hydrotreater Unit

The Hydrotreater unit (Source ID #1001) serves to remove sulfur from fuels and lube oils through a reaction with hydrogen that is produced in other refinery processes (platformer catalytic reforming). Sulfur removed from the fuels and lube oils in the Hydrotreater is contained in the off gas from the Hydrotreater in the form of H₂S. In turn, Hydrotreater unit off gas is directed to the Desulfurization unit.

4.2 Desulfurization Unit

The Desulfurization unit reduces sulfur loading in the off gas through a series of chemical reactions; the sulfur is recovered as a solid product. Unlike a Claus unit, which has been traditionally applied at petroleum refineries, the Desulfurization unit does not produce sulfur dioxide (SO₂) as a reactant; it uses chemical reduction and chemical oxidation to recover sulfur

from the gas, producing no potential hazardous by-products. The Desulfurization unit generally consists of an absorber section (ID #C1001) and an oxidizer section (ID #C1001A). In the absorber section, hydrogen atoms are liberated from sulfur as an iron chelate binds to the sulfur, thereby displacing the hydrogen. Following treatment of the Hydrotreater off gas stream in the absorber section, the resulting "sweet gas" is directed to various refinery process heaters and boilers. The iron chelate solution is regenerated in the oxidizer section as oxygen displaces sulfur bound to the chelate. The sulfur is then recovered as a solid and the regenerated iron chelate is pumped back to the absorber in a cyclical process. All atmospheric exhaust from the Desulfurization unit are from the oxidizer section and specifically the LO-CAT oxidizer stack (Stack ID #S1001).

5 TESTING PROCEDURES

All source testing was conducted in accordance with the October 8, 2009 test protocol, the PADEP acceptance letter sent October 26, 2009, PADEP electronic mail confirmation on November 12, 2010 and USEPA, Title 40, CFR, Part 60, Appendix A and the procedures described below.

5.1 Sampling and Traverse Locations – USEPA Method 1

The sampling location for the collection of gas-flow data is located at the desulfurization unit oxidizer vent exhaust stack. The inside diameter (ID) of the stack, at the sampling location, is 8.0". The nearest upstream disturbance from the flow sample port is 56" and the nearest downstream disturbance is 24". Two, 2.0" test ports, at 90° from each other, were utilized for the test program. Flow points were determined at 8 points per port for a total of 16 points in all.

5.2 Gas Flow and Temperature Measurements – USEPA Method 2

Gas flow measurements were conducted using USEPA Method 2, *Determination of Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)*. Although it was a small pipe, Method 2A could not be used due to the nipple length as discussed prior to the field test (November 11, 2010). The gas flow rate and temperature for the gas streams were measured by conducting simultaneous velocity and temperature measurements during each sampling run. Gas velocity head was measured with a calibrated S Type Pitot tube that was connected to a manometer. The

static pressure was measured using the same Pitot tube and manometer. A Chrome-Alumel thermocouple attached to a digital indicator was used to measure the gas temperature at each of the traverse points.

5.3 Carbon Dioxide and Oxygen Determination – USEPA Method 3C

The principles of USEPA Method 3C, *Determination of Carbon Dioxide, Methane, Nitrogen, and Oxygen from Stationary Sources*, was utilized for the determination of oxygen (O₂) and carbon dioxide (CO₂) for the test program. An integrated bag sample was pulled during each test run over the 60-minute test period. This bag was sent to AQS for analysis by USEPA Method 3C, ASTM D-1945. Nitrogen (N) concentrations were determined by the difference.

5.4 Moisture Content Sampling – USEPA Method 4

Moisture content sampling was conducted concurrently with each sampling run using the principles presented in USEPA Method 4, *Determination of Moisture Content in Stack Gases*. Parameters evaluated in order to determine the gas stream moisture content were sample gas volume, temperature, pressure and impingers, and silica gel moisture gain.

5.5 Hydrogen Sulfide Emissions - USEPA Method 11

The principles of USEPA Method 11, *Determination of Hydrogen Sulfide Content of Fuel Gas Streams in Petroleum Refineries*, were used for this test program. The sample gas was extracted through a short heated Teflon[®] probe connected to a series of six midget impingers. The first impinger contained 15 milliliters (ml) of hydrogen peroxide. The second impinger remained empty. The third, fourth, and fifth impingers each contained 15 ml of cadmium sulfate absorbing solution. A silica gel midget impinger followed the impinger set. A volatile organic sampling train (VOST) type meter box was utilized to control the sample flow rate and to measure the sample volume.

Three 60-minute test runs were performed. Samples were collected at a rate of 1 liter per minute (lpm) for each testing run. At the conclusion of each test, the impinger train was purged with clean ambient air for 15 minutes at a rate of 1 lpm.

5.6 Methane and Ethane Emissions – USEPA Method 18

Tedlar[®] bag samples were taken utilizing USEPA Method 18 procedures, *Measurement of Gaseous Organic Compound Emissions by Gas Chromatography*. These bags were then analyzed for methane/ethane hydrocarbons; emissions are reported as non-methane/non-ethane VOCs (NMEVOC).

5.7 Total Gaseous Non-methane Organic Emissions– USEPA Method 25

USEPA Method 25, *Determination of Total Gaseous Non-methane Organic Emissions as Carbon*. The sampling system consisted of a heated probe, heated filter, condensate trap, flow control system, and sample tank. The sample tank was evacuated prior to collecting samples and leak checked 24 hours later. An emission sample was drawn from the sample port at a point centrally located within the duct, at a constant rate of 100 cubic centimeters per minute (ccm) through a heated filter and a condensate trap, chilled with dry ice, by means of the evacuated sample tank. After the 1-hour sample run, the condensate trap was removed from the sample train, capped, and uniquely labeled, then kept on dry ice until reaching the analytical laboratory. The sample tank was removed from the sample train, capped, and uniquely labeled. The sample set (1 trap and 1 sample tank), information was included on a Chain of Custody (COC) form completed for shipment to the laboratory. The total gaseous non-methane organics (TGNMOs) was determined by independently analyzing the condensate trap and sample tank fractions and combining the analytical results. Field data related to USEPA Method 25 sampling was recorded on field data sheets and have been provided in Appendix B. All laboratory analysis sheets are contained in Appendix C and all relevant quality assurance / quality control (QA/QC) data can be found in Appendix D.

5.8 Process Data

ARG personnel recorded the absorber refinery fuel gas throughput at least every 15 minutes during each testing period. A copy of the process data can be located in Appendix E

5.9 Calculations

Emission calculations were completed using a computer spreadsheet format. The results of each pertinent parameter are detailed on the spreadsheet for each sampling run and provided in the

Appendix B. A sample calculation for one complete test run of each parameter is included in Appendix F.

5.10 Calibrations

The following field equipment calibrations are contained in Appendix D:

- Thermocouple
- Dry gas meter and orifice
- Pitot tube
- Qualified Source Testing Individual (QSTI) Certificates

6 TESTING SUMMARY

The results of the testing program are presented in Tables 1 and 2 and Table 3 contains the table nomenclature.

7 CONCLUSION

A compliance emissions evaluation program has been conducted for the American Refining Group, Inc. on their LO-CAT oxidizer exhaust located in Bradford, Pennsylvania. Test results represent data that is considered to be representative of the emission rate at the prevailing operating conditions.

To the best of ACCI's knowledge, this source test report has been checked for completeness and the results contained herein are accurate, error-free, and representative of the actual emissions measured during testing.

TABLES

Table 1. VOC Test Results, Lo-Cat Desulfurization Unit (ID:1002), V-204 Vessel Outlet
American Refining Group, Inc., Bradford, Pennsylvania

Test Data		Run 1	Run 2	Run 3	Average
Date		12/08/10	12/08/10	12/08/10	
Start Time		7:57 AM	9:27 AM	10:57 AM	
End Time		8:57 AM	10:27 AM	11:57 AM	
Flow Rate	(ACFM)	386	561	572	506
Flow Rate	(SCFM)	333	484	493	437
Flow Rate	(DSCFM)	290	420	426	379
Flow Rate	(DSCM/min)	8	12	12	11
Sample Volume	(DSCF)	22.25	21.93	22.15	22.11
Sample Volume	(DSCM)	0.63	0.62	0.63	0.63
Carbon Dioxide (CO ₂)	(dry volume %)	0.10	0.09	0.16	0.12
Oxygen (O ₂)	(dry volume %)	20.25	20.02	20.09	20.12
Water Vapor (H ₂ O)	(volume %)	13.06	13.15	13.51	13.24
Stack Temperature	(°F)	122.8	123.0	124.0	123.3

Results

Total Gaseous Non-Methane Organic (TGNMO) by M25

TGNMO Conc. as Carbon	(ppm _{dv})	2361	2277	2281	2306.3
TGNMO Conc. as Propane	(ppm _{dv})	787.0	759.0	760.3	768.8

Non-Methane, Non-Ethane Volatile Organic Compounds (NMEVOC)

Ethane Concentration	(ppm _{dv})	304.9	301.2	208.4	271.5
Ethane as Propane	(ppm _{dv})	203.3	200.8	138.9	181.0
NMEVOC Concentration as Propane	(ppm _{dv})	583.7	558.2	621.4	587.8
NMEVOC Emission Rate as Propane	(lb/hr)	1.16	1.61	1.82	1.53

Table 2. H₂S Test Results, Lo-Cat Desulfurization Unit (ID:1002), V-204 Vessel Outlet
American Refining Group, Inc., Bradford, Pennsylvania

Test Data		Run 1	Run 2	Run 3	Average
Date		12/08/10	12/08/10	12/08/10	
Start Time		12:46 PM	1:53 PM	3:00 PM	
End Time		1:46 PM	2:53 PM	4:00 PM	
Flow Rate	(ACFM)	567	563	588	573
Flow Rate	(SCFM)	489	486	507	494
Flow Rate	(DSCFM)	425	422	441	429
Flow Rate	(DSCM/min)	12	12	12	12
Sample Volume	(DSCF)	22.43	22.23	22.55	22.41
Sample Volume	(DSCM)	0.64	0.63	0.64	0.63
Carbon Dioxide (CO ₂)	(dry volume %)	0.10	0.10	0.10	0.10
Oxygen (O ₂)	(dry volume %)	20.70	20.70	20.70	20.70
Water Vapor (H ₂ O)	(volume %)	13.15%	13.15%	13.15%	13.15%
Stack Temperature	(°F)	123.0	123.0	123.0	123.0
Results					
Hydrogen Sulfide					
Concentration	(ppm _{dv})	2.74	11.65	0.45	4.95
Emission	(lb/hr)	0.0062	0.026	0.0011	0.011

Table 3.

TABLE NOMENCLATURE

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
%	- Percent	gpm	- Gallons per minute	OSHA	- Occupational Safety & Health Administration
% Volume	- Percent by volume	H ₂ O	- Water	PADEP	- PA Department of Environmental Protection
°F	- Degrees Fahrenheit	H ₂ SO ₄	- Sulfuric acid	Pb	- Lead
<	- Less than	HAP	- Hazardous air pollutant	PEL	- Permissible exposure limit
>	- Greater than	Hg	- Mercury	PM	- Particulate matter
AB	- Acetone Blank	HI	- Heat input	PM ₁₀	- Particulate matter less than 10 microns
ACFM	- Actual cubic feet per minute	Hp	- Horsepower	ppb	- Parts per billion
BACT	- Best Available Control Technology	hr	- Hour	PPE	- Personal protective equipment
BHP	- Brake horsepower	IC	- Ion chromatography	ppm	- Parts per million
BTU	- British thermal units	in H ₂ O	- Inches of Water	ppm _{dw}	- Parts per million, dry volume
C ₃ H ₈	- Propane	in Hg	- Inches of Mercury	ppm _{wv}	- Parts per million, wet volume
CE	- Capture efficiency	Kg	- Kilograms	psia	- Pounds per square inch absolute
CEMS	- Continuous emission monitor system	lb	- Pound	psig	- Pounds per square inch gauge
cf	- Cubic foot	lb/hr	- Pound per hour	PTI	- Permit to Install
CFR	- Code of Federal Regulations	lb/lb-mole	- Pound per pound mole	PTE	- Permanent total enclosure
CH ₄	- Methane	MACT	- Maximum Achievable Control Technology	RA	- Relative Accuracy
C ₂ H ₆	- Ethane	m ³	- Cubic meters	RATA	- Relative Accuracy Test Audit
Cl ₂	- Chlorine	MDL	- Minimum detection limit	RM	- Reference Method
CO	- Carbon monoxide	mg	- Milligrams	RMD	- Relative mean difference
CO ₂	- Carbon dioxide	mg/g	- Milligrams per gram	S	- Sulfur
COG	- Coke oven gas	mL	- Milliliter	SCF	- Standard cubic feet
DACF	- Dry actual cubic feet	mm HG	- Millimeters of mercury	SCFM	- Standard cubic feet per minute
DACM	- Dry actual cubic meters	MMBtu	- Million British thermal units	SCM	- Standard cubic meters
DE	- Destruction efficiency	MNOC	- Maximum normal operating capacity	SO ₂	- Sulfur dioxide
DSCF	- Dry standard cubic feet	MSDS	- Material Safety Data Sheet	STD	- Standard
DSCFM	- Dry standard cubic feet per minute	MW	- Megawatts	TEQ	- Toxicity Equivalence Quotient
FID	- Flame Ionization Detector	N ₂	- Nitrogen	THC	- Total hydrocarbons
ft	- Foot	ND	- Non-detectable	tph	- Tons per hour
ft/sec	- Feet per second	NDO	- Natural draft opening	tpy	- Tons per year
ft ²	- Square feet	NESHAP	- National Emission Standard for Hazardous Air Pollutants	µg	- Micrograms
ft ³	- Cubic feet	ng	- Nanograms	USEPA	- United States Environmental Protection Agency
ft ³ /lb-mole	- Cubic feet per pound mole	NMEVOC	- Non-methane, non-ethane volatile organic compounds	VE	- Visible emissions
g	- Grams	NMVOC	- Non-methane volatile organic compound	VOC	- Volatile organic compound
g/mL	- Gram per milliliter	NO ₂	- Nitrous Oxide	vol	- Volume
GC	- Gas Chromatography	NO _x	- Oxides of Nitrogen	w/o	- With out
gr/DSCF	- Grains per dry standard cubic feet	O ₂	- Oxygen		

APPENDIX A

Accepted PADEP Protocol and Agency Correspondence

**HYDROTREATER LO-CAT DESULFURIZATION UNIT
VOC AND H₂S TEST PROTOCOL
AMERICAN REFINING GROUP, INC.
BRADFORD, PENNSYLVANIA**

Plan Approval No. 42-004E

September 2009

Prepared for:

American Refining Group, Inc.
77 N. Kendall Avenue
Bradford, Pennsylvania 16701

Prepared by:

Air/Compliance Consultants, Inc.
1050 William Pitt Way
Pittsburgh, Pennsylvania 15238
(412) 826-3636

PA Laboratory Registration Number: 02-742

Project Number 09-160



**Air/Compliance
Consultants, Inc.**

TEST METHOD CERTIFICATION

American Refining Group, Inc. and Air/Compliance Consultants, Inc. have conducted a review of the state and federal regulations which apply to each source at American Refining Group, Inc. in order to develop the test methods described in this protocol. We certify, to the best of our knowledge, that the test methods that have been incorporated into the attached protocol meet the testing requirements of the applicable regulations.

HYDROTREATER LO-CAT DESULFURIZATION UNIT VOC AND H₂S TEST PROTOCOL AMERICAN REFINING GROUP, INC. BRADFORD, PENNSYLVANIA


Plan Approval No. 42-004E

September 2009

Project No. 09-160



Eric S. White
Project Manager, QSTI
Air/Compliance Consultants, Inc.



Jason L. Goodling
Environmental Manager
American Refining Group, Inc.

TABLE OF CONTENTS

	<u>Page</u>
1 INTRODUCTION.....	1
2 COMPANY AND TESTING FIRM INFORMATION.....	1
3 ANALYTICAL LABORATORY INFORMATION.....	1
4 SCOPE AND OBJECTIVES.....	2
5 PROCESS DESCRIPTION.....	2
5.1 Hydrotreater Unit.....	2
5.2 Desulfurization Unit.....	2
6 TESTING PROCEDURES.....	3
6.1 Sampling and Traverse Locations.....	3
6.2 Gas Flow and Temperature Measurements.....	3
6.3 CO ₂ and O ₂ Determination.....	3
6.4 Moisture Content Sampling.....	4
6.5 Determination of Hydrogen Sulfide Emissions.....	4
6.6 Determination of VOC Emissions.....	4
6.7 Determination of Total Gaseous Nonmethane Organic Emissions.....	5
6.8 Verification of Gas Dilution System.....	5
6.9 Process Data.....	6
6.10 Calculations.....	6
6.11 Calibrations.....	6
7 FORMULAS TO BE USED IN DATA REDUCTION.....	6
8 EXAMPLES OF FIELD DATA SHEETS.....	6
9 TESTING SCHEDULE.....	6
10 PLANT SAFETY.....	6
11 REPORTING.....	7

FIGURES

1. Hydrotreater and Desulfurization Unit Simple Block Diagram
2. LO-CAT Oxidizer Outlet Sample Location Schematic
3. USEPA Method 25A Sampling Train Schematic
4. Method 25 Sampling Train Schematic

APPENDICES

- A. PADEP Plan Approval No. 42-004E and Agency Correspondence
- B. Sample Calculations
- C. Example Field Data Sheets

**HYDROTREATER LO-CAT DESULFURIZATION UNIT
VOC AND H₂S TEST PROTOCOL
AMERICAN REFINING GROUP, INC.
BRADFORD, PENNSYLVANIA**

Plan Approval No. 42-004E

1 INTRODUCTION

American Refining Group, Inc. (ARG) has contracted Air/Compliance Consultants, Inc. (ACCI) to perform an emissions evaluation of the LO-CAT oxidizer vent at their facility located in Bradford, Pennsylvania. Emission rates will be determined for volatile organic compounds (VOCs) as propane (C₃H₈) and hydrogen sulfide (H₂S). A previously approved VOC test protocol, submitted in 2008 and accepted on October 3, 2008, was referenced to complete the following protocol. This protocol represents the initial VOC and H₂S performance test for the aforementioned unit under the newly submitted Plan Approval No. 42-004E, formerly No. 42-004C. No testing was performed for the 2008 protocol.

2 COMPANY AND TESTING FIRM INFORMATION

COMPANY	TESTING FIRM
Mr. Jason Goodling American Refining Group, Inc. 77 N. Kendall Avenue Bradford, Pennsylvania 16701 (814) 368-1223 – Telephone (814) 368-1427 – Facsimile jgoodling@amref.com	Mr. Eric White Air/Compliance Consultants, Inc. 1050 William Pitt Way Pittsburgh, Pennsylvania 15238 (412) 826-3636 – Telephone (412) 826-3640 – Facsimile ewhite@air-comp.com

3 ANALYTICAL LABORATORY INFORMATION

USEPA Methods 11, 18, and 25 will be analyzed by the following laboratories:

USEPA Method 11	USEPA Method 18	USEPA Method 25
Air/Compliance Consultants, Inc. Mr. Todd Haas 1050 William Pitt Way Pittsburgh, Pennsylvania 15238 (412) 826-3636 – Telephone (412) 826-3640 – Facsimile thaas@air-comp.com PA Lab Registration #02-742	Air Quality Services Ms. Nancy Kotsko 4527 Clairton Blvd. Pittsburgh, Pennsylvania 15236 (412) 881-5630 –Telephone (412) 881-7925 –Facsimile aqsl@earthlink.net PA Lab Registration #02-711	Triangle Environmental Services Mr. Wayne Stollings 6661 S. Alston Avenue Durham, North Carolina 27713 (919) 361-2890 – Telephone (919) 361-3474 Facsimile Lab Registration # 68-3321

4 SCOPE AND OBJECTIVES

The scope of this project is to determine emissions from the Hydrotreater LO-CAT Desulfurization Unit and comply with the performance testing requirements of Plan Approval No. 42-004E. Testing and analyses will be conducted using the principles of the United States Environmental Protection Agency (USEPA) Methods 1, 2C, 3, 4, 11, 18, 25, 25A, and 205 as described in 40 Code of Federal Regulations (CFR), Part 60, Appendix A, and the methodology described in the PADEP *Source Testing Manual*. The testing is intended to comply with Pennsylvania Department of Environmental Protection's (PADEP) Plan Approval No. 42-004E Request for Testing. Pertinent pages of the Plan Approval are contained in Appendix A.

5 PROCESS DESCRIPTION

5.1 Hydrotreater Unit

The Hydrotreater unit (Source ID #S1001) serves to remove sulfur from fuels and lube oils through a reaction with hydrogen that is produced in other refinery processes (platformer catalytic reforming). Sulfur removed from the fuels and lube oils in the Hydrotreater is contained in the off gas from the Hydrotreater in the form of hydrogen sulfide (H_2S). In turn, Hydrotreater unit off gas is directed to the Desulfurization unit.

5.2 Desulfurization Unit

The Desulfurization unit reduces sulfur loading in the off gas through a series of chemical reactions; the sulfur is recovered as a solid product. Unlike a Claus unit, which has been traditionally applied at petroleum refineries, the Desulfurization unit does not produce sulfur dioxide (SO_2) as a reactant; it uses chemical reduction and chemical oxidation to recover sulfur from the gas, producing no potential hazardous by-products. The Desulfurization unit generally consists of an absorber section (ID #C1001) and an oxidizer section (ID #C1001A). In the absorber section, hydrogen atoms are liberated from sulfur as an iron chelate binds to the sulfur, thereby displacing the hydrogen. Following treatment of the Hydrotreater off gas stream in the absorber section, the resulting "sweet gas" is directed to various refinery process heaters and boilers. The iron chelate solution is regenerated in the oxidizer section as oxygen displaces sulfur bound to the chelate. The sulfur is then recovered as a solid and the regenerated iron

chelate is pumped back to the absorber in a cyclical process. All atmospheric exhaust from the Desulfurization unit will be from the oxidizer section and specifically the LO-CAT oxidizer stack (Stack ID #S1001). A simple block diagram is located in Figure 1.

6 TESTING PROCEDURES

Testing will be conducted in accordance with USEPA, Title 40, CFR, Part 60, Appendix A and the procedures described below.

6.1 Sampling and Traverse Locations

The sampling location for the collection of gas-flow data is located at the desulfurization unit oxidizer vent exhaust stack. The inside diameter of the stack, at the sampling location, is 8.0" (Figure 2). The nearest upstream disturbance from the flow sample port is approximately 56" and the nearest downstream disturbance is approximately 24". The flow and gas samples will be collected from the center of the stack as shown in Figure 2.

6.2 Gas Flow and Temperature Measurements

Gas flow measurements will be conducted using USEPA Method 2C, *Determination of Gas Velocity and Volumetric Flow Rate in Small Stacks or Ducts (Standard Pitot Tube)*. The gas flow rate and temperature for the gas streams will be measured by conducting simultaneous velocity and temperature measurements during each sampling run. Gas velocity head will be measured with a calibrated Standard Pitot tube that will be connected to a manometer. The static pressure will be measured using the same Pitot tube and manometer. A Chrome-Alumel thermocouple attached to a digital indicator will be used to measure the gas temperature at each of the traverse points.

6.3 CO₂ and O₂ Determination

The principles of USEPA Method 3A, *Gas Analysis for the Determination of Dry Molecular Weight (Instrumental Analyzer Procedure)*, will be utilized for the determination of oxygen (O₂) and carbon dioxide (CO₂) for the test program. A paramagnetic analyzer or equivalent will be used to continuously measure O₂ concentrations and a non-dispersive infrared (NDIR) analyzer or equivalent will be used to continuously measure CO₂ concentrations at each testing location.

An extractive gas-conditioning system will be used to convey the sample to the gas analyzers. Nitrogen (N) concentration will be determined by the difference.

6.4 Moisture Content Sampling

Moisture content sampling will be conducted concurrently with each sampling run using the principles presented in USEPA Method 4, *Determination of Moisture Content in Stack Gases*. Parameters to be evaluated in order to determine the gas stream moisture content will be sample gas volume, temperature, pressure and impingers, and silica gel moisture gain.

6.5 Determination of Hydrogen Sulfide Emissions

The principles of USEPA Method 11, *Determination of Hydrogen Sulfide Content of Fuel Gas Streams in Petroleum Refineries*, will be used for this test program. The sample gas will be extracted through a short Teflon probe connected to a series of six midget impingers. The first impinger will contain 15 milliliters (ml) of hydrogen peroxide. The second impinger will remain empty. The third, fourth, and fifth impingers will contain 15 ml of cadmium sulfate absorbing solution. A silica gel midget impinger will follow the impinger set. A volatile organic sampling train (VOST) type meter box will be used to control the sample flow rate and to measure the sample volume.

Three 60-minute test runs will be performed. Samples will be collected at a rate of approximately 1 liter per minute (lpm) for each testing run. At the conclusion of each test, the impinger train will be disconnected and the impinger train purged with clean ambient air for 15 minutes at a rate of 1 lpm.

6.6 Determination of VOC Emissions

USEPA Method 25A, *Determination of Total Gaseous Organic Concentration using a Flame Ionization Analyzer*, will be used to collect and analyze for total hydrocarbons (THC). Sampling will follow USEPA Guidance Document 033 for methodology and sampling system operation. See Figure 3 for Method 25A Sampling Train Schematic. The gas sample will be extracted with a heated sample line and analyzed with a JUM VOC analyzer without using a sample conditioner. This measurement provides information collectively on all hydrocarbons containing

gas constituents in terms of C_3H_8 equivalent concentrations. Three 60-minute sampling runs will be performed on the exhaust stack. Emissions will be reported in terms of propane. Sample lines will be heated to $375^{\circ}\pm 25^{\circ}F$. The instrument will be calibrated to 25-75% of span.

Tedlar bag samples will be taken utilizing USEPA Method 18 procedures, *Measurement of Gaseous Organic Compound Emissions by Gas Chromatography*. These bags will then be analyzed for methane/ethane hydrocarbons so emissions can be reported as non-methane/non-ethane volatile organic compounds (NMEVOC).

6.7 Determination of Total Gaseous Nonmethane Organic Emissions

If the results from Method 25A analysis are above 50 parts per million (ppm) as carbon, then the VOC emissions will be tested in accordance with USEPA Method 25, *Determination of Total Gaseous Nonmethane Organic Emissions as Carbon*. The sampling system consists of a heated probe, heated filter, condensate trap, flow control system, and sample tank (Figure 4). The sample tank will be evacuated prior to collecting samples and leak checked. An emission sample will be withdrawn from the sample port at a point centrally located within the duct, at a constant rate through a heated filter and a condensate trap, chilled with dry ice, by means of the evacuated sample tank. After the 1-hour sample run, the condensate trap will be removed from the sample train, capped, and uniquely labeled, then kept on dry ice until reaching the analytical laboratory. The sample tank will be removed from the sample train, capped, and uniquely labeled. The sample set (1 trap and 1 sample tank), information will be included on a Chain of Custody (COC) form completed for shipment to the laboratory. The total gaseous non-methane organics (TGNMOs) will be determined by independently analyzing the condensate trap and sample tank fractions and combining the analytical results. Field data related to USEPA Method 25 sampling will be recorded on field data sheets, which have been provided in Appendix C.

6.8 Verification of Gas Dilution System

USEPA Method 205, *Verification of Gas Dilution Systems for Field Instrument Calibrations*, utilizing USEPA Protocol gases and an Environics Model 4040 Computerized Gas Dilution System, may be used for several analyzer calibration values. USEPA Method 205 results and the unit calibration data will be included in the final report, if necessary.

6.9 Process Data

ARG personnel will record the absorber refinery fuel gas throughput at least every 15 minutes during each testing period for inclusion in the final report.

6.10 Calculations

Emission calculations will be completed by using a computer spreadsheet format. The results of each pertinent parameter will be detailed on a spreadsheet for each sampling run and provided in the final report. A sample calculation for one complete test run of each parameter will be included in the final report.

6.11 Calibrations

The following field equipment calibrations will be contained in the final report:

- Thermocouple,
- Dry gas meter and orifice,
- Pitot tube,
- Analyzer calibration data, and
- Calibration gas certificates and USEPA Method 205 verifications.

7 FORMULAS TO BE USED IN DATA REDUCTION

See Appendix B.

8 EXAMPLES OF FIELD DATA SHEETS

See Appendix C.

9 TESTING SCHEDULE

A tentative test date of December 9, 2009 is planned. ARG will contact the PADEP of the exact date.


10 PLANT SAFETY

ACCI personnel will comply with all ARG safety requirements. Those requirements are hard hats, steel-toed work boots, full-length pants, shirt, and eye protection. Sampling sites may require additional items such as site specific safety training, respirators, Nomex coveralls, hearing protection, and fall protection items.

11 REPORTING

At the conclusion of the field evaluation program, a test report summarizing the findings will be prepared in accordance with USEPA and PADEP requirements. Included in the report will be a sampling procedure description, names of individuals present for the testing, and average test results for each pollutant. The report will also contain all field data sheets and supporting sample calculations. The final report will be submitted within 60 days after completion of the field-testing.


FIGURES



Hydrotreater and Desulfurization Unit Sample Block Diagram
American Refining Group, Bradford, Pennsylvania

Figure 1

AIR/COMPLIANCE CONSULTANTS, INC.
USEPA METHOD 1 DATA SHEET



LO-CAT Oxidizer Outlet Sample Location Schematic
American Refining Group, Inc. Bradford, Pennsylvania

Figure
2





Figure
3

USEPA Method 25A Sampling Train Schematic



APPENDIX A

**Relevant Pages of PADEP Plan
Approval No. 42-004E and
Agency Correspondence**

SECTION D. Source Level Plan Approval Requirements


Source ID: 1001

Source Name: HYDROTREATER UNIT

Source Capacity/Throughput:

25 266 MCF/HR

Refinery Gas

**I. RESTRICTIONS.****Emission Restriction(s).**

001 [25 Pa. Code §123.21]

General

No person may permit the emission into the outdoor atmosphere of sulfur oxides from a source in a manner that the concentration of the sulfur oxides, expressed as SO₂, in the effluent gas exceeds 500 parts per million, by volume, dry basis.

002 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

(a) This source is subject to 25 Pa Code Sections 123.1, 123.31, and 123.41 for fugitive, odor, and visible emissions, respectively.

(b) No person may permit the emission into the outdoor atmosphere of particulate matter in a manner that the concentration of particulate matter in the effluent gas exceeds 0.04 grain per dry standard cubic foot.

II. TESTING REQUIREMENTS.

003 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

(a) Within 180 days of the issuance of the Plan Approval or a schedule approved by the Department, a stack test shall be performed in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection. The stack test shall be performed while the aforementioned source is operating at the maximum or normal rated capacity as stated on the application. The stack test shall be conducted for VOC and H₂S at the exhaust from the LO-CAT Oxidizer (S1001).

(b) The following methods shall be used to conduct emission testing unless another method is approved by the Department.

If VOC < 50 ppm C: THC M25A + M18 (methane/ethane)

If VOC > 50 ppm C: NMOC M25

H₂S: M11

(c) Pursuant to 25 Pa. Code 139.3, at least 45 calendar days prior to commencing an emissions testing program, a test protocol shall be submitted to the Department for review and approval. The test protocol shall meet all applicable requirements specified in the most current version of the Department's Source Testing Manual.

(d) Pursuant to 25 Pa. Code 139.3 at least 15 calendar days prior to commencing an emission testing program, notification as to the date and time of testing shall be given to the appropriate Regional Office. Notification shall also be sent to the Division of Source Testing and Monitoring. Notification shall not be made without prior receipt of a protocol acceptance letter from the Department.

(e) Pursuant to 25 Pa. Code Section 139.53(a)(3) within 15 calendar days after completion of the on-site testing portion of an emission test program, if a complete test report has not yet been submitted, an electronic mail notification shall be sent to the Department's Division of Source Testing and Monitoring indicating the completion date of the on-site testing.

SECTION D. Source Level Plan Approval Requirements

(f) Pursuant to 40 CFR Part 63.7(g) a complete test reports shall be submitted to the Department no later than 60 calendar days after completion of the on-site testing portion of an emission test program.

(g) Pursuant to 25 Pa. Code Section 139.53(b) a complete test report shall include a summary of the emission results on the first page of the report indicating if each pollutant measured is within permitted limits and a statement of compliance or non-compliance with all applicable permit conditions. The summary results will include, at a minimum, the following information:

1. A statement that the owner or operator has reviewed the report from the emissions testing body and agrees with the findings.

2. Permit number(s) and condition(s) which are the basis for the evaluation.

3. Summary of results with respect to each applicable plan approval condition.

4. Statement of compliance or non-compliance with each applicable plan approval condition.

(h) Pursuant to 25 Pa. Code § 139.3 all submittals shall meet all applicable requirements specified in the most current version of the Department's Source Testing Manual.

(i) All testing shall be performed in accordance with the provisions of Chapter 139 of the Rules and Regulations of the Department of Environmental Protection.

(j) Pursuant to 25 Pa. Code Section § 139.53(a)(1) and § 139.53(a)(3) all submittals, besides notifications, shall be accomplished through PSIMS*Online, available through <https://www.depgreenport.state.pa.us/ecommm/Login.jsp>, when it becomes available. If internet submittal can not be accomplished, three copies of the submittal shall be sent to the Pennsylvania Department of Environmental Protection, Bureau of Air Quality, Division of Source Testing and Monitoring, 400 Market Street, 12th Floor Rachael Carson State Office Building, Harrisburg, PA 17105-8468 with deadlines verified through document postmarks.

(k) The permittee shall insure all federal reporting requirements contained in the applicable subpart of 40 CFR are followed, including timelines more stringent than those contained herein. In the event of an inconsistency or any conflicting requirements between state and the federal, the most stringent provision, term, condition, method or rule shall be used.

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this plan approval including Section B (Plan Approval General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

004 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

(a) The permittee shall maintain a record of all preventative maintenance inspections of the source. These records shall, at a minimum, contain the dates of the inspections, any problems or defects, the actions taken to correct the problem or defects, and any routine maintenance performed.

(b) The permittee shall maintain a record of the following from the operational inspections:

1. The performance of an operational inspection

005 [25 Pa. Code §127.12b]

Plan approval terms and conditions.

ARG shall maintain a record of the date and time:

(a) The hydrotreater is operating


(b) The LO-CAT unit is operating.

(c) The hydrotreater is shut down

(d) The LO-CAT unit is shut down

The records shall be kept for a period of five years and made available to the Department upon request.

THIS PAGE INTENTIONALLY LEFT BLANK



RECEIVED OCT 13 2008

SCANNED

Pennsylvania Department of Environmental Protection

P.O. Box 8468
Harrisburg, PA 17105-8468
October 3, 2008

Eric W
CC: Jill

717-772-3938

Bureau of Air Quality

Mr. Jason L. Goodling
Environmental Manager
American Refining Group, Inc.
77 North Kendall Avenue
Bradford, PA 16701

Dear Mr. Goodling:

Re: ACCI Project 08-176

On September 25, 2008, the Department received the protocol for the baseline testing to determine the emissions of volatile organic compounds (VOC) from the Lo Cat Desulphurization Unit (ID: 1002) at American Refining Group's refinery in Bradford, McKean County. This protocol is unacceptable to the Department, unless all of the following conditions are met.

- All sample lines must be heated to $375 \pm 25^\circ\text{F}$.
- The instrument shall be calibrated such that the actual pollutant concentrations are approximately 25-75% of the span

Please notify the Regional Office and me at least ten business days prior to testing so that someone may be present to observe. Failure to do so could result in a rejection of the test results. Final acceptance of the test results is contingent upon fulfillment of all of the applicable requirements specified in Title 25, Chapter 139 of the PA Code; Plan Approval 42-00004C; and the Department's Source Testing Manual (Revision 3.3; November 2000). If there are any questions regarding this matter, please contact me at your convenience.

Sincerely,

Rick Szekeres

Rick Szekeres
Environmental Chemist
Source Testing Section
Division of Source Testing and Monitoring

APPENDIX B

Sample Calculations

ACCI SAMPLE CALCULATIONS

THC and Moisture

0
0
0
0
0%

January 0, 1900
Oxidizer Inlet and Outlet

Run 1

Vf	210.0	ml	Tstandard	68	F
Vi	200.0	ml	Pstandard	760	mm Hg
Wf	700.0	g	K1method 4	0.04706	scf/ml
Wi	650.0	g	K2method 4	0.04715	scf/g
	23.275	dacf	K1method 5	17.64	R/in. Hg
	0.000	dry actual liters	K4method 5	0.0945	
Yd	0.9960		V/nstandard	385.3	ft ³ /lb-mole
Pbar	28.64	in. Hg	Kp	85.49	
dHavg	1.70	in. H ₂ O	Ps	0	0
Im	67.0	F	π	3.141593	
O ₂	20.50	% dv	Ds (or L)	14.00	inches
CO ₂	0.00	% dv	Stack Width (W)	NA	inches
Pg	-0.34	in. H ₂ O	Dn	NA	inches
Cp	0.84		Time	60	minutes
(dP) ^{1/2} avg	1.000	in. H ₂ O ^{1/2}	Tsavg	300.0	F
F _d	NA;Fd@68/760=NA	dscf/MMBtu	Product rate	NA	input ton/hr

CEMS DATA

Total Hydrocarbons

Coverage _{THC}	10.00	ppm _{wv}
O ₂ Correction	20.5	% dv
MW Propane	44	lb/lb-mole
MW Carbon	12	lb/lb-mole

1. Volume of Water Vapor Condensed (Vwc)

Vwc(std) = K1method 4 * (Vf - Vi)	
K1method 4 =	0.04706 scf/ml
Vf =	210.0 ml
Vi =	200.0 ml
Vwc(std) =	0.471 scf

2. Volume of Water Vapor Collected in Silica Gel (Vwsg)

Vwsg(std) = K2method 4 * (Wf - Wi)	
K2method 4 =	0.04715 scf/g
Wf =	700.0 g
Wi =	650.0 g
Vwsg(std) =	2.358 scf

3. Total Volume of Water Vapor in Gas Sample (Vw)

Vw(std) = Vwc(std) + Vwsg(std)	
Vwc(std) =	0.471 scf
Vwsg(std) =	2.358 scf
Vw(std) =	2.828 scf

4. Volume of Gas Metered

Vm = Volume metered in dacf + Volume metered in dry actual liters * (1 cf / 28.317 liters)	
Volume metered in dacf =	23.275 dacf
Volume metered in dry actual liters =	0.000 dry actual liters
Vm =	23.275 dacf
Vm(m ³) = Vm * (1 m ³ / 35.3145 cf)	
Vm =	23.275 dacf
Vm(m ³) =	0.659 daem

5. Volume of Gas Metered , dry basis, STD

$$Vm(std) = (KImethod 5 * Vm * Yd * (Pbar + (dHavg/13.6))) / (Tm + 460)$$

$$KImethod 5 = 17.64 \text{ R/in. Hg}$$

$$Vm = 23.275 \text{ dacf}$$

$$Yd = 0.9960$$

$$Pbar = 28.64 \text{ in. Hg}$$

$$dHavg = 1.70 \text{ in. H}_2\text{O}$$

$$Tm = 67.0 \text{ F}$$

$$Vm(std) = 22.320 \text{ dscf}$$

$$Vm(std)m^3 = Vm(std) * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$$Vm(std) = 22.320 \text{ dscf}$$

$$Vm(std)m^3 = 0.632 \text{ dscm}$$

6. Water Vapor in the Gas Stream

$$Bws \text{ used} = \text{the lower of} \quad \frac{SP_{H_2O@T_{avg}}}{Ps} \quad \text{and} \quad \frac{Vw(std)}{(Vm(std) + Vw(std))}$$

$$Bws = \frac{SP_{H_2O@T_{avg}}}{Ps} \quad \text{With a maximum allowable value of 1.0}$$

$$SP_{H_2O@T_{avg}} = \text{The saturation pressure of water at stack temperature}$$

$$1997 \text{ ASHRAE Handbook page 6.2 Eq. (6)}$$

$$\text{EXP}(C8/T + C9 + C10 * T + C11 * T^2 + C12 * T^3 + C13 * \ln(T)) * (29.921/14.696)$$

$$T = T_{avg} + 459.67$$

$$T_{avg} = 300.0 \text{ F}$$

$$T = 759.7 \text{ R}$$

$$C8 = -1.044040\text{E}+04$$

$$C9 = -1.1294650\text{E}+01$$

$$C10 = -2.702236\text{E}-02$$

$$C11 = 1.289036\text{E}-05$$

$$C12 = -2.478068\text{E}-09$$

$$C13 = 6.545967\text{E}+00$$

$$SP_{H_2O@T_{avg}} = 136.48 \text{ in. Hg}$$

$$Ps = 28.62 \text{ in. Hg}$$

$$Bws = 1.0000 \text{ vol. fraction}$$

$$Bws = \frac{Vw(std)}{(Vm(std) + Vw(std))}$$

$$Vw(std) = 2.828 \text{ scf}$$

$$Vm(std) = 22.320 \text{ dscf}$$

$$Bws = 0.1125 \text{ vol. fraction}$$

$$Bws \text{ used} = 0.1125 \text{ vol. fraction}$$

7. Carbon Monoxide and Nitrogen in gas

$$CO + N_2 = 100 - (CO_2 + O_2)$$

$$CO_2 = 0.00 \% \text{ dv}$$

$$O_2 = 20.50 \% \text{ dv}$$

$$CO + N_2 = 79.50 \% \text{ dv}$$

8. Molecular weight of dry gas stream

$$Md = 0.44 * CO_2 \% \text{ dv} + 0.32 * O_2 \% \text{ dv} + 0.28 * (CO + N_2 \% \text{ dv})$$

$$CO_2 = 0.00 \% \text{ dv}$$

$$O_2 = 20.50 \% \text{ dv}$$

$$CO + N_2 = 79.50 \% \text{ dv}$$

$$Md = 28.82 \text{ lb/lb-mole}$$

9. Molecular weight of wet gas stream

$$Ms = Md * (1 - Bws) + 18 * Bws$$

$$Md = 28.82 \text{ lb/lb-mole}$$

$$Bws = 0.1125 \text{ vol. fraction}$$

$$Ms = 27.60 \text{ lb/lb-mole}$$

10 Stack Pressure

$$P_s = P_{bar} + P_g / 13.6$$

$P_{bar} =$	28.64 in. Hg
$P_g =$	-0.34 in. H ₂ O
$P_s =$	28.62 in. Hg

11. Average Stack Gas Velocity

$$V_s = K_p * C_p * (dP)^{1/2}_{avg} * ((T_{savg} + 460) / (P_s * M_s))^{1/2}$$

$K_p =$	85.49
$C_p =$	0.84
$(dP)^{1/2}_{avg} =$	1.0000 in. H ₂ O ^{1/2}
$T_{savg} =$	300.0 F
$P_s =$	28.62 in. Hg
$M_s =$	27.60 lb/lb-mole
$V_s =$	70.44 ft/s

12. Area of the Stack

If $W = 0$, the stack is circular.

Circular

$$A_s = \pi * (D_s)^2 / 4 * (1 \text{ ft} / 12 \text{ in})^2$$

$\pi =$	3.141593
$D_s =$	14.00 inches
$A_s =$	1.07 ft ²

Rectangular

$$A_s = L * W * (1 \text{ ft} / 12 \text{ in})^2$$

$L =$	0.00 inches
$W =$	NA inches
$A_s =$	0.00 ft ²

13 Stack Gas Flow Rate, Actual

$$Q_{acfm} = V_s * A_s * 60$$

$V_s =$	70.44 ft/s
$A_s =$	1.07 ft ²
$Q_{acfm} =$	4,518 acfm

$$Q_{acm/min} = Q_{acfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{acfm} =$	4,518 acfm
$Q_{acm/min} =$	128 acm/min

14 Stack Gas Flow Rate, Standard

$$Q_{scfm} = Q_{acfm} * ((T_{standard} + 460) / (T_{savg} + 460)) * (P_s / P_{standard})$$

$Q_{acfm} =$	4,518 acfm
$T_{standard} =$	68 F
$T_{savg} =$	300.0 F
$P_s =$	28.62 in. Hg
$P_{standard} =$	29.92 in. Hg
$Q_{scfm} =$	3,002 scfm

$$Q_{scm/min} = Q_{scfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{scfm} =$	3,002 scfm
$Q_{scm/min} =$	85.0 scm/min

15 Stack Gas Flow Rate, Dry Standard

$$Q_{dscfm} = Q_{scfm} * (1 - B_{ws})$$

$Q_{scfm} =$	3,002 scfm
$B_{ws} =$	0.1125 vol. fraction
$Q_{dscfm} =$	2,664 dscfm

$$Q_{dscm/min} = Q_{dscfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{dscfm} =$	2,664 dscfm
$Q_{dscm/min} =$	75.4 dscm/min

16 Total Hydrocarbons (THC) as Propane Emission Concentration (ppmdv) (OUTLET)

THC as Propane	10.00 ppm _{wv}
Bws	0.1125 vol. fraction
THC as Propane	11.27 ppm _{dv}

17 USEPA Method 18 Concentrations (OUTLET)

Methane	6.00 ppm _{dv}
Ethane	3.00 ppm _{dv}
M + E as Propane	4.00 ppm _{dv}

18 Non-Methane, Non-Ethane Emission Concentration (as Propane) (Outlet)

NMEVOC as C ₃ H ₈ = THC (C ₃ H ₈) - USEPA (M+E, as propane)	
THC (as C ₃ H ₈) =	11.27 ppm _{dv}
M + E as Methane	4.00 ppm _{dv}
NMEVOC as C ₃ H ₈ =	7.3 ppm _{dv}

19 NMEVOC Emission Rate (lb/hr), (OUTLET, as propane)

$\text{NMEVOC (lb/hr)} = \text{NMEVOC} / 1,000,000 * Q_{\text{dscfm}} * (60 \text{ min} / 1 \text{ hour}) / V/n_{\text{standard}} * \text{Carbon}_{\text{MW}}$	
NMEVOC (as Propane) =	7.267 ppm _{dv}
Q _{dscfm}	2.664.4 dscfm
V/n _{standard}	385.3 ft ³ /lb-mole
MW Propane	44 lb/lb-mole
NMEVOC (lb/hr)	0.1327 lb/hr

20 NMEVOC Emission Rate (lb/day), (OUTLET)

$\text{NMEVOC (lb/day)} = \text{NMEVOC (lb/hr)} * \text{Operating Rate (hr/day)}$	
NMEVOC (lb/hr)	0.1327 lb/hr
Operating Rate	1.61 hr/day
NMEVOC (lb/day)	0.214 lb/day

THIS PAGE INTENTIONALLY LEFT BLANK

ACCI SAMPLE CALCULATIONS
USEPA Method 25HC and Moisture

Company Name
Project No.
Facility Location
Process Line
Normal
Test Date
Main Exhaust

Run 1

Vf	208 0	ml	Tstandard	68	F
Vi	200 0	ml	Pstandard	760	mm Hg
Wf	254 8	g	K1method 4	0 04707	scf/ml
Wi	248 3	g	K2method 4	0 04715	scf/g
	23 460	dacf	K1method 5	17 64	R/in Hg
	0 000	dry actual liters	K4method 5	0 0945	
Yd	1 0010		V/nstandard	385 3	ft ³ /lb-mole
Pbar	29 30	in. Hg	Kp	85 49	
dHavg	1 70	in. H ₂ O	pa	0	0
Tm	74 8	F	π	3 141593	
O ₂	18 00	% dv	Ds (or L)	24 00	inches
CO ₂	1 50	% dv	Stack Width (W)	NA	inches
Pg	-0 56	in. H ₂ O	Dn	NA	inches
Cp	0 84		Time	60	minutes
(dP) ^{1/2} avg	0 703	in. H ₂ O ^{1/2}	Tsavg	703 2	F
Fd	NA;Fd@68/760=NA	dscf/MMBtu	Product rate	NA	input ton/hr

1 Volume of Water Vapor Condensed (Vwc)

$$Vwc(std) = K1method\ 4 * (Vf - Vi)$$

$$K1method\ 4 = 0\ 04707\ scf/g$$

$$Vf = 208\ 0\ ml$$

$$Vi = 200\ 0\ g$$

$$Vwc(std) = 0\ 377\ scf$$

2 Volume of Water Vapor Collected in Silica Gel (Vwsg)

$$Vwsg(std) = K2method\ 4 * (Wf - Wi)$$

$$K2method\ 4 = 0\ 04715\ R/in\ Hg$$

$$Wf = 254\ 8\ g$$

$$Wi = 248\ 3\ dacf$$

$$Vwsg(std) = 0\ 306\ scf$$

3 Total Volume of Water Vapor in Gas Sample (Vw)

$$Vw(std) = Vwc(std) + Vwsg(std)$$

$$Vwc(std) = 0\ 377\ scf$$

$$Vwsg(std) = 0\ 306\ scf$$

$$Vw(std) = 0\ 683\ scf$$

4 Volume of Gas Metered

$$Vm = \text{Volume metered in dacf} + \text{Volume metered in dry actual liters} * (1\ cf / 28\ 317\ liters)$$

$$\text{Volume metered in dacf} = 23\ 460\ dacf$$

$$\text{Volume metered in dry ac} = 0\ 000\ dry\ actual\ liters$$

$$Vm = 23\ 460\ dacf$$

$$Vm(m3) = Vm * (1\ m3 / 35\ 3145\ cf)$$

$$Vm = 23\ 460\ dacf$$

$$Vm(m3) = 0\ 664\ dactm$$

5 Volume of Gas Metered , dry basis, STD

$Vm(std) = (KImethod\ 5 * Vm * Yd * (Pbar + (dHavg/13.6))) / (Tm + 460)$
 $KImethod\ 5 = 17.64$ 0.00
 $Vm = 23.460$ dscf
 $Yd = 1.0010$
 $Pbar = 29.30$ in H₂O
 $dHavg = 1.70$ %dv
 $Tm = 74.8$ F
 $Vm(std) = 22.794$ dscf

 $Vm(std)m3 = Vm(std) * (1\ m3 / 35.3145\ cf)$
 $Vm(std) = 22.794$ dscf
 $Vm(std)m3 = 0.645$ dscm

6 Water Vapor in the Gas Stream

$Bws\ used = \text{the lower of}$
 $SPH2O@T_{savg} / Ps$
 $\text{and } Vw(std) / (Vm(std) + Vw(std))$

$Bws = SPH2O@T_{savg} / Ps$ With a maximum allowable value of 1.0
 $SPH2O@T_{savg} =$ The saturation pressure of water at stack temperature
 1997 ASHRAE Handbook page 6.2 Eq. (6)
 $EXP(C8/T + C9 + C10 * T + C11 * T^2 + C12 * T^3 + C13 * \ln(T)) * (29.921/14.696)$

$T = T_{savg} + 459.67$
 $T_{savg} = 703.2$ F
 $T = 1162.9$ R
 $C8 = -1.044040E+04$
 $C9 = -1.1294650E+01$
 $C10 = -2.702236E-02$
 $C11 = 1.289036E-05$
 $C12 = -2.478068E-09$
 $C13 = 6.545967E+00$
 $SPH2O@T_{savg} = 6340.59$ in. Hg
 $Ps = 29.26$ in. Hg
 $Bws = 1.0000$ vol fraction

$Bws = Vw(std) / (Vm(std) + Vw(std))$
 $Vw(std) = 0.683$ scf
 $Vm(std) = 22.794$ dscf
 $Bws = 0.0291$ vol fraction

$Bws\ used = 0.0291$ vol fraction

7 Carbon Monoxide and Nitrogen in gas

$CO + N2 = 100 - (CO2 + O2)$
 $CO2 = 1.50$ %dv
 $O2 = 18.00$ %dv
 $CO + N2 = 80.50$ %dv

8 Molecular weight of dry gas stream

$Md = 0.44 * CO2\ \%dv + 0.32 * O2\ \%dv + 0.28 * (CO + N2\ \%dv)$
 $CO2 = 1.50$ in. H₂O
 $O2 = 18.00$ %dv
 $CO + N2 = 80.50$ %dv
 $Md = 28.96$ lb/lb-mole

9 Molecular weight of wet gas stream

$Ms = Md * (1 - Bws) + 18 * Bws$
 $Md = 28.96$ lb/lb-mole
 $Bws = 0.0291$ vol fraction
 $Ms = 28.64$ lb/lb-mole

10 Stack Pressure

$$P_s = P_{bar} + P_g / 13.6$$

$P_{bar} =$	29.30 in H ₂ O
$P_g =$	-0.56 in H ₂ O
$P_s =$	29.26 in Hg

11 Average Stack Gas Velocity

$$V_s = K_p \cdot C_p \cdot (dP)^{1/2} / \text{avg} \cdot ((T_{savg} + 460) / (P_s \cdot M_s))^{1/2}$$

$K_p =$	85.49
$C_p =$	0.84
$(dP)^{1/2} / \text{avg} =$	0.7033 in. H ₂ O ^{1/2}
$T_{savg} =$	703.2 F
$P_s =$	29.26 in. Hg
$M_s =$	28.64 lb/lb-mole
$V_s =$	59.50 ft/s

12 Area of the Stack

If $W = 0$, the stack is circular

Circular

$$A_s = P_1 \cdot (D_s)^2 / 4 \cdot (1 \text{ ft} / 12 \text{ in.})^2$$

$P_1 =$	3.141593
$D_s =$	24.00 inches
$A_s =$	3.14 ft ²

Rectangular

$$A_s = L \cdot W \cdot (1 \text{ ft} / 12 \text{ in.})^2$$

$L =$	0.00 inches
$W =$	NA inches
$A_s =$	0.00 ft ²

13 Stack Gas Flow Rate, Actual

$$Q_{acfm} = V_s \cdot A_s \cdot 60$$

$V_s =$	59.50 ft/s
$A_s =$	3.14 ft ²
$Q_{acfm} =$	11,216 acfm

$$Q_{acm/min} = Q_{acfm} \cdot (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{acfm} =$	11,216 acfm
$Q_{acm/min} =$	318 acm/min

14 Stack Gas Flow Rate, Standard

$$Q_{scfm} = Q_{acfm} \cdot ((T_{standard} + 460) / (T_{savg} + 460)) \cdot (P_s / P_{standard})$$

$Q_{acfm} =$	11,216 acfm
$T_{standard} =$	68 F
$T_{savg} =$	703.2 F
$P_s =$	29.26 in. Hg
$P_{standard} =$	29.92 in. Hg
$Q_{scfm} =$	4,979 scfm

$$Q_{scm/min} = Q_{scfm} \cdot (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{scfm} =$	4,979 scfm
$Q_{scm/min} =$	141.0 scm/min

15 Stack Gas Flow Rate, Dry Standard

$$Q_{dscfm} = Q_{scfm} \cdot (1 - B_{ws})$$

$Q_{scfm} =$	4,979 scfm
$B_{ws} =$	0.0291 vol fraction
$Q_{dscfm} =$	4,834 dscfm

$$Q_{dscm/min} = Q_{dscfm} \cdot (1 \text{ m}^3 / 35.3145 \text{ cf})$$

$Q_{dscfm} =$	4,834 dscfm
$Q_{dscm/min} =$	136.9 dscm/min

16 Total Gaseous Non-methane, Organic Compounds (TGNMOCs) as Carbon Emission Concentration (ppmdv) (Exhaust)

TGNMOCs as Carbon	56.00 ppmdv
-------------------	-------------

17 TGNMOCs Emission Rate (lb/hr)

TGNMOCs(lb/hr) = TGNMOCs / 1,000,000 * Qdscfm * (60 min / 1 hour) / V/nstandard * CarbonMW	
V/nstandard	385.3 ft ³ /lb-mole
MW Carbon	12 lb/lb-mole
TGNMOCs outlet	56.000 ppmdv
Qdscfm	4834.0 dscfm
TGNMOCs (lb/hr)	0.5059 lb/hr

18 Destruction Efficiency (lb/hr basis)

DE = (TGNMOCs lb/hr inlets - TGNMOCs lb/hr outlet) / TGNMOCs lb/hr inlets

TGNMOCs Hot Inlet	57.034 lb/hr
TGNMOCs Cold Inlet	11.25 lb/hr
TGNMOCs Main Ex.	0.5059 lb/hr

DE	0.9926
DE	99.26%

This page intentionally left blank

ACCI SAMPLE CALCULATIONS **H2S**

CEMS	8.48 ppm _v	n	9
Rm _{av}	8.10 ppm _v	t-value	2.306 (40 CFR 75, Appendix A, Table 7-1)
RMstd	161 ppm _v	n-1	8
d	-0.382	Mw H2S	34.07 g/g-mole

1. Standard Deviation

$$Sd = [(\sum di^2 - (\sum di)^2/n)/(n-1)]^{1/2} \quad (40 \text{ CFR } 75, \text{ Appendix A, Eq. A-8})$$

Run	di	i ²
1	-1.66	2.75
2	-1.38	1.90
3	-0.61	0.37
4	0.22	0.05
5	0.79	0.63
6	-0.74	0.54
7	-1.23	1.52
8	1.64	2.68
9	-0.48	0.23
10	-4.21	17.69

Sum/Total of Runs Used	-3.44
* indicates run used in calculations	
Sum of Runs Used $\sum di^2$	10.66
Sum of Runs Used $(\sum di)^2$	11.84
Sd=	1.081

2. Confidence Coefficient

(40 CFR 75, Appendix A, Eq. A-9)

Cc = t-value*(S _d /n ^{1/2})	
t-value	2.306 (40 CFR 75, Appendix A, Table 7-1)
n	9
Sd	1.081
Cc	0.830684347

3. Relative Accuracy to Reference Method

(40 CFR 75, Appendix A, Eq. A-10)

$$RA = \frac{[|d| + |Cc|]}{RM_{av}} * 100\%$$

d	0.382343964
Cc	0.830684347
RM _{av}	8.10

RA = 0.14979993

RA = 14.98%

4. Relative Accuracy to Applicable Standard

$$RA = \frac{[|d| + |Cc|]}{RM_{std}} * 100\%$$

d	0.382343964
Cc	0.830684347
RM _{std}	161

RA = 0.007534337

RA = 0.75%

5. Volume Metered Standardized

$$Vm_{std} = Vm * Yd * [(T_{std} * Pbar)/(Tm * Pstd)]$$

Vm = 29.94 L

Yd = 0.999

T_{std} = 293.15 °K

Pbar = 732.03 mm. Hg

T_m = 284.65 °K

Pstd = 760 mm. Hg

Vm_{std} = 29.67

6. H₂S Concentration

$$CH_2S = 17040 * [(V_{IT} * N_I - V_{IT} * N_T)_{sample} - (V_{IT} * N_I - V_{IT} * N_T)_{blank}] / Vm_{std}$$

Sample

Blank

V_{IT} = 50.00 ml

V_{IT} = 50.00 ml

N_I = 0.01 g-eq/liter

N_I = 0.01 g-eq/liter

V_{IT} = 48.62 ml

V_{IT} = 49.99 ml

N_T = 0.01 g-eq/liter

N_T = 0.01 g-eq/liter

CH₂S = 7.87

CH₂S = CH₂S * [24.04/34.07]

CH₂S = 5.55

APPENDIX C

Example Field Data Sheets

AIR/COMPLIANCE CONSULTANTS, INC.
USEPA METHOD 2 AND METHOD 4 DATA SHEET

Client	_____	Date	_____
ACCI Project #	_____	Run #	_____
Plant Location	_____	Meter Box #	_____
Stack ID	_____	Yd	_____
Stack Diameter	_____	Delta H	_____
Pitot ID	_____	Test Crew:	_____
Pitot Cp	_____	Pre-Test Leak Check	<div style="background-color: #cccccc; width: 100px; height: 1.2em;"></div>
B P (in Hg)	_____	Impingers	_____
Ps (in. H ₂ O)	_____	Pitot (+/-)	_____ _____
Start Time:	_____	Post-Test Leak Check	<div style="background-color: #cccccc; width: 100px; height: 1.2em;"></div>
Stop Time:	_____	Impingers	_____
Fyrite Kit#:	_____	Pitot (+/-)	_____ _____

Stack Dia. Measured?

DIAGRAM

MOISTURE DATA

Clock	Elapsed	Meter Volume	Meter Temp	Delta H	Vacuum/ Pressure	Impinger Temp.
	Initial					
	5 Min					
	10 Min					
	15 Min					
	20 Min					
	25 Min					
	30 Min					
	35 Min					
	Final					

IMPINGER WEIGHTS

Impinger	Initial	Final
1		
2		
3		
4		
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %

start:

stop:

[illegible]

start:

stop:

[illegible]

AIR/COMPLIANCE CONSULTANTS, INC.
USEPA METHOD 25A HEATING COMPONENT DATA SHEET

Client _____
 Project Number _____
 Plant Location _____
 Sample Location _____

Start Time _____
 Stop Time _____
 Date _____
 Run Number _____
 Test Crew _____

HEATING COMPONENT	TEMP @ 15 MIN (°F)	TEMP @ 30 MIN (°F)	TEMP @ 45 MIN (°F)	TEMP @ 60 MIN (°F)

ACCI CEM Verification of Gas Dilution System for Field Instrument Calibrations
Based on EN14103-205

Client	Date
Project No	Location
Plant	Series No.
Unit	S/N
Operation	Last Calibration
Tester(s)	Next Calibration

Mass Flow Controller
Component of Protocol Calibration Gas Used
Concentration of Protocol Gas Used


Section 3.2.3 Prepared Dilutions	Section 3.2.4 Difference from Single Injection and the Average Instrument Response	Section 3.2.5 Difference from Average Output Concentration and the Predicted Concentration
Predicted Concentration 1	Analyzer Output	
Instrument Response 1	#DIV/0!	#DIV/0!
Instrument Response 2	#DIV/0!	#DIV/0!
Instrument Response 3	#DIV/0!	#DIV/0!
Average Response	+/- 2 % Allowable	+/- 2 % Allowable

Predicted Concentration 2		
Instrument Response 1	#DIV/0!	#DIV/0!
Instrument Response 2	#DIV/0!	#DIV/0!
Instrument Response 3	#DIV/0!	#DIV/0!
Average Response	#DIV/0!	+/- 2 % Allowable

Section 3.2.6 Mid-Level Supply Gas	Analyzer Output	Difference between Protocol Concentration and Average Instrument Response
Mid-Level Gas Concentration		
Instrument Response 1		#DIV/0!
Instrument Response 2		#DIV/0!
Instrument Response 3		#DIV/0!
Average Response	#DIV/0!	+/- 2 % Allowable

Air/Compliance Consultants, Inc. (ACCI)

Standard Pitot Tube Inspection Data Sheet



Allowable Range/Parameter	Value
Obstruction?	Y <input type="checkbox"/> N <input type="checkbox"/>
Damaged?	Y <input type="checkbox"/> N <input type="checkbox"/>
θ 90° Bend	Y <input type="checkbox"/> N <input type="checkbox"/>
D_T inside diameter	"
Static Holes – 0.1 of D_T	"
Static Holes – equally spaced in a piezometer ring	Y <input type="checkbox"/> N <input type="checkbox"/>
$A = \geq 6 \times D_T$	"
$B = \geq 8 \times D_T$	"

Certification:

I certify that the Standard Pitot Tube/Probe ID# _____ meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a Pitot tube calibration factor C_p of 0.99 ± 0.01 .

Checked by: _____
(Signature / Date)

Air/Compliance Consultants, Inc. (ACCI)

Thermocouple Calibration Data Sheet

Probe I.D.: _____

Dry Gas Meter I.D.: _____

Standard Used: Mercury Thermometer

Temperature Scale: °F

Converted to: °R (Equation= 460 + °F result)

Post Test

Temperature Range	Reference Thermometer (°R)	Probe Thermometer (°R)	Absolute Temperature Difference
Ice Bath			
Room Temp.			
Hot Bath			

Criteria are:

Hot Bath Value within 10% of the average stack temperature measured.

The absolute temperature Difference within 1.5% of Reference Standard used.

Section 10.3.1 of USEPA Method 2

Checked by: _____
(Signature / Date)

Client _____	Date _____	Run # _____
ACCI Project # _____		
Plant Location _____		
Stack ID _____		
Pre-Test Leak Check _____		Post-Test Leak Check _____
Barometric Pressure (in. Hg) _____		
Start Time: _____		Stop Time: _____
Test Crew _____		
Meter Box ID _____	Y _d _____	ΔH _(g) _____
Meter Volume _____	Initial _____	Final _____
Dry Gas Meter Temp _____	Initial _____	Final _____
Delta H/Vacuum _____	Initial _____	Final _____

ANALYSIS

	<u>Sample</u>	<u>Blank</u>
<u>Sample</u>		
Volume of I ₂ Solution Used (V _{IT})	_____ ml	_____ ml
Normality of I ₂ Solution (N _I)	_____ g-eq/liter	_____ g-eq/liter
Volume of Na ₂ S ₂ O ₃ Solution (V _{TT})		
Initial Vol	_____ ml	_____ ml
Final Vol	_____ ml	_____ ml
Amount Used	_____ ml	_____ ml
Normality of Na ₂ S ₂ O ₃ Solution (N _T)	_____ g-eq/liter	_____ g-eq/liter

METER VOLUME (STANDARD)

$$V_{M(std)} = V_m Y_d \frac{T_{std} P_{bar}}{T_m P_{std}}$$

$$T_{std} = 70^{\circ}F = 573.15 K$$

$$P_{std} = 760 \text{ mmHg}$$

H₂S CONCENTRATION

$$C_{H_2S} = 17.04 \times 10^3 \frac{(V_{II} N_I - V_{IT} N_T)_{sample} - (V_{II} N_I - V_{IT} N_T)_{blank}}{V_{m(std)}}$$

$$C_{H_2S} = C_{H_2S} * \frac{24.45}{34.07}$$



Facility: _____ Project No: _____ Date: _____
 City/State: _____ Run No.: _____
 Sample Location: _____ Operator: _____
 Pressure/Temp: _____ Pressure/Temp: _____

[illegible]

Facility: _____ Project No: _____ Date: _____

City/State: _____ Run No.: _____

Sample Location: _____ Operator: _____

Tank No: _____ Trap No: _____ Sample ID: _____

Tank Vacuum mmHG cmHG	Barometric Pressure mm HG	Ambient Temperature °F
Pretest (Manometer) _____		
Post-test (Manometer) _____		

Leak Rate: mmHG/1.0 min.

Pretest:

$$P = 0.01(FP_b/N_t)$$

P = Allowable pressure change, cm Hg.

P_b = Barometric pressure, cm Hg.

F = Sampling flow rate, cc/min

V_1 = Sample train volume, cc

[illegible]



Analysis Request / Chain of Custody Form

Please Print Neatly

Page ____ of ____

1 Client Name		Project No.	
Project Location		Project Manager (PM)	
PM Email		PO #	
Laboratory		Lab Contact / Phone #	
Sample Identification 2		Date Collected	Time Collected
Air		Composite 3	
Total # of Containers		Relinquished by:	
Containers		Relinquished by:	
Matrix 4		Relinquished by:	
Analysis Requested 5		Relinquished by:	
Remarks 6		Relinquished by:	
Temperature of samples upon receipt (if requested)		Relinquished by:	

7 Turnaround Time Requested (TAT)

Please indicate: Normal Rush

Data results are needed:

If rush results requested please fax to:

Fax #

8 Notes:

Please call (412) 826-3636 if there are any questions prior to proceeding. Please cc slinquis@air-comp.com with all laboratory results

9 Project Manager Approval (Print & Sign)

PM Sign: _____

PM Print: _____

COC completed by (initial): _____ Date: _____

WHITE - FILE • YELLOW - PM • PINK - LAB

Nº 1500

Instructions on reverse side
correspond with circled numbers

This page intentionally left blank



RECEIVED NOV 02 2009

Pennsylvania Department of Environmental Protection

P.O. Box 8468
Harrisburg, PA 17105-8468
October 26, 2009

ERIC
cc: Jill

717-772-3938

Bureau of Air Quality

Mr. Jason L. Goodling
Environmental Manager
American Refining Group, Inc.
77 North Kendall Avenue
Bradford, PA 16701

Dear Mr. Goodling:

Re: ACCI Project 09-160

On October 20, 2009, the Department received the protocol for the baseline testing to determine the emissions of hydrogen sulfide (H_2S) and volatile organic compounds (VOC) from the absorber (ID: C1001) and oxidizer (ID: C1001A) sections of the Lo Cat Desulfurization Unit, used to control the sulfur emissions from the Hydrotreater Unit (ID: 1001) at American Refining Group's refinery in Bradford, McKean County. This protocol is acceptable to the Department.

Final acceptance of the test results is contingent upon fulfillment of all of the applicable requirements specified in Title 25, Chapter 139 of the PA Code; Plan Approval 42-00004E; and the Department's Source Testing Manual (Revision 3.3; November 2000). If there are any questions regarding this matter, please contact me at your convenience.

Sincerely,

Rick Szekeres
Environmental Chemist
Source Testing Section
Division of Source Testing and Monitoring



This page intentionally left blank

Eric White

From: Szekeres, Richard [rszekeres@state.pa.us]
Sent: Friday, November 12, 2010 10:31 AM
To: Eric White
Cc: Bill Stanziana; Jason Goodling; Jill Merrill; Rob Frey
Subject: RE: ARG LO-CAT Desulfurization Unit Baseline testing
Importance: High

All proposed changes are acceptable.

Rick Szekeres, M.S. | Source Testing Section
Department of Environmental Protection
Rachel Carson State Office Building
400 Market Street | Harrisburg, PA 17101
Phone: 717.772.3938 | Fax: 717.772.2303
www.depweb.state.pa.us

-----Original Message-----

From: Eric White [mailto:EWhite@air-comp.com]
Sent: Thursday, November 11, 2010 10:49 AM
To: Szekeres, Richard
Cc: Bill Stanziana; Jason Goodling; Jill Merrill; Rob Frey
Subject: ARG LO-CAT Desulfurization Unit Baseline testing

Rick,

We have set a tentative date for the American Refining Group's, LO-CAT testing. Mr. Jason Goodling will confirm the following through formal notification; testing will commence on December 8th for THC's (M25; M18) and possibly Hydrogen Sulfide (H2S; M-11) testing. The 9th would be utilized as a contingency day to complete the H2S testing.

I reviewed the September 2009 protocol that was accepted on October 26, 2009.

The only slight deviations from the protocol will be:

- The use of an "S" type pitot instead of the proposed standard pitot. This is due to the port length on the unit and the inability to insert said pitot tube. This was per a previous discussion between you and I.
- We proposed to perform M25A analysis to determine whether M25A or M25 would be used. Previous data showed levels above the 50ppm as carbon; M25 specifications and not M25A. We will be performing the M25 only for total hydrocarbons.
- Ethane and Methane analysis would be via M18 bag sampling as stated in the protocol. No M25 separate Ethane analysis is required.
- Oxygen and Carbon Dioxide results were proposed as M3A, on site analysis. We will have the analysis run via 3C from the M25 samples or 3A from the M18 samples.

I hope to hear only good responses to this E-mail, (I will keep my fingers crossed on that one).

Feel free to contact me at any of the listings below.

Thanks,

APPENDIX B

ACCI Field Data Sheets

M25 Volatile Organic Compounds

SAMPLE DATA

Triangle Environmental Services, Inc.

Company Name: <u>American Refining Group / LO-CAT</u>			Date:	
Units of Measure:	Pressure: <input type="checkbox"/> mm Hg <input checked="" type="checkbox"/> in.Hg		Temperature: <input checked="" type="checkbox"/> °F <input type="checkbox"/> °C	
Sample # <u>Run 2</u>	Tank ID # <u>114</u>		Trap ID # <u>ALX</u>	
Description (20 character limit)	<u>R.U.N T W O A R G L O C A T</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
12-6-10 Pre-Test Data	<u>29.08</u>	<u>29.00</u>		<u>70</u>
12-8-10 Post-Test Data	<u>28.50</u>	<u>8.00</u>		<u>20</u>
Sample # <u>Run 3</u>	Tank ID # <u>251</u>		Trap ID # <u>AET</u>	
Description (20 character limit)	<u>R u n T h r e e A R G L O C A T</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
12-6-10 Pre-Test Data	<u>29.08</u>	<u>29.00</u>		<u>70</u>
12-8-10 Post-Test Data	<u>28.50</u>	<u>7.5</u>		<u>18</u>
Sample #	Tank ID # <u>106</u>		Trap ID #	
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
2-6-10 Pre-Test Data	<u>29.08</u>	<u>29.00</u>		<u>70</u>
Post-Test Data				
Sample # <u>Run 1</u>	Tank ID # <u>259</u>		Trap ID # <u>BRT</u>	
Description (20 character limit)	<u>R u n O N E A R G L O C A T</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
12-6-10 Pre-Test Data	<u>29.08</u>	<u>29.00</u>		<u>70</u>
12-8-10 Post-Test Data	<u>28.52</u>	<u>7.50</u>		<u>20</u>
Sample #	Tank ID #		Trap ID #	
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data				
Post-Test Data				
Sample #	Tank ID #		Trap ID #	
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data				
Post-Test Data				

Triangle Environmental Services, Inc.

LABORATORY SAMPLE INFORMATION AND CHAIN-OF-CUSTODY FORM

Company Name: <u>Air Compliance Consultants, Inc.</u>		Project/Client ID: <u>ARB LO-CAT 09-160</u>		Date: <u>12-9-10</u>
Contact Person: <u>Eric S. White</u>		Phone #: <u>1-412-826-3636</u>		Process Type: <u>DeSulfurization</u>
Latest Date Complete Set of Samples Expected at Lab: <u>12-13-10</u>		Note: Normal Turnaround is 15 working days after receipt of complete set of samples		Extra charge will apply for rush results
Send Report to:		Results Due Date: <u>Normal</u>		Report Package Due Date: <u>Normal</u>
Person <u>Eric S. White</u>		Person <u>Jen Hartman</u>		
Company <u>Air Compliance Consultants, Inc.</u>		Company <u>Same as Report address</u>		
Address <u>1050 William Pitt Way</u>		Address		
<u>Pittsburgh, Pa 15238</u>				
Phone # <u>412-826-3636</u>		FAX # <u>412-826-3640</u>		PO#

Analysis

✓ all applicable boxes

US EPA: <input checked="" type="checkbox"/> Method 25	<input type="checkbox"/> Method 3-C	<input type="checkbox"/> Method 25-C (NMOC as C default)	<input type="checkbox"/> Method 10-B	SCAQMD: <input type="checkbox"/> Method 25.1	<input type="checkbox"/> Method 25.2
# of Tank & Trap Samples: <u>6</u>	# of Tank-Only Samples: <u>3</u>	# of Trap-Only Samples: <u>3</u>	# of Bag Samples: <u>0</u>		
<input type="checkbox"/> Audit with Delay (extra charge)	<input type="checkbox"/> Rush Turnaround (extra charge)	<input checked="" type="checkbox"/> High Concentrations Possible	<input type="checkbox"/> Call if Concentrations High	<input type="checkbox"/> Dilute High Concentrations (extra charge)	

Special Instructions:

Tanks for Analysis (Bags) (List IDs): <u>114, 251, 259</u>	Traps for Analysis (List IDs): <u>ALX, AET, BBT</u>
--	---

<input checked="" type="checkbox"/> TES Equipment	<input type="checkbox"/> Client Equipment	<input type="checkbox"/> Client Equipment to be Reconditioned
Tanks, Unused for Reconditioning (List IDs): <u>106</u>		Traps, Unused for Reconditioning (List IDs): <u>ATD</u>

Relinquished by: <u>[Signature]</u>	Date: <u>12-9-10</u>	Time: <u>12:10</u>	To: <u>UPS</u>
Tanks received at TES by:	Condition:	Date:	Time:



Date: 12-6-10

Run No.: 24 hr | 1st ✓

Operator: εu

Pressure/Temp: 28.40 24°f

[illegible]

Facility: ARG

 Project No: 09-160

 Date: 12-8-10

 City/State: Bradford, PA

 Run No.: ~~001~~ ONE

 Sample Location: LO-CAT Exhaust

 Operator: ESW

 Tank No: 259

 Trap No: BB7

 Sample ID: AmONE

Tank Vacuum mmHG	Barometric Pressure mm-HG	Ambient Temperature °F
Pretest (Manometer) <u>28.00</u> <u>HG"</u>	<u>28.52</u> <u>HG"</u>	<u>20</u>
Post-test (Manometer) <u>7.50</u>	<u>28.52</u>	<u>20</u>

 Leak Rate: mmHG/1.0 min.
 $P = 0.01(FP_b/V_t)$

P = Allowable pressure change, cm Hg.

 P_b = Barometric pressure, cm Hg.

F = Sampling flow rate, cc/min

 V_t = Sample train volume, cc

 Pretest: 0.0 in 10 min
10 min Pass

Time	Vacuum	Flowmeter Settings	Probe	Filter	Comments
7:57	28.00	100	130	123	
8:02	25.00	100	129	122	
8:07	24.00	100	133	122	
8:12	23.00	100	132	122	
8:17	21.50	100	133	129	
8:22	20.00	100	133	128	
8:27	18.50	100	132	127	
8:32	17.00	100	133	126	
8:37	15.50	100	134	125	
8:42	13.00	100	134	122	
8:47	11.00	100	132	123	
8:52	9.00	100	135	123	
8:57	7.50	100	131	123	

Facility: ARG

Project No: 09-160

Date: 12-8-10

City/State: Bradford, PA

Run No.: Two

Sample Location: LO-CAT Exhaust

Operator: ESW

Tank No: 114

Trap No: ALX

Sample ID: Rin Two

Tank Vacuum mmHG	Barometric Pressure mm HG	Ambient Temperature °F
Pretest (Manometer) <u>28.00</u>	<u>28.52</u>	<u>20</u>
Post-test (Manometer) <u>8.00</u>	<u>28.50</u>	<u>18</u>

Leak Rate: mmHG/1.0 min.
 $P = 0.01(FP_b/V_t)$

P = Allowable pressure change, cm Hg.

P_b = Barometric pressure, cm Hg.

F = Sampling flow rate, cc/min

V_t = Sample train volume, cc

Pretest: 0.0 in 10 min.
10 min Range ✓

Time	Vacuum	Flowmeter Settings	Probe	Filter	Comments
9:27	28.00	100	130	124	
9:32	25.00	100	133	128	
9:37	23.50	100	132	129	
9:42	22.50	100	131	127	
9:47	21.50	100	132	123	
9:52	20.50	100	130	124	
9:57	19.00	100	130	122	
10:02	18.00	100	130	128	
10:07	16.50	100	131	127	
10:12	14.00	100	133	125	
10:17	12.00	100	134	122	
10:22	9.50	100	133	125	
10:27	8.00	100	135	127	

Facility: ARG

 Project No: 09-160

 Date: 12-8-10

 City/State: Bradford, PA

 Run No.: Three

 Sample Location: LO-CAT Exhaust

 Operator: ESW

 Tank No: 251

 Trap No: AET

Sample ID: _____

Tank Vacuum mmHG	Barometric Pressure mmHG	Ambient Temperature °F
Pretest (Manometer) <u>28.00</u>	<u>28.50</u>	<u>18</u>
Post-test (Manometer) <u>7.5</u>	<u>28.50</u>	<u>18</u>

Leak Rate: _____ mmHG/1.0 min.

 Pretest: 0.0 in 10min
10 min Purge
 $P = 0.01(FP_b/V_t)$

P = Allowable pressure change, cm Hg.

 P_b = Barometric pressure, cm Hg.

F = Sampling flow rate, cc/min

 V_t = Sample train volume, cc

Time	Vacuum	Flowmeter Settings	Probe	Filter	Comments
10:57	28.00	100	129	125	
11:02	25.00	100	130	124	
11:07	23.50	100	132	122	
11:12	22.0	100	132	132	
11:17	20.5	100	130	132	
11:22	18.5	100	131	127	
11:27	17.0	100	131	122	
11:31	16.0	100	132	124	
11:37	14.5	100	131	127	
11:42	12.5	100	131	127	
11:47	11.0	100	133	129	
11:52	9.0	100	130	130	
11:57	7.5	100	131	127	

This page intentionally left blank

Stack Dia. Measured?

DIAGRAM

Field Balance #:

Reference Weight Result:

IMPINGER WEIGHTS

Impinger	Initial	Final
1	100	220
2	100	108
3	0	0
4	236.2	241.2
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %

stop:

[illegible]

Figure 1

Stack Dia. Measured?

DIAGRAM

Field Balance #:

Reference Weight Result:_____

IMPINGER WEIGHTS

Impinger	Initial	Final
1	100	246
2	100	102
3	0	0
4	236.9	240.0
WET bulb		
DRY Bulb		

start: 1100 stop: 1106

start: stop:\\Server1\aproject\1 References\Field Data Sheets\Manual Method Data Sheets\Revised Data Sheets\Method 2 and 4 Data Sheets.xls Flow and Moisture

This page intentionally left blank

Client:	ARG	Test Date:	December 8, 2010
Project No.:	09-160	Test Location:	V-204 Vessel Outlet
Plant:	Bradford, PA	Test Run:	Run 1
Unit:	LO Cat Desulf	Test Start Time:	7:57 AM
Unit Operation:	rmcc	Test Finish Time:	8:57 AM

Red is a calculation. Pink is a reference to a cell on another sheet. Green is a reference to a cell on this sheet.

Data Input		Calculations									
Control Box:	1595		in	H ₂ O	CO + N ₂						
Meter DH ₆₀ (0.75 scfm)	1.760				Water Vapor Collected (V _r - V _i)				79.65	% dv	
Meter Calibration Factor (Y _d)	1.007			in	Water Vapor Condensed (V _w (std))				128.0	ml	
Barometric Pressure (P _{bar})	28.50			in	Water Collected (W _r - W _i)				6.024	scf	
Stack Static Pressure (P _g)	0.16			in	Water Vapor in Silica Gel (V _w (std))				5.0	g	
Stack Diameter (D _s) (L if rectangular)	8.0			inches	Vol. Water Vapor in Gas Stand (V _w (std))				0.236	scf	
Stack Width (enter NA if circular)	NA			inches	Volume Dry Gas Metered (V _m)				6.239	scf	
CO ₂	0.10			% dv	Vol. Dry Gas Metered Stand (V _m (std))				22.231	dscf	
	20.25			% dv	Volume Dry Gas Metered (V _m (m ³))				22.249	dscf	
Product Rate (enter NA if not needed)	NA			ton/hr	Vol. Dry Gas Metered Stand (V _m (std)(m ³))				0.630	dscm	
Is the input ton/hr metric? (YES=1)	0				Stack Absolute Pressure (P _s)				0.630	dscm	
Pilot Tube Coefficient (C _p)	0.84				Stack Absolute Temperature (T _{avg})				28.51	in Hg	
									582.4	R	
Flow, Moisture, THC											
Sample Calculation Title					H ₂ O Vapor Pressure @ avg Stack Temp.				3.72	in Hg	
F _g @ 70 F and 760 mm Hg (NA if NA)	na			dscf/MMBtu	H ₂ O in the gas at saturation (Bv _s)				0.1306	vol. fraction	
Standard Temperature	68			F	H ₂ O in the gas from test data (Bv _s)				0.2196	vol. fraction	
Standard Pressure	760			mm Hg	H ₂ O in the gas used (lower of the 2 Bv _s)				0.1306	vol. fraction	
Pilot Tube Constant (K _p)	85.49				Is the Gas Stream Saturated With H ₂ O?				YES		
Calculations											
Meter Temperature (T _m)	48.1			F	Dry Gas Molecular Weight (M _d)				28.83	lb/lb-mole	
Stack Temperature (T _{avg})	122.8			F	Wet Gas Molecular Weight (M _w)				27.41	lb/lb-mole	
Orifice Pressure Drop (dh _{avg})	1.700			F	Gas Velocity (V _g)				18.44	ft/s	
Gas Velocity Head (dP) ^{1/2} avg	0.2973			in H ₂ O ^{1/2}	Is the stack circular or rectangular?				CIRCULAR		
F _g @ Standard Conditions	NA			dscf/MMBtu	Area Stack (A _s)				0.349	ft ²	
F _g @ Stan. Cond. & Actual O ₂	NA			dscf/MMBtu	Actual Gas Flowrate				386	acfm	
Heat Input Based on F _g	NA			MMBtu/hr	Standard Gas Flowrate				333	scfm	
K1method 4	0.04706			scf/g	Dry Standard Gas Flowrate				290	dscfm	
K2method 4	0.04715			R/in. Hg	Actual Gas Flowrate				11	acm/min	
K1method 5	17.64				Standard Gas Flowrate				9	scm/min	
K1method 5	0.0945				Dry Standard Gas Flowrate				8	dscm/min	
Standard lb-mole compound	385.3			ft ³ /lb-mole	Operating Hours				50	hr/month	
Volatile Organic Compounds (VOC's) as THC M 25									1.67	hr/day	

Use Bias Corrected? (1=YES, 0=NO)		lb/lb-mole lb/lb-mole
0	MW Propane	44
	MW Carbon	12
	O2 for Correction	7
	TGNMO Concentration as Carbon	2361
	TGNMO Concentration as Propane	787.00
	Ethane as Propane	203.27
	NMEVOC Conc as Propane	583.73
	Emission Rate as Propane	1.159
	<u>Non-Methane, Non-Ethane Compounds (VOC)</u>	
	TGNMO Concentration as Carbon	2361
	Methane Concentration (N25 included)	320.00
	Ethane Concentration	304.90
	Ethane as Propane	203.27
	NMEVOC Concentration as Propane	583.73
	NMEVOC Emission Rate as Propane	1.159
	NME VOC Emission Rate as Propane	1.932
		lb/day

ARG	LO Cat Desulf	Run 1	F or C?
			F=1, C=0 1
Point	Pilot DP (dP) (in. H2O)	SQRT dP (in. H2O) ^{1/2}	Stack Temp (F or C)
A-1	0.12	0.346	123
A-2	0.13	0.361	123
A-3	0.12	0.346	123
A-4	0.10	0.316	123
A-5	0.07	0.265	122
A-6	0.06	0.245	122
A-7	0.07	0.265	122
A-8	0.07	0.265	122
B-1	0.08	0.283	123
B-2	0.08	0.283	123
B-3	0.09	0.300	123
B-4	0.09	0.300	123
B-5	0.09	0.300	123
B-6	0.08	0.283	123
B-7	0.09	0.300	123
B-8	0.09	0.300	123

Average	0.09	0.297	1.70	122.8	48.1
Initial volume	290.007	ft ³	Initial volume	0.000	liters
Final volume	312.238	ft ³	Final volume	0.000	liters
Total metered	22.231	dacf	Total metered	0.000	dry, actual liters

Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml	ml Gain
1			0.0	220.0	100.0	120.0
2			0.0	108.0	100.0	8.0
3			0.0	0.0	0.0	0.0
4	241.2	236.2	5.0	0.0	0.0	0.0
5			0.0	0.0	0.0	0.0
6			0.0	0.0	0.0	0.0
7			0.0	0.0	0.0	0.0
8			0.0	0.0	0.0	0.0
9			0.0	0.0	0.0	0.0
10			0.0	0.0	0.0	0.0
Total	241.2	236.2	5.0	328.0	200.0	128.0
	W _f	W _i	(W _f -W _i)	V _f	V _i	(V _f -V _i)

Client:	ARG	Test Date:	December 8, 2010
Project No.:	09-160	Test Location:	V-204 Vessel Outlet
Plant:	Bradford, PA	Run 2:	
Unit:	LO Cat Desulf	Test Start Time:	9:27 AM
Unit Operator:	mmoc	Test Finish Time:	10:27 AM
Red is a calculation.			Green is a reference to a cell on this sheet.
Data Input		Calculations	
Control Box:	1595	CO + N2	% dv
Meter DH ₂ (0.75 scfm)	1.76	Water Collected (V _r - V _i)	ml
Meter Calibration Factor (Yd)	1.007	Water Vapor Condensed (V _{wc} (std))	scf
Barometric Pressure (Pbar)	28.50	Water Collected (W _r - W _i)	g
Stack Static Pressure (Pg)	0.15	Water Vapor in Silica Gel (V _{wsg} (std))	scf
Stack Diameter (Ds) (L if rectangular)	8.0	Vol. Water Vapor in Gas Stand (V _w (std))	6.791 scf
Stack Width (enter NA if circular)	NA	Volume Dry Gas Metered (V _m)	21.953 dsf
CO2	0.09	Vol. Dry Gas Metered Stand (V _m (std))	21.927 dsf
O2	20.02	Volume Dry Gas Metered (V _m (m ³))	0.622 dcm
Product Rate (enter NA if not needed)	NA	Vol. Dry Gas Metered Stand (V _m (std)m ³)	0.621 dcm
Is the input ton/hr metric? (YES=1)	NA	Stack Absolute Pressure (Ps)	in. Hg
Pilot Tube Coefficient (Cp)	0	Stack Absolute Temperature (Tsavg)	R
Pilot Tube Coefficient (Cp)	0.84	Stack Absolute Temperature (Tsavg)	582.7
Flow, Moisture, THC		H2O Vapor Pressure (̂i) avg Stack Temp.	in. Hg
Sample Calculation Title	na	H2O in the gas at saturation (Bvs)	0.1315
F _g (̂i) 70 F and 760 mm Hg (NA if NA)		H2O in the gas from test data (Bws)	0.2365
Standard Temperature	68	H2O in the gas used (lower of the 2 Bvs)	0.1315
Standard Pressure	760	Is the Gas Stream Saturated With H2O?	YES
Pilot Tube Constant (Kp)	85.49	Dry Gas Molecular Weight (Md)	28.82
Calculations		Wet Gas Molecular Weight (Ms)	27.39
Meter Temperature (Tm)	49.1	Gas Velocity (Vs)	ft/s
Stack Temperature (Tsavg)	123.0	Is the stack circular or rectangular?	CIRCULAR
Orifice Pressure Drop (̂havg)	1.700	Area Stack (As)	0.349
Gas Velocity Head (̂h) ^{1/2} avg	0.4315	Actual Gas Flowrate	scfm
F _g (̂i) Standard Conditions	NA	Standard Gas Flowrate	scfm
F _g (̂i) Stan. Cond. & Actual O2	NA	Dry Standard Gas Flowrate	dsfm
Heat Input Based on F _g	NA	Dry Standard Gas Flowrate	acm/run
K1method 4	0.04706	Standard Gas Flowrate	scf/g
K2method 4	0.04715	R/in. Hg	16
K1method 5	17.64	Dry Standard Gas Flowrate	scm/min
K4method 5	0.0945	Operating Hours	14
Standard lb-mole volume	385.3	Operating Hours	12
Volatile Organic Compounds (VOC's) as THC M 25			
			50
			hr/month
			hr/day
			1.67

ARC		Run 2		F or C?	
LO Cat Desulf		F=1, C=0		I	
Point	Pilot DP (dP) (in. H ₂ O)	SQRT dP (in. H ₂ O) ^{1/2}	Orifice DP (dH) (in. H ₂ O)	Stack Temp (F)	Mater Temp In/Out (F or C)
A-1	0.21	0.458	1.7	123	47 48
A-2	0.22	0.469	1.7	123	47 48
A-3	0.22	0.469	1.7	123	50 47
A-4	0.22	0.469	1.7	123	51 47
A-5	0.21	0.458	1.7	123	54 48
A-6	0.19	0.436	1.7	123	54 48
A-7	0.19	0.436		123	
A-8	0.19	0.436		123	
B-1	0.18	0.424		123	
B-2	0.18	0.424		123	
B-3	0.17	0.412		123	
B-4	0.17	0.412		123	
B-5	0.17	0.412		123	
B-6	0.16	0.400		123	
B-7	0.16	0.400		123	
B-8	0.15	0.387		123	

Average		0.19	0.432	1.70	123.0	49.1
Initial volume	313.097	ft ³	Initial volume	0.000	liters	
Final volume	335.050	ft ³	Final volume	0.000	liters	
Total metered	21.953	daef	Total metered	0.000	liters	dry actual liters
Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml	ml Gain
1			0.0	234.0	100.0	134.0
2			0.0	101.0	100.0	1.0
3			0.0	6.0	0.0	6.0
4	243.2	239.9	3.3			0.0
5			0.0			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	243.2	239.9	3.3	341.0	200.0	141.0
	W _f	W _i	(W _f -W _i)	V _f	V _i	(V _f -V _i)

Average	0.19	0.432	1.70	123.0	49.1
Initial volume	313.097	ft ³	Initial volume	0.000	liters
Final volume	335.050	ft ³	Final volume	0.000	liters
Total metered	21.953	dacf	Total metered	0.000	dry actual liters
Impinger	Final grams	Initial grams	Gram Gain	Final ml	ml Gain
1			0.0	234.0	100.0
2			0.0	101.0	1.0
3			0.0	6.0	0.0
4	243.2	239.9	3.3	0.0	0.0
5			0.0	0.0	0.0
6			0.0	0.0	0.0
7			0.0	0.0	0.0
8			0.0	0.0	0.0
9			0.0	0.0	0.0
10			0.0	0.0	0.0
Total	243.2	239.9	3.3	341.0	200.0
	W _f	W _i	(W _f -W _i)	V _f	(V _f -V _i)

Client: ARG
Project No.: 09-160
Plant: Bradford, PA
Unit: LO Cat Desulf
Unit Operation: mmoce
Blue is data input.

Red is a calculation.

Data Input
Control Box:
Meter DH_{90} (0.75 scfm) 1.595
Meter Calibration Factor (Yd) 1.76
Barometric Pressure (Pbar) 28.50
Stack Static Pressure (Pg) 0.15
Stack Diameter (Ds) (L if rectangular) 8.0
Stack Width (enter NA if circular) NA
CO2 0.16
O2 20.09
Product Rate (enter NA if not needed) NA
Is the input ton/hr metric? (YES=1) 0
Pilot Tube Coefficient (Cp) 0.84

Flow, Moisture, THC
 F_d @70 and 760 mm Hg (NA if NA) na
Standard Temperature 68
Standard Pressure 760
Pilot Tube Constant (Kp) 85.49

Calculations
Meter Temperature (Tm) 46.9
Stack Temperature (Tsavg) 124.0
Orifice Pressure Drop (dHavg) 1.700
Gas Velocity Head (dH)^{1/2} avg 0.4398
 F_d @ Standard Conditions NA
 F_d @ Stan. Cond. & Actual O2 NA
Heat Input Based on F_d NA
K1method 4 0.04706
K2method 4 0.04715
K3method 5 17.64
K4method 5 0.0945
Standard lb-mole volume 385.3
Use Bias Corrected? (1=YES, 0=NO) 0
MW Propane 44
MW Carbon 12
O2 for Correction 7
TGNMO Concentration as Carbon 2281
TGNMO Concentration as Propane 760.33
Ethane as Propane 138.93
NMEVOC Conc as Propane 621.40
Emission Rate as Propane 1.815

Non-Methane, Non-Ethane Compounds (VOC)

TGNMO Concentration as Carbon 2281
Methane Concentration (M25 included) 321.00
Ethane Concentration 208.40
Ethane as Propane 138.93
NMEVOC Concentration as Propane 621.40
NMEVOC Emission Rate as Propane 1.815
NME VOC Emission Rate as Propane 3.026

Test Date: December 8, 2010
Test Location: V-204 Vessel Outlet
Test Run: Run 3
Test Start Time: 10:57 AM
Test Finish Time: 11:57 AM
Green is a reference to a cell on this sheet.

Calculations
CO + N2 79.75 % dv
Water Vapor Collected (Vv - Vj) 148.0 ml
Water Vapor Condensed (Vvc(std)) 6.965 scf
Water Collected (W - Wj) 3.1 g
Water Vapor in Silica Gel (Vvsg(std)) 0.146 scf
Vol. Water Vapor in Gas Stand (Vv(std)) 7.111 scf
Volume Dry Gas Metered (Vm) 22.081 dscf
Vol. Dry Gas Metered Stand (Vm(std)) 22.149 dscf
Volume Dry Gas Metered (Vm(m³)) 0.625 dscm
Vol. Dry Gas Metered Stand (Vm(stdm³)) 0.627 dscm
Stack Absolute Pressure (Ps) 28.51 in. Hg
Stack Absolute Temperature (Tsavg) 585.7 R
H2O Vapor Pressure @ avg Stack Temp. 3.85 in. Hg
H2O in the gas at saturation (Bvs) 0.1351 vol. fraction
H2O in the gas from test data (Bvs) 0.2430 vol. fraction
H2O in the gas used (lower of the 2 Bvs) 0.1351 vol. fraction
Is the Gas Stream Saturated With H2O? YES
Dry Gas Molecular Weight (Md) 28.83 lb/lb-mole
Gas Velocity (Vs) 27.32 ft/s
Is the stack circular or rectangular? CIRCULAR
Area Stack (As) 0.349 ft²
Actual Gas Flowrate 572 acfm
Standard Gas Flowrate 493 scfm
Dry Standard Gas Flowrate 426 dscfm
Actual Gas Flowrate 16 acm/min
Standard Gas Flowrate 14 scm/min
Dry Standard Gas Flowrate 12 dscm/min
Process Parameters
Operating Hours 50 hr/month
Operating Hours 1.67 hr/day

ARG
LO Cat Desulf

Run 3

F or C?
F=1, C=0

Point	Pilot DP (dP) (in. H2O) ^{1/2}	SOFT dP (in. H2O) ^{1/2}	Orifice DP (dH) (in. H2O)	Stack Temp (F)	Meter Temp In/Out (F or C)
A-1	0.19	0.436	1.7	124	44
A-2	0.20	0.447	1.7	124	44
A-3	0.21	0.458	1.7	124	45
A-4	0.22	0.469	1.7	124	48
A-5	0.22	0.469	1.7	124	50
A-6	0.22	0.469	1.7	124	51
A-7	0.21	0.458	1.7	124	
A-8	0.19	0.436		124	
B-1	0.17	0.412		124	
B-2	0.17	0.412		124	
B-3	0.18	0.424		124	
B-4	0.18	0.424		124	
B-5	0.18	0.424		124	
B-6	0.19	0.436		124	
B-7	0.19	0.436		124	
B-8	0.18	0.424		124	

Average	0.19	0.440	1.70	124.0	46.9
Initial volume	335.266	ft ³	Initial volume	0.000	liters
Final volume	357.347	ft ³	Final volume	0.000	liters
Total metered	22.081	dscf	Total metered	0.000	dry actual liters

Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml	ml Gain
1			0.0	246.0	100.0	146.0
2			0.0	102.0	100.0	2.0
3			0.0	0.0	0.0	0.0
4	240.0	236.9	3.1			
5			0.0			
6			0.0			
7			0.0			
8			0.0			
9			0.0			
10			0.0			
Total	240.0	236.9	3.1	348.0	200.0	148.0
	W _r	W _i	(W _r - W _i)	V _r	V _i	(V _r - V _i)

M11 Hydrogen Sulfide

Client	ARG	Date	12/8/10	Run #	1
ACCI Project #	09-160				
Plant Location	Bradford, PA				
Stack ID	LO-CAT Exhaust				
Pre-Test Leak Check	0.000	Post-Test Leak Check			
Barometric Pressure (in. Hg)	28.5				
Start Time:	1246	Stop Time: 1346			
Test Crew	TP EW THKK	Meter # 8002649			
Meter Box ID	HG Len-1	Y _d	0.9739	ΔH@	NA
Meter Volume	Initial 0	Final	59.530		
Dry Gas Meter Temp	Initial 57	Final	70		
Delta H/Vacuum	Initial 1 lpm	4.0	Final	1 lpm	4.0

probe temp: 250

ANALYSIS

	Sample	Blank
Volume of I ₂ Solution Used(V _{IT})	50.00 ml	50.00 ml
Normality of I ₂ Solution (N _I)	0.01 g-eq/liter	0.01 g-eq/liter
Volume of Na ₂ S ₂ O ₃ Solution (V _{TT})		
Initial Vol	0.00 ml	0.00 ml
Final Vol	47.83 ml	49.10 ml
Amount Used	47.83 ml	49.10 ml
Normality of Na ₂ S ₂ O ₃ Solution (N _T)	0.01 g-eq/liter	0.01 g-eq/liter

METER VOLUME (STANDARD)

$$V_{M(std)} = V_m Y_d \frac{T_{std} P_{bar}}{T_m P_{std}}$$

$$T_{std} = 70^{\circ}F = 573.15 K$$

$$P_{std} = 760 \text{ mmHg}$$

H₂S CONCENTRATION

$$C_{H_2S} = 17.04 \times 10^3 \frac{(V_{IT} N_I - V_{TT} N_T)_{sample} - (V_{IT} N_I - V_{TT} N_T)_{blank}}{V_{m(std)}}$$

$$C_{H_2S} = C_{H_2S} * \frac{24.45}{34.07}$$

Client **ARG** Date **12/8/10** Run # **2**

ACCI Project # **09-160**

Plant Location **Bradford, PA**

Stack ID **LO-CAT Exhaust**

Pre-Test Leak Check **0.00 @ 20"** Post-Test Leak Check **0.00 @ 10"**

Barometric Pressure (in. Hg) **28.5**

Start Time: **1353** Stop Time: **1453**

Test Crew **TPEW THKK** Meter # **8002649**

Meter Box ID **H6 Com-1** Y_d **0.9739** ΔH_@ **NA**

Meter Volume Initial **0** Final **59.881**

Dry Gas Meter Temp Initial **73** Final **75**

Delta H/Vacuum Initial **4 lpm** **5.0** Final **1 lpm** **5.0**

ANALYSIS

	Sample	Blank
Volume of I ₂ Solution Used (V _{IT})	<u>50.00</u> ml	<u>50.00</u> ml
Normality of I ₂ Solution (N _I)	<u>0.01</u> g-eq/liter	<u>0.01</u> g-eq/liter
Volume of Na ₂ S ₂ O ₃ Solution (V _{TT})		
Initial Vol	<u>0.00</u> ml	<u>0.00</u> ml
Final Vol	<u>43.78</u> ml	<u>49.10</u> ml
Amount Used	<u>43.78</u> ml	<u>49.10</u> ml
Normality of Na ₂ S ₂ O ₃ Solution (N _T)	<u>0.01</u> g-eq/liter	<u>0.01</u> g-eq/liter

METER VOLUME (STANDARD)

$$V_{M(std)} = V_m Y_d \frac{T_{std} P_{bar}}{T_m P_{std}}$$

$$T_{std} = 70^{\circ}F = 573.15 K$$

$$P_{std} = 760 mmHg$$

H₂S CONCENTRATION

$$C_{H_2S} = 17.04 \times 10^3 \frac{(V_{IT} N_I - V_{TT} N_T)_{sample} - (V_{IT} N_I - V_{TT} N_T)_{blank}}{V_{m(std)}}$$

$$C_{H_2S} = C_{H_2S} * \frac{24.45}{34.07}$$

Client	ARG	Date	12/8/10	Run #	3
ACCI Project #	09-160				
Plant Location	Bradford, PA				
Stack ID	LO-CAT Exhaust				
Pre-Test Leak Check	0.000 @ 12"	Post-Test Leak Check	0.000 @ 12"		
Barometric Pressure (in. Hg)	28.5				
Start Time:	1500	Stop Time:	1600		
Test Crew	TP EWTN KK	Meter #	8002649		
Meter Box ID	Hgcon-1	Y _d	09739	ΔH@	NA
Meter Volume	Initial	0	Final	59.958	
Dry Gas Meter Temp	Initial	62	Final	64	
Delta H/Vacuum	Initial	1 LPM	3.0	Final	1 LPM 3.0

ANALYSIS

	Sample		Blank
Sample			
Volume of I ₂ Solution Used (V _{IT})	50.00 ml		50.00 ml
Normality of I ₂ Solution (N _I)	0.01 g-eq/liter		0.01 g-eq/liter
Volume of Na ₂ S ₂ O ₃ Solution (V _{TT})			
Initial Vol	0.00 ml		0.00 ml
Final Vol	49.31 ml		49.10 ml
Amount Used	49.31 ml		49.10 ml
Normality of Na ₂ S ₂ O ₃ Solution (N _T)	0.01 g-eq/liter		0.01 g-eq/liter

METER VOLUME (STANDARD)

$$V_{M(std)} = V_m Y_d \frac{T_{std} P_{bar}}{T_m P_{std}}$$

$$T_{std} = 70^{\circ}F = 573.15 K$$

$$P_{std} = 760 \text{ mmHg}$$

H₂S CONCENTRATION

$$C_{H_2S} = 17.04 \times 10^3 \frac{(V_{IT} N_I - V_{TT} N_T)_{sample} - (V_{IT} N_I - V_{TT} N_T)_{blank}}{V_{m(std)}}$$

$$C_{H_2S} = C_{H_2S} * \frac{24.45}{34.07}$$

Client	ARG	Date	12/8/10
ACCI Project #	09-160	Run #	M11 Run 2
Plant Location	Bradford, Pa	Meter Box #	1555
Stack ID	LO-CAT Exhaust	Yd	1.007
Stack Diameter	8"	Delta H	1760
Pitot ID	41-1	Test Crew:	TP THEW KK
Pitot Cp	0.84	Pre-Test Leak Check	
B. P. (in. Hg)	28.5	Impingers	0.000 @ 14"
Ps (in. H ₂ O)	4.15	Pitot (+/-)	✓+ ✓-
Start Time:	1353	Post-Test Leak Check	
Stop Time:	1423	Impingers	0.000 @ 9"
Fyrite Kit#:	NA	Pitot (+/-)	✓+ ✓-

	DIAGRAM

Reference Weight Result:_____

Clock	Elapsed	Meter Volume	Meter Temp		Delta H	Vacuum/ Pressure	Impinger Temp.
	Initial	379.800					
	5 Min	383.496	41	41	1.7	2.0	30
	10 Min	387.310	43	42	1.7	2.0	31
	15 Min	390.985	46	40	1.7	2.0	36
	20 Min	394.510	48	43	1.7	2.0	38
	25 Min	398.114	49	44	1.7	2.0	40
	30 Min	401.848	48	45	1.7	2.0	39
	35 Min						
	Final						

Impinger	Initial	Final
1	100	225
2	100	102
3	0	0
4	224.2	228.2
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %

[illegible][illegible]

Client	ARG	Date	12/8/10
ACCI Project #	09-160	Run #	M11 Run 3
Plant Location	Bradford, Pa	Meter Box #	1555
Stack ID	LO-CAT Exhaust	Yd	1.007
Stack Diameter	84	Delta H	1.760
Pitot ID	41-1	Test Crew:	TP ENTH KK
Pitot Cp	0.84	Pre-Test Leak Check	
B. P. (in. Hg)	28.5	Impingers	0.000 @ 15"
Ps (in. H ₂ O)	1.15	Pitot (+/-)	✓ + ✓ -
Start Time:	1300	Post-Test Leak Check	
Stop Time:	1330	Impingers	0.000 @ 9"
Fyrite Kit#:	NA	Pitot (+/-)	✓ + ✓ -

DIAGRAM	

Reference Weight Result:

Clock	Elapsed	Meter Volume	Meter Temp		Delta H	Vacuum/ Pressure	Impinger Temp.
	Initial	402.067					
	5 Min	405.815	42	43	1.7	2.0	30
	10 Min	409.602	42	43	1.7	2.0	31
	15 Min	413.354	45	42	1.7	2.0	34
	20 Min	417.226	46	43	1.7	2.0	34
	25 Min	421.071	48	45	1.7	2.0	36
	30 Min	424.422	48	43	1.7	2.0	37
	35 Min						
	Final						

Impinger	Initial	Final
1	100	230
2	100	105
3	0	0
4	230.4	233.9
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %

[illegible][illegible]

This page intentionally left blank

Client:	ARG	Test Date:	December 8, 2010
Project No.:	09-160	Test Location:	V-204 Vessel Outlet
Plant:	Bradford, PA	Test Run:	Run 1
Unit:	LO Cat Desulf	Test Start Time:	12:46 PM
Unit Operation:	mmoc	Test Finish Time:	1:46 PM
Blue is data input.			
Pink is a reference to a cell on another sheet.			
Red is a calculation.			
			Green is a reference to a cell on this sheet.

Data Input		Calculations							
Control Box:	1595	CO + N2							% dv
Meter DH_g (0.75 scfm)	1.760	Water Collected (Vr- Vr)							ml
Meter Calibration Factor (Yd)	1.007	Water Vapor Condensed (Vvvc(std))							scf
Test Time (Theta)	60	Water Collected (Wr- Wj)							g
Barometric Pressure (Phat)	28.50	Water Vapor in Silica Gel (Vvsg(std))							scf
Stack Static Pressure (Psg)	0.15	Vol. Water Vapor in Gas Stand (Vv(std))							scf
Stack Diameter (Ds) (L if rectangular)	8.0	Volume Dry Gas Metered (Vm)							dscf
Stack Width (enter NA if circular)	NA	Vol. Dry Gas Metered Stand (Vm(std))							dscf
CO2	0.10	Volume Dry Gas Metered (Vm(m ³))							dscm
O2	20.70	Vol. Dry Gas Metered Stand (Vm(stdm ³))							dscm
Product Rate (enter NA if not needed)	NA	Stack Absolute Pressure (Ps)							in. Hg
Is the input ton/hr metric? (YES=1)	0	Stack Absolute Temperature (Tavg)							R
Pilot Tube Coefficient (Cp)	0.84	H2O Vapor Pressure (p avg Stack Temp.							in. Hg
Sample Calculation Title		H2O in the gas at saturation (Bvs)							vol fraction
F ₁ (q/ 70 F and 760 mm Hg (NA if NA)	na	H2O in the gas from test data (Bvs)							vol fraction
Standard Temperature	68	H2O in the gas used (lower of the 2 Bvs)							
Standard Pressure	760	Is the Gas Stream Saturated With H2O?							lb/lb-mole
Pilot Tube Constant (Kp)	85.49	Dry Gas Molecular Weight (Md)							lb/lb-mole
Calculations		Wet Gas Molecular Weight (Ms)							ft/s
Meter Temperature (Tm)	41.5	Gas Velocity (Vs)							
Stack Temperature (Tavg)	123.0	Is the stack circular or rectangular?							CIRCULAR
Orifice Pressure Drop (dHavg)	1.700	Area Stack (As)							ft ²
Gas Velocity Head (dp) ^{1,2} avg	0.4364	Actual Gas Flowrate							scfm
F ₁ (q) Standard Conditions	NA	Standard Gas Flowrate							dscfm
F ₁ (q) Stan. Cond. & Actual O2	NA	Dry Standard Gas Flowrate							acm/min
Heat Input Based on F ₁	NA	Actual Gas Flowrate							scm/min
K1method 4	0.04706	Standard Gas Flowrate							dscm/min
K2method 4	0.04715	Dry Standard Gas Flowrate							
K1method 5	17.64								
K4method 5	0.0945								
Standard lb-mole volume	385.3								
Hydrogen Sulfide									
MW H2S	34.08								
O2 for Correction	na								
Concentration	2.74								
Concentration	na								
Concentration	na								
Emission	0.006/1811								
Emission	NA								
Emission	NA/Not Needed								

Client:	ARG	Test Date:	December 8, 2010
Project No.:	09-160	Test Location:	V-204 Vessel Outlet
Plant:	Bradford, PA	Test Run:	Run 2
Unit:	LO Cat Desulf	Test Start Time:	1:53 PM
Unit Operation:	mmoc	Test Finish Time:	2:53 PM
Blue is data input.			
Data Input	Pink is a calculation.		
Control Box:	1595	CO + N2	79.20 % dv
Meter DH _g (0.75 scfm)	1.76	in. H ₂ O	127.0 ml
Meter Calibration Factor (Yd)	1.007	Water Vapor Collected (V _r -V _i)	5.977 scf
Test Time (Theta)	60	Water Vapor Collected (W _r -W _i)	4.0 g
Barometric Pressure (Pbar)	28.50	Water Vapor in Silica Gel (Vwsg(std))	0.189 scf
Stack Static Pressure (Psg)	0.15	Vol. Water Vapor in Gas Stand (Vw(std))	6.165 scf
Stack Diameter (Ds) (L if rectangular)	8.0	Volume Dry Gas Metered (Vm)	22.048 dscf
Stack Width (enter NA if circular)	NA	Vol. Dry Gas Metered Stand (Vm(std))	22.229 dscf
CO2	0.10	Volume Dry Gas Metered (Vm(m ³))	0.624 dscm
% dv	20.70	Vol. Dry Gas Metered Stand (Vm(std)m ³)	0.629 dscm
Product Rate (enter NA if not needed)	NA	Stack Absolute Pressure (Ps)	28.51 in. Hg
Is the input ton/hr metric? (YES=1)	0	Stack Absolute Temperature (Tavg)	582.7 R
Pilot Tube Coefficient (Cp)	0.84	H2O Vapor Pressure (@ avg Stack Temp.	3.75 in. Hg
Sample Calculation Title	Flow, Moisture, Hydrogen Sulfide	H2O in the gas at saturation (Bws)	0.1315 vol. fraction
F _d @ 70 F and 760 mm Hg (NA if NA)	na	H2O in the gas from test data (Bws)	0.2171 vol. fraction
Standard Temperature	68	H2O in the gas used (lower of the 2 Bws)	0.1315 vol. fraction
Standard Pressure	760	Is the Gas Stream Saturated With H2O?	YES
Pilot Tube Constant (Kp)	85.49	Dry Gas Molecular Weight (Md)	28.84 lb/lb-mole
Calculations		Wet Gas Molecular Weight (Mw)	27.42 lb/lb-mole
Meter Temperature (Tm)	44.3	Gas Velocity (Vs)	26.88 ft/s
Stack Temperature (Tavg)	123.0	Is the stack circular or rectangular?	CIRCULAR
Orifice Pressure Drop (dHavg)	1.700	Area Stack (As)	0.349 ft ²
Gas Velocity Head (dP) ^{1,2} avg	0.4335	Actual Gas Flowrate	563 scfm
F _d @ Standard Conditions	NA	Standard Gas Flowrate	486 scfm
F _d @ Stan. Cond. & Actual O2	NA	Dry Standard Gas Flowrate	422 dscfm
Heat Input Based on F _d	NA	Actual Gas Flowrate	16 acm/min
K1method 4	0.04706	Standard Gas Flowrate	14 dscm/min
K2method 4	0.04715		
K1method 5	17.64		
K4method 5	0.0945		
Standard lb-mole volume			
Hydrogen Sulfide			
NW H2S	34.08		
O2 for Correction	na		
Concentration	11.65		
Concentration	na		
Concentration	na		
Emission	0.0260857		
Emission	NA		
Emission	NA:Not Needed		

ARG		Run 2		F or C?	
LO Cat Desulf		F=1,C=0		1	
Point	Pilot DP (dP) (in. H2O)	SQRT dP (in. H2O) ^{1,2}	Orifice DP (dH) (in. H2O)	Stack Temp (E)	Meter Temp In/Out (F or C) (F or C)
A-1	0.21	0.458	1.7	123	41
A-2	0.20	0.447	1.7	123	43
A-3	0.20	0.447	1.7	123	46
A-4	0.20	0.447	1.7	123	48
A-5	0.20	0.447	1.7	123	49
A-6	0.19	0.436	1.7	123	48
A-7	0.19	0.436	1.7	123	
A-8	0.19	0.436		123	
B-1	0.18	0.424		123	
B-2	0.19	0.436		123	
B-3	0.19	0.436		123	
B-4	0.18	0.424		123	
B-5	0.18	0.424		123	
B-6	0.17	0.412		123	
B-7	0.17	0.412		123	
B-8	0.17	0.412		123	
Average	0.19	0.434	1.70	123.0	44.3
Initial volume	379.800	ft ³	Initial volume	0.000	liters
Final volume	401.848	ft ³	Final volume	0.000	liters
Total metered	22.048	dscf	Total metered	0.000	liters
Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml
1			0.0	225.0	100.0
2			0.0	102.0	100.0
3			0.0	0.0	0.0
4	228.2	224.2	4.0	0.0	0.0
5			0.0	0.0	0.0
6			0.0	0.0	0.0
7			0.0	0.0	0.0
8			0.0	0.0	0.0
9			0.0	0.0	0.0
10			0.0	0.0	0.0
Total	228.2	224.2	4.0	327.0	200.0
W _r		W _i	(W _r -W _i)	V _r	V _i
					(V _r -V _i)

Client: ARG
Project No.: 09-160
Plant: Bradford, PA
Unit: LO Cat Desulf
Unit Operation: mmoc
Unit Start Time: Red is a calculation.
Unit Finish Time: Pink is a reference to a cell on another sheet.

Test Date: December 8, 2010
Test Location: V-204 Vessel Outlet
Test Run: Run 3
Test Start Time: 3:00 PM
Test Finish Time: 4:00 PM
Green is a reference to a cell on this sheet.

Data Input
Control Box: 1595
Meter DH_{ig} (0.75 scfm) 1.76 in. H_2O
Meter Calibration Factor (Yd) 1.007 minutes
Test Time (Theta) 60
Barometric Pressure (Pbar) 28.50 in. Hg
Stack Static Pressure (Pg) 0.15 in. H_2O
Stack Diameter (Ds) (L if rectangular) 8.0 inches
Stack Width (enter NA if circular) NA inches
CO2 0.10 % dv
O2 20.70 % dv
Product Rate (enter NA if not needed) NA ton/hr
Is the input ton/hr metric? (YES=1) 0
Pilot Tube Coefficient (Cp) 0.84
Sample Calculation Title Flow, Moisture, Hydrogen Sulfide
 F_d @ 70 and 760 mm Hg (NA if NA) na dscf/MMBtu
Standard Temperature 68 F
Standard Pressure 760 mm Hg
Pilot Tube Constant (Kp) 85.49
Calculations
Meter Temperature (Tm) 44.0 F
Stack Temperature (Tavg) 123.0 F
Orifice Pressure Drop (dHavg) in. H_2O
Gas Velocity Head (dP)^{1,2} avg 0.4526 in. H_2O ^{1,2}
 F_d @ Standard Conditions NA dscf/MMBtu
 F_d @ Stan. Cond. & Actual O2 NA dscf/MMBtu
Heat Input Based on F_d NA MMBtu/hr
K1method 4 0.04706 scf/ml
K2method 4 0.04715 scf/g
K1method 5 17.64 R/in. Hg
K4method 5 0.0945 ft^3 /lb-mole
Standard lb-mole volume 385.3
Hydrogen Sulfide
MW H2S 34.08
O2 for Correction na
Concentration 0.45 vol. %
Concentration na ppm_w, 7 % O2
Concentration na gr/dscf
Emission 0.0010515 lb/hr
Emission NA lb/MMBtu
Emission NA, Not Needed lb/ton prod.

ARG		Run 3		F or C?	
LO Cat Desulf		SQRT dP		Meter Temp	
Point	Pilot DP (dP) (in. H2O)	Orifice DP (dH) (in. H2O)	Stack Temp (E)	Inlet (F or C)	Outlet (F or C)
A-1	0.20	0.447	1.7	123	42
A-2	0.19	0.436	1.7	123	42
A-3	0.20	0.447	1.7	123	45
A-4	0.20	0.447	1.7	123	46
A-5	0.19	0.436	1.7	123	48
A-6	0.19	0.436	1.7	123	48
A-7	0.19	0.436		123	
A-8	0.20	0.447		123	
B-1	0.21	0.458		123	
B-2	0.22	0.469		123	
B-3	0.22	0.469		123	
B-4	0.22	0.469		123	
B-5	0.22	0.469		123	
B-6	0.21	0.458		123	
B-7	0.21	0.458		123	
B-8	0.21	0.458		123	

Average		0.21		0.453		1.70		123.0		44.0	
Initial volume	402.067	ft ³		Initial volume	0.000	liters		Final volume	0.000	liters	
Final volume	424.422	ft ³		Final volume	0.000	liters		Total metered	0.000	liters	
Total metered	22.355	dscf								dry actual liters	

Impinger		Initial grams		Initial ml		Final ml		Gram Gain		ml Gain	
1								0.0		100.0	130.0
2								0.0		105.0	5.0
3								0.0		0.0	0.0
4	233.9		230.4					3.5		0.0	0.0
5								0.0		0.0	0.0
6								0.0		0.0	0.0
7								0.0		0.0	0.0
8								0.0		0.0	0.0
9								0.0		0.0	0.0
10								0.0		0.0	0.0
Total		233.9	230.4					3.5		200.0	135.0
		W _i		W _f		(W _f -W _i)		V _f		(V _f -V _i)	

This page intentionally left blank

USEPA Method 11 Worksheet
LoCat Outlet
12/8/2010

Run	Start Time	End Time	V _m L	Y _d	T _m °F	T _m °K	P _{bar} in. Hg	P _{bar} mm. Hg	Sample			Blank			V _{mstd}	H ₂ S ppm		
									V _{IT} ml	N _I g-eq/liter	V _{TT} ml	N _T g-eq/liter	V _{IT} ml	N _I g-eq/liter	V _{TT} ml	N _T g-eq/liter		
1	12:46	13:46	59.530	0.9739	63.5	290.7	28.50	723.9	50.00	0.01	47.83	0.01	50.00	0.01	49.10	0.01	55.70	2.74
2	13:53	14:53	59.881	0.9739	74.0	296.5	28.50	723.9	50.00	0.01	43.78	0.01	50.00	0.01	49.10	0.01	54.92	11.65
3	15:00	16:00	59.958	0.9739	63.0	290.4	28.50	723.9	50.00	0.01	49.31	0.01	50.00	0.01	49.10	0.01	56.15	0.45

Tstd 293.15 °K 70 °F
Pstd 760 mm. Hg 29.92 in. Hg

L Liter
°F Degrees Fahrenheit
°K Degrees Kelvin
Pbar Barometric Pressure
V_{ITB} Volume Iodine Solution Intial for Blank
N_{IB} Normality of Iodine Solution Initial for Blank
V_{ITB} Volume Sodium Thiosulfate Solution used in Titration for Blank
N_{IB} Normality of Sodium Thiosulfate Solution used in Titration for Blank
V_{nsid} Volume metered corrected to Standard Conditions
V_{ITS} Volume Iodine Solution Intial for Sample
V_{TTS} Volume Sodium Thiosulfate Solution used in Titration for Sample
N_{TS} Normality of Sodium Thiosulfate Solution used in Titration for Sample

g-eq/liter Equivalent grams per liter
ppm Parts per million
Tstd Standard Temperature
Pstd Standard Pressure
in. Hg Inches of Mercury
mm. Hg Millimeters of Mercury
ml Milliliter
H₂S Hydrogen Sulfide
V_m Volume Metered
Y_d Meter Correction Factor
T_m Meter Temperature
N_{IS} Normality of Iodine Solution Initial for Sample

APPENDIX C

Laboratory Data

M18 Ethane/Methane and O₂/CO₂

Air Quality Services, Inc.

4527 Clairton Boulevard

Pittsburgh, PA 15236

412-881-5630

412-881-7925 FAX

aq@comcast.netOrig - Eric N.
CC: Rob

TABLE I
ANALYSIS OF AIR BAG SAMPLES FOR SELECTED COMPONENTS
AIR/COMPLIANCE CONSULTANTS, INC.
1050 WILLIAM PITT WAY
PITTSBURGH, PA 15238
PROJECT ID: #09-160 ARG/LO-CAT, BEDFORD, PA.
PURCHASE ORDER # NOT GIVEN
SAMPLES RECEIVED: DECEMBER 09, 2010

ACCI SAMPLE IDENTIFICATION AND SAMPLE DATE	AQS LABORATORY NUMBER	METHANE PPM	ETHANE PPM	CARBON DIOXIDE PPM	OXYGEN/ARGON PERCENT
12-08-10					
RUN ONE	AQS-99115	289.8	304.9	1039.2	20.25
RUN TWO	AQS-99116	326.7	301.2	884.1	20.02
RUN THREE	AQS-99117	188.0	208.4	1589.9	20.09

THE OXYGEN/ARGON AND CARBON DIOXIDE WERE ANALYZED BY GAS CHROMATOGRAPHY USING A THERMAL CONDUCTIVITY DETECTOR AS OUTLINED BY ASTM METHOD D-1945 AND EPA METHOD 3C. THE METHANE AND ETHANE WERE ANALYZED BY GAS CHROMATOGRAPHY USING A FLAME PHOTOMETRIC DETECTOR AS OUTLINED BY EPA METHOD 18.


AIR QUALITY SERVICES, INC.

JOB 9268
REPORTED: DECEMBER 22, 2010

GAS ANALYSIS BY GC USING TCD DETECTOR

EPA METHOD 3

CLIENT INFORMATION

CLIENT: AIR COMPLIANCE CONSULTANTS PROJECT: ARG/LO-CAT
 ADDRESS: 1050 WILLIAM PITT WAY DATE: DECEMBER 10, 2010
 PITTSBURGH, PA 15238 ANALYST: M BRNA
 CONTACT: ERIC WHITE AQS JOB # 9268

CALIBRATION DATA

REQUIRED: OXYGEN COLUMN: SG/MS
 DETECTOR: TCD INJECTION VOLUME: 2.0 CC

CALIBRATION VALUE PERCENT	INJECT VOLUME ML	PEAK AREA COUNT	PEAK AREA COUNT	AVERAGE PEAK COUNT	STANDARD FACTOR PPM/COUNT	INDIVIDUAL AREA STD DEV	% STD DEV
20.95	2.0	3944.1600	4068.5870	4010.9740	0.0052	50.84	1.27
4.99	2.0	954.6830	960.4470	958.8055	0.0052	2.42	0.25

CALIBRATION STATISTICAL DATA

MEAN FACTOR: 0.0052
 STDDEV: 0.0000
 0.2

SAMPLE ANALYTICAL DATA

CLIENT SAMPLE ID	AQS LAB NUMBER	INJECT VOLUME ML	PEAK AREA COUNTS	PEAK AREA COUNTS	AVERAGE PEAK COUNT	INDIVIDUAL AREA STD DEV	OXYGEN PERCENT
RUN ONE	99115	2.0	3911.5000	3888.3505	3845.7510	3881.87	20.25
RUN TWO	99116	2.0	3879.8740	3884.4920	3747.8060	63.37	20.02
RUN THREE	99117	2.0	3805.3590	3890.2860	3859.4725	3851.71	20.09

GAS ANALYSIS BY GC USING TCD DETECTOR

EPA METHOD 3

CLIENT INFORMATION

CLIENT: AIR COMPLIANCE CONSULTANTS PROJECT: ARG/LO-CAT
 ADDRESS: 1050 WILLIAM PITT WAY DATE: DECEMBER 10, 2010
 PITTSBURGH, PA 15238 ANALYST: M BRNA
 CONTACT: ERIC WHITE AQS JOB # 9268

CALIBRATION DATA

REQUIRED: CARBON DIOXIDE COLUMN: SG/MS
 DETECTOR: TCD INJECTION VOLUME: 2.0 CC

CALIBRATION VALUE PERCENT	INJECT VOLUME ML	PEAK AREA	PEAK COUNT	AVERAGE PEAK COUNT	STANDARD FACTOR	INDIVIDUAL AREA STD DEV	% STD DEV
---------------------------	------------------	-----------	------------	--------------------	-----------------	-------------------------	-----------

5.006	2.0	1050.2895	1127.6830	1143.0570	1107.01	0.0045	40.60	3.67
1.00	2.0	220.8235	216.9400	226.7425	221.50	0.0045	4.03	1.82
0.1038	2.0	22.3010	22.8040	22.8375	22.65	0.0046	0.25	1.08


CALIBRATION STATISTICAL DATA

MEAN FACTO 0.0045
 STDDEV: 0.0000
 0.7

SAMPLE ANALYTICAL DATA


CLIENT SAMPLE ID	AQS LAB NUMBER	INJECT VOLUME ML	PEAK AREA	PEAK COUNTS	AVERAGE PEAK COUNT	INDIVIDUAL AREA STD DEV	% STD DEV	CARBON DIOXIDE PERCENT	PPM
RUN ONE	99115	2.0	23.62	22.6885	22.362	22.89	0.53	0.1	1039.2
RUN TWO	99116	2.0	19.324	19.569	19.5275	19.47	0.11	0.1	884.1
RUN THREE	99117	2.0	35.242	35.572	34.2445	35.02	0.56	0.2	1589.9

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: AIR
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.233	271.402	4010.9740	20.5658
NITROGEN	3.766	446.019	15371.7150	78.8166
CO2	15.733	2.027	34.9925	0.1794
			19417.6815	100.0000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: TCD DETECTOR
Column: SILICA GEL/MOLE SIEVE
Carrier: HELIUM
Sample: AIR
Operator: MAI BRNA
Comments: JOB #9268
OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.366	268.378	4068.5870	20.6856
NITROGEN	3.900	445.586	15503.1260	78.8215
CO2	15.700	0.782	12.3035	0.0626
		19584.0165	100.0000	

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: AIR
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
OXYGEN	3.300	266.443	3944.1600	20.6878
NITROGEN	3.833	441.544	15037.0475	78.8718
CO2	15.666	0.717	11.2510	0.0590
			18992.4585	100.0000


Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: 1% MIX
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
OXYGEN	3.333	12.166	93.0780	0.4651
NITROGEN	3.733	528.347	18615.1940	93.0208
METHANE	7.083	6.218	173.2000	0.8655
CO	7.716	6.920	169.5940	0.8475
ETHANE	13.400	11.813	236.1960	1.1803
CO2	15.666	14.150	220.8235	1.1035
ETHYLENE	16.233	14.783	238.0075	1.1893
ACETYLENE	18.900	14.426	200.2080	1.0004


19946.3010 100.0000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: TCD DETECTOR
Column: SILICA GEL/MOLE SIEVE
Carrier: HELIUM
Sample: 1% MIX
Operator: MAI BRNA
Comments: JOB #9268
OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.433	22.091	168.8895	0.8426
NITROGEN	3.816	525.329	18588.8590	92.7453
METHANE	7.183	7.119	180.2710	0.8994
CO	7.866	7.748	165.1690	0.8241
ETHANE	13.316	11.714	229.5205	1.1451
CO2	15.683	13.238	216.9400	1.0824
ETHYLENE	16.233	14.641	233.5370	1.1652
ACETYLENE	18.883	14.135	198.5030	0.9904
			19981.6890	100.0000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: TCD DETECTOR
Column: SILICA GEL/MOLE SIEVE
Carrier: HELIUM
Sample: 4-5% MIX
Operator: MAI BRNA
Comments: JOB #9268
OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.766	89.639	958.8055	19.4027
NITROGEN	4.550	74.686	1099.7765	22.2554
METHANE	7.300	47.446	950.8920	19.2425
CO	7.916	33.502	716.8165	14.5057
CO2	15.500	55.539	1143.0570	23.1312
			4869.3475	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: 4-5% MIX
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.666	89.010	954.6830	17.0309
NITROGEN	4.350	118.326	1925.3040	34.3461
METHANE	7.033	43.492	909.7475	16.2293
CO	7.733	30.135	664.8390	11.8603
CO2	15.533	54.489	1050.2895	18.7364
			5504.8630	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: 4-5% MIX
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.783	89.933	960.4470	19.3457
NITROGEN	4.550	80.050	1197.2580	24.1157
METHANE	7.316	46.210	932.4180	18.7812
CO	7.966	32.201	675.3580	13.6034
CO2	15.516	55.464	1127.6830	22.7143
			4893.1640	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: 1038 PPM CO2
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
CO2	15.766	1.410	22.3010	22.3706
			22.3010	100.0000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: TCD DETECTOR
Column: SILICA GEL/MOLE SIEVE
Carrier: HELIUM
Sample: 1038 PPM CO2
Operator: MAI BRNA
Comments: JOB #9268
OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
CO2	15.833	1.515	22.8040	25.7962
			22.8040	100.0000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: TCD DETECTOR
Column: SILICA GEL/MOLE SIEVE
Carrier: HELIUM
Sample: 1038 PPM CO2
Operator: MAI BRNA
Comments: JOB #9268
OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
CO2	15.850	1.503	22.6585	23.4504
			22.6585	100.0000


Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99115
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN ONE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
OXYGEN	3.183	272.938	3845.7510	19.5436
NITROGEN	3.683	462.045	15737.9175	79.9781
CO2	15.766	1.515	22.3620	0.1136


19606.0305 100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99115
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN ONE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.333	264.573	3888.3505	19.7214
NITROGEN	3.866	452.011	15724.6300	79.7539
CO2	15.816	1.573	22.6885	0.1151
			19635.6690	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99115
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN ONE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.383	261.666	3911.5000	19.7597
NITROGEN	3.900	449.292	15767.7160	79.6536
CO2	15.833	1.520	23.6200	0.1193
			19702.8360	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99116
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN TWO
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.333	262.805	3879.8740	20.0142
NITROGEN	3.866	446.585	15404.9490	79.4659
CO2	15.766	1.250	19.3240	0.0997
			19304.1470	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99116
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN TWO
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.300	257.642	3747.8060	19.8355
NITROGEN	3.800	443.536	15043.4220	79.6184
CO2	15.800	1.276	19.5275	0.1034
				18810.7555 100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99116
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN TWO
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.333	258.191	3884.4920	19.9325
NITROGEN	3.850	445.307	15521.7565	79.6467
CO2	15.766	1.252	19.5690	0.1004
			19425.8175	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99117
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN THREE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS




Component	Retention	Height	Area	Area %
OXYGEN	3.300	260.533	3805.3590	20.1451
NITROGEN	3.833	441.464	14994.5485	79.3792
CO2	15.633	2.184	35.2420	0.1866
			18835.1495	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99117
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN THREE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
OXYGEN	3.333	262.195	3890.2860	20.2706
NITROGEN	3.866	443.220	15198.5940	79.1933
CO2	15.683	2.117	35.5720	0.1854
			19124.4520	100.0000

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99117
 Description: TCD DETECTOR
 Column: SILICA GEL/MOLE SIEVE
 Carrier: HELIUM
 Sample: RUN THREE
 Operator: MAI BRNA
 Comments: JOB #9268
 OXYGEN AND CARBON DIOXIDE ANALYSIS



Component	Retention	Height	Area	Area %
OXYGEN	3.300	264.038	3859.4725	20.1054
NITROGEN	3.816	447.070	15232.9275	79.3537
CO2	15.700	2.117	34.2445	0.1784
			19126.6445	100.0000

GAS ANALYSIS BY GC USING FID DETECTOR

EPA METHOD 18

CLIENT INFORMATION

CLIENT: AIR COMPLIANCE CONSULTANTS PROJECT: ARG/LO-CAT
ADDRESS: 1050 WILLIAM PITT WAY DATE: DECEMBER 10, 2010
PITTSBURGH, PA 15238 ANALYST: M BRNA
CONTACT: ERIC WHITE AQS JOB # 9268

CALIBRATION DATA

REQUIRED: METHANE COLUMN: GSQ
DETECTOR: FID INJECTION VOLUME: 2.0 CC

CALIBRATION VALUE	PPM	Cv	INJECT VOLUME	ML	Civ	PEAK AREA	PEAK COUNT	PEAK AREA	PEAK COUNT	AVERAGE PEAK COUNT	STANDARD FACTOR	INDIVIDUAL AREA	STD DEV	% STD DEV	Ca= Avg(Ca1,Ca3)	Cf= Cv/Ca
1005.00		2.0	7267.9870	2.0	7250.3025	7245.4070	7254.57	7245.4070	7254.57	0.1385	0.1385	9.70	0.13			
100.00		2.0	819.7470	2.0	757.5340	843.8140	807.03	843.8140	807.03	0.1239	0.1239	36.35	4.50			
50.90		2.0	347.6940	2.0	368.0970	366.8690	360.89	366.8690	360.89	0.1410	0.1410	9.34	2.59			
50.90		2.0	380.5780	2.0	375.2990	349.6910	368.52	349.6910	368.52	0.1381	0.1381	13.49	3.66			
25.10		2.0	182.1280	2.0	196.6525	186.2145	188.33	186.2145	188.33	0.1333	0.1333	6.12	3.25			
10.20		2.0	72.9540	2.0	72.7975	75.2380	73.66	75.2380	73.66	0.1385	0.1385	1.12	1.51			

PRE SAMPLE ANALYSIS
POST SAMPLE ANALYSIS

CALIBRATION STATISTICAL DATA

MEAN FACTOR: 0.1356 Mf
STDDEV: 0.0057
4.2

SAMPLE ANALYTICAL DATA

CLIENT SAMPLE ID	AQS LAB NUMBER	INJECT VOLUME	ML	PEAK AREA	PEAK COUNT	PEAK AREA	PEAK COUNT	AVERAGE PEAK COUNT	INDIVIDUAL AREA	STD DEV	% STD DEV	METHANE PPM
			Siv	Sa1	Sa2	Sa2	Sa2	Sa				PPM= (Mf*Sa)*(Civ/Siv)
RUN ONE	99115	2.0	2066.7370	2252.8725	2092.9860	2137.53	82.26	3.85	289.8			
RUN TWO	99116	2.0	2298.2500	2369.7840	2561.8795	2409.97	111.31	4.62	326.7			
RUN THREE	99117	2.0	1436.6380	1355.1120	1369.5175	1387.09	35.53	2.56	188.0			

CLIENT INFORMATION

CLIENT: AIR COMPLIANCE CONSULTANTS PROJECT: ARG/LO-CAT
ADDRESS: 1050 WILLIAM PITT WAY DATE: DECEMBER 10, 2010
PITTSBURGH, PA 15238 ANALYST: M BRNA
CONTACT: ERIC WHITE AQS JOB # 9268

CALIBRATION DATA

REQUIRED: ETHANE COLUMN: GSQ
DETECTOR: FID INJECTION VOLUME: 2.0 CC

CALIBRATION VALUE PPM	INJECT VOLUME ML	INJECT AREA COUNT	PEAK AREA COUNT	PEAK AREA COUNT	AVERAGE PEAK COUNT	STANDARD FACTOR	INDIVIDUAL AREA		Ca= Cf=	Avg(Ca1,Ca3) Cv/Ca
							STD DEV	% STD DEV		
1000.00	2.0	14916.3290	15640.4760	16147.2505	15568.02	0.0642	505.13	3.24		
100.00	2.0	1652.6610	1524.7315	1697.4220	1624.94	0.0615	73.18	4.50		
49.40	2.0	772.1900	836.7560	840.9155	816.62	0.0605	31.46	3.85		
49.40	2.0	865.5050	789.4990	853.2750	836.09	0.0591	33.32	3.99		
24.30	2.0	376.9730	410.6010	387.1025	391.56	0.0621	14.09	3.60		
9.86	2.0	154.8925	148.3770	151.9045	151.72	0.0650	2.66	1.76		

PRE SAMPLE ANALYSIS
POST SAMPLE ANALYSIS


CALIBRATION STATISTICAL DATA

MEAN FACTOR: 0.0621 Mf
STDDEV: 0.0020
3.3

SAMPLE ANALYTICAL DATA


CLIENT SAMPLE ID	AQS LAB NUMBER	INJECT VOLUME ML	PEAK AREA COUNTS	PEAK AREA COUNTS	AVERAGE PEAK COUNT	INDIVIDUAL AREA		ETHANE PPM
						STD DEV	% STD DEV	
		Siv	Sa1	Sa2	Sa			PPM= (Mf*Sa)*(Civ/Siv)
RUN ONE	99115	2.0	4741.1315	5201.5755	4796.526	205.25	4.18	304.9
RUN TWO	99116	2.0	4583.046	4803.933	5170.6675	242.35	4.99	301.2
RUN THREE	99117	2.0	3507.734	3242.596	3324.825	110.81	3.30	208.4

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-14-2010
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 1000 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	532.312	7245.4070
ETHANE	2.500	903.603	13193.3060
			20438.7130

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-14-2010
 Lab ID: STANDARD
 Description: FID DETECTOR
 Column: GSQ 30M
 Carrier: HYDROGEN
 Sample: 1000 PPM MIX
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	552.958	7267.9870
ETHANE	2.533	924.599	13281.0600
			20549.0470

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-14-2010
 Lab ID: STANDARD
 Description: FID DETECTOR
 Column: GSQ 30M
 Carrier: HYDROGEN
 Sample: 1000 PPM MIX
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	556.290	7250.3025
ETHANE	2.500	914.505	13213.7760
			20464.0785

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-14-2010
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 1000 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	563.140	8250.5710
ETHANE	2.500	920.863	14916.3290
			23166.9000

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 1000 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	546.627	8689.4290
ETHANE	2.466	907.578	15640.4760
			24329.9050

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 1000 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.500	575.843	8994.8170
ETHANE	2.466	956.606	16147.2505
			25142.0675

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 100 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	51.406	843.8140
ETHANE	2.516	103.547	1697.4220
			2541.2360

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 100 PPM M/100 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.633	43.710	819.7470
ETHANE	2.400	77.141	1652.6610
			2472.4080

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30M
Carrier: HYDROGEN
Sample: 100 PPM MIX
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	52.257	757.5340
ETHANE	2.500	103.177	1524.7315
			2282.2655

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 50.9 PPM M/49.4 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.500	22.788	375.2990
ETHANE	2.500	53.806	853.2750
			1228.5740

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: 50.9 PPM M/49.4 PPM E
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	22.431	380.5780
ETHANE	2.533	52.916	865.5050
			1246.0830

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 50.9 PPM M/49.4 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	23.011	349.6910
ETHANE	2.516	52.492	789.4990
			1139.1900

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 50.9 PPM M/49.4 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	21.913	368.0970
ETHANE	2.500	50.965	836.7560
			1204.8530

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: 50.9 PPM M/49.4 PPM E
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	22.695	366.8690
ETHANE	2.533	52.431	840.9155
			1207.7845

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 50.9 PPM M/49.4 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	22.407	347.6940
ETHANE	2.533	50.942	772.1900
			1119.8840

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 25.1 PPM M/24.3 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	12.326	182.1280
ETHANE	2.533	25.289	376.9730
			559.1010

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 25.1 PPM M/24.3 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS



Component	Retention	Height	Area
METHANE	1.516	13.688	196.6525
ETHANE	2.533	27.437	410.6010
			607.2535

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 25.1 PPM M/24.3 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHAN AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	13.775	186.2145
ETHANE	2.550	27.497	387.1025
			573.3170

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 10.2 PPM M/9.86 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS



Component	Retention	Height	Area
METHANE	1.616	3.837	72.9540
ETHANE	2.533	9.444	154.8925
			227.8465

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Lab ID: STANDARD
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: 10.2 PPM M/9.86 PPM E
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.550	4.176	75.2380
ETHANE	2.533	9.453	151.9045
			227.1425

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Lab ID: STANDARD
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: 10.2 PPM M/9.86 PPM E
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	4.123	72.7975
ETHANE	2.516	9.456	148.3770
			221.1745

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99115
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: RUN ONE
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	125.348	2092.9860
ETHANE	2.533	291.354	4796.5260
			6889.5120

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-08-2010
Lab ID: 99115
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: RUN ONE
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	132.829	2252.8725
ETHANE	2.533	318.111	5201.5755
			7454.4480

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99115
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: RUN ONE
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	128.453	2066.7370
ETHANE	2.483	310.571	4741.1315
			6807.8685

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99116
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: RUN TWO
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	157.956	2369.7840
ETHANE	2.500	322.253	4803.9330
			7173.7170

Lab name: AIR QUALITY SERVICES
 Client: AIR/COMPLIANCE
 Collected: 12-08-2010
 Lab ID: 99116
 Description: FID DETECTOR
 Column: GSQ 30METER
 Carrier: HYDROGEN
 Sample: RUN TWO
 Operator: MAI BRNA
 Comments: JOB #9268
 LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	156.608	2298.2500
ETHANE	2.516	312.679	4583.0460
			6881.2960

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-08-2010
Lab ID: 99116
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: RUN TWO
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.516	149.885	2561.8795
ETHANE	2.516	312.708	5170.6675
			7732.5470

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-08-2010
Lab ID: 99117
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: RUN THREE
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS




Component	Retention	Height	Area
METHANE	1.533	80.451	1355.1120
ETHANE	2.533	206.477	3242.5960
			4597.7080

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-08-2010
Lab ID: 99117
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: RUN THREE
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS



Component	Retention	Height	Area
METHANE	1.483	125.032	1436.6380
ETHANE	2.450	328.419	3507.7340
			4944.3720

Lab name: AIR QUALITY SERVICES
Client: AIR/COMPLIANCE
Collected: 12-08-2010
Lab ID: 99117
Description: FID DETECTOR
Column: GSQ 30METER
Carrier: HYDROGEN
Sample: RUN THREE
Operator: MAI BRNA
Comments: JOB #9268
LOW LEVEL METHANE AND ETHANE ANALYSIS



Component	Retention	Height	Area
METHANE	1.500	118.719	1369.5175
ETHANE	2.516	282.153	3324.8250
			4694.3425

M25 Volatile Organic Compounds

RECEIVED JAN 10 2011

NJ NELAP ID - NC004
PADEP Registration #68-3321

cc: Bill N.
Jill Rob

Method 25 Analytical Results

prepared for

AIR/COMPLIANCE CONSULTANTS, INC.


1050 William Pitt Way
Pittsburgh, PA 15238

by


Triangle Environmental Services, Inc.

We, the undersigned, certify to the best of our knowledge that all analytical data presented in this report have been checked for completeness; that the results are accurate, error-free, legible, and have been obtained in accordance with approved protocol; and that all deviations and analytical problems are summarized in the "Comments on the Analyses" page(s).

Approved by:


Wayne A. Stollings
President

Reviewed by:


Donna Nolen-Weathington
Method 25 Supervisor

Report
10195

January 7, 2011

Triangle Environmental Services, Inc. COMMENTS ON THE ANALYSES

Report #10195 for Air/Compliance Consultants, Inc.
Project ID: ARG LO-CAT 09-160

Traps Received: 12/10/10 with dry ice
Tanks Received: 12/13/10

Samples Analyzed: 1/1-2/11 on Analyzer B
Client Chain-of-Custody forms: 1 pg

- General:
- The analytical system indicates a background concentration of (1) "CO" due to the interference of O₂ resulting from the coelution of O₂ and CO and (2) CO₂ due to CO₂ and organic compounds in the recovery carrier gas. The CO, CO₂, and condensibles concentrations in the report are calculated using a "blank" correction, which results in a more accurate reporting and a better comparison of these concentrations in the analyses.
 - The presence of organic compounds in the sample tank that should have condensed in the dry ice trap **may** result in an underreporting of those compounds (especially if oxygenated).
 - A concentration of noncondensibles or condensibles of less than the RL is considered to be zero in computing the TGNMO.
- All samples: All post-test tank pressure/temperature ratios agreed with the lab receipt pressure/temperature ratios within $\pm 4\%$.
- Sample #1: When recovering the condensible portion of a sample, scientific-grade air is passed through the trap heated to 250 °C into an intermediate collection vessel. The collection is normally stopped when the CO₂ concentration in the trap effluent drops below 10 ppmC. For this sample, recovery was stopped when the concentration was ≈ 11 ppm. This may have an effect on the reported concentrations.

Triangle Environmental Services, Inc.
METHOD 25 TABLE OF RESULTS

Client: Air/Compliance Consultants, Inc.

ID#10195 Analyzed: 1/1-2/11

Project ID: ARG LO-CAT 09-160

	Sample Description	Concentrations (ppmC)						Mass Conc. (mgC/cu.m)
		CO	CH4	CO2	Noncon- densibles	Conden- sibles	TGNMO	
1	Run 1 ARG LO-CAT	< 11	320	3511	2219	142	2361	1179
2	Run 2 ARG LO-CAT	< 12	312	2610	2140	137	2277	1137
3	Run 3 ARG LO-CAT	< 10	321	1359	2105	175	2281	1139

< # = Concentration Below Report Limit

* Please refer to the "Comments on the Analyses" page of the report for additional information.

Triangle Environmental Services, Inc.

METHOD 25 PROCEDURES

Report #10195

CALIBRATION

The calibrations satisfy the requirements for Methods 25, 25-C, and 10-B.

Triplicate injections of a calibration gas mixture consisting of carbon monoxide (≈ 200 ppm), methane (≈ 50 ppm), carbon dioxide ($\approx 10,000$ ppm), and propane (≈ 20 ppm) are made immediately before and after each batch of samples. Daily response factors are calculated from the pre-batch integrated responses (average area count / concentration in ppmC) and must agree within 10% of the response factors of the initial calibrations. Further, the post-batch response factors must agree within 2% of the pre-batch response factors. Both criteria must be met before the analyses are considered valid.

CONDENSATE RECOVERY

To flush the trap of CO_2 , hydrocarbon-free air is flushed through the trap maintained at -78°C into the sample tank until less than 10 ppm CO_2 is detected in the flow stream (the concentration of CO_2 is monitored with an NDIR CO_2 detector and measured using a CO_2 analyzer). The sample tank is pressurized to about 1200 mm Hg for analysis and is replaced with an intermediate collection vessel (ICV).

To oxidize the organic material in the trap, hydrocarbon-free air is then passed through the trap heated to 250°C and the recovery oxidation catalyst into the ICV until less than 10 ppm CO_2 is detected in the flow stream. The ICV is pressurized to about 1200 mm Hg for analysis.

ANALYSIS

All samples, which include the daily calibration gas mixture, sample tanks, and ICVs, are analyzed in triplicate using a computer-interfaced gas chromatograph equipped with an automated gas sampling system and a flame ionization detector (FID). CO , CH_4 , and CO_2 are eluted from the Unibead 1S-Carbosieve G column and pass through the analytical oxidation and reduction catalyst to the FID. The column is then backflushed to elute the nonmethane organic (NMO) fraction, which passes through the analytical oxidation and reduction catalysts to the FID.

CALCULATIONS

Calculations are done in accord with USEPA Method 25 procedures. A sample calculation for one of the samples is provided in the report. CO and CO_2 blanks are used to compensate for a background concentration of (1) "CO" due to the interference of O_2 resulting from the coelution of O_2 and CO and (2) CO_2 due to CO_2 and organic compounds in the recovery carrier gas. A concentration of noncondensibles or condensibles of less than the RL is considered to be zero in computing the TGNMO.

EQUIPMENT

Tanks and ICVs are at a minimum twice evacuated and filled with ambient air filtered through charcoal and are then evacuated to below 10 mm Hg and monitored for at least an hour to check that the tanks do not leak more than 1 mm Hg/hour. They are then pressurized to greater than ambient pressure with helium, analyzed to ensure < 2 ppmC NMO, and stored for later use.

Traps are flushed at 300°C for at least 30 minutes with compressed air. Each trap is then flushed at 350°C for thirty minutes with hydrocarbon-free air. The effluent is then routed through an oxidation catalyst and a reduction catalyst for analysis by FID-GC to confirm less than 10 ppmC total C.

Sampling units are reconditioned by replacing filters and checking that all sections operate properly. The unit is heated (with a PTFE line used in place of a trap) and is flushed with zero air for at least thirty minutes before an aliquot of this flow is injected into the analyzer. If the total carbon concentration is below 10 ppm, the unit is made ready for use and stored for shipment.

Certifications:

South Coast Air Quality Management District: ID# 94 LA 0401

New Jersey NELAP ID: NC004

Pennsylvania DEP: Registration #68-3321

Triangle Environmental Services, Inc.

METHOD 25 SAMPLE CALCULATION

Client: Air/Compliance Consultants, Inc.

ID#10195 Analyzed: 1/1-2/11

Project ID: ARG LO-CAT 09-160

Sample #.1 Run 1 ARG LO-CAT

D A T A

Note: All pressure values have been converted when necessary to mm Hg and all temperature values to Kelvin.

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	
Presampling	2.0	294.26	Tank 259:
Postsampling	533.9	266.48	Tank Volume = 0.008390 cu.m
Lab Receipt	590.0	299.15	
Tank Final	1197.0	299.15	Trap BRT →
CV Final	1528.0	299.15	Collection Vessel 14:
			CV Volume = 0.008349 cu.m

Response Factors (RF), Report Limits (RL), and Area Counts:

	RF (area/ppmC)	RL (ppmC)	Area 1	Area 2	Area 3
CO	296.2	11	739	743	739
CH4	299.8	7	48,008	47,811	47,750
CO2	308.0	7	541,702	540,382	539,508
Noncondensibles	286.6	5	317,948	316,295	317,645
Condensibles	308.0	8	18,295	18,014	18,002

CO Blank = 5 area counts CO2 Blank = 3 ppm

C A L C U L A T I O N S

Measured Concentrations, corrected for blank (ppmC):

$$\begin{aligned}
 C_m(\text{CO}) &= [\text{Area}(\text{CO}) - \text{CO Blank}] / \text{RF}(\text{CO}) \\
 &= [739 - 5] / 296.2 = 2.5 \\
 &= [743 - 5] / 296.2 = 2.5 \\
 &= [739 - 5] / 296.2 = 2.5
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{CH}_4) &= \text{Area}(\text{CH}_4) / \text{RF}(\text{CH}_4) \\
 &= 48008 / 299.8 = 160.1 \\
 &= 47811 / 299.8 = 159.5 \\
 &= 47750 / 299.8 = 159.3
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{CO}_2) &= \text{Area}(\text{CO}_2) / \text{RF}(\text{CO}_2) - \text{CO}_2 \text{ Blank} \\
 &= 541702 / 308.0 - 3 = 1755.8 \\
 &= 540382 / 308.0 - 3 = 1751.5 \\
 &= 539508 / 308.0 - 3 = 1748.6
 \end{aligned}$$

$$\begin{aligned}\text{Cm(Noncondensibles)} &= \text{Area(Noncondensibles)} / \text{RF(Noncondensibles)} \\ &= 317948 / 286.6 = 1109.4 \\ &= 316295 / 286.6 = 1103.6 \\ &= 317645 / 286.6 = 1108.3\end{aligned}$$

$$\begin{aligned}\text{Cm(Condensibles)} &= \text{Area(Condensibles)} / \text{RF(Condensibles)} - \text{CO2 Blank} \\ &= 18295 / 308.0 - 3 = 56.4 \\ &= 18014 / 308.0 - 3 = 55.5 \\ &= 18002 / 308.0 - 3 = 55.4\end{aligned}$$

Pressure-Temperature Ratio, $Q(i) = P(i)/T(i)$ (mm Hg/K):

$$\begin{aligned}\text{Tank Presampling: } Q(2) &= 2.0 / 294.26 = 0.007 \\ \text{Tank Postsampling: } Q(1) &= 533.9 / 266.48 = 2.004 \\ \text{Tank Lab Receipt: } Q(5) &= 590.0 / 299.15 = 1.972 \\ \text{Tank Final: } Q(3) &= 1197.0 / 299.15 = 4.001 \\ \text{CV Final: } Q(4) &= 1528.0 / 299.15 = 5.108\end{aligned}$$

$$\begin{aligned}\text{Volume Sampled (dscm)} &= 0.3857 \times \text{Tank Volume} \times [Q(1) - Q(2)] \\ &= 0.3857 \times 0.008390 \times [2.004 - 0.007] \\ &= 0.006461\end{aligned}$$

Averages and % Relative Standard Deviations (%RSD) of Cm's are calculated.
(%RSD of C=%RSD of Cm)

Calculated Concentrations (ppmC):

$$\begin{aligned}\text{C(CO)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CO)} \\ &= 4.001 / (2.004 - 0.007) \times 2.5 = 5.0 \quad (<\text{RL of } 11)\end{aligned}$$

$$\begin{aligned}\text{C(CH}_4\text{)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CH}_4\text{)} \\ &= 4.001 / (2.004 - 0.007) \times 159.6 = 319.9\end{aligned}$$

$$\begin{aligned}\text{C(CO}_2\text{)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(CO}_2\text{)} \\ &= 4.001 / (2.004 - 0.007) \times 1752.0 = 3511.0\end{aligned}$$

$$\begin{aligned}\text{C(Noncondensibles)} &= Q(3) / [Q(1) - Q(2)] \times \text{Cm(Noncondensibles)} \\ &= 4.001 / (2.004 - 0.007) \times 1107.1 = 2218.7\end{aligned}$$

$$\begin{aligned}\text{C(Condensibles)} &= \text{Volume(CV)} / \text{Volume(Tank)} \times Q(4) / [Q(1) - Q(2)] \times \text{Cm(Condensibles)} \\ &= 0.008349 / 0.008390 \times 5.108 / (2.004 - 0.007) \times 55.8 = 142.0\end{aligned}$$

$$\begin{aligned}\text{Total Gaseous Non-Methane Organics (TGNMO)} &= \text{C(Noncondensibles)} + \text{C(Condensibles)} \\ &= 2218.7 + 142.0 \\ &= 2360.7\end{aligned}$$

$$\begin{aligned}\text{Mass Concentration (mgC/cu.m)} &= 0.4993 \times \text{TGNMO} \\ &= 0.4993 \times 2360.7 = 1178.7\end{aligned}$$

<RL of ### = Concentration Below Report Limit

Triangle Environmental Services, Inc.
METHOD 25 SAMPLE QA/QC DATA
Report #10195

DAILY RECOVERY SYSTEM CHECKS

11.1.1.1* Condensate Recovery System Leak Check

Evacuate system to ≤ 10 mm Hg absolute pressure, isolate system, and monitor for ten minutes.

Requirement: Pressure Change ≤ 3 mm Hg

11.1.1.2* Condensate Recovery System Background Test

Analyze recovery system effluent for CO_2 concentrations.

Requirement: $\text{CO}_2 \leq 10$ ppm

11.1.1.3* Condensate Oxidation Catalyst Efficiency Check (Initial Check: 10.1.1.2)

Analyze 1% methane standard through oxidation catalyst.

Requirement: $\text{CO}_2 = \text{CH}_4$ concentration $\pm 4\%$

DAILY ANALYZER CHECKS

10.2* Daily Calibration

Response Factor Checks

Requirement: Daily RF = Initial RF $\pm 10\%$

Triplicate injections of a mixture of CO , CH_4 , CO_2 , and C_3H_8 are made before and after each batch of samples.

See the individual sample data sheet for the daily response factor.

10.1.2.3* Initial Calibration/Linearity

Triplicate injections of a calibration gas is made for each compound at four levels:

	Nominal Concentrations (ppm)				Initial RF for Analyzer A 10/22/10	Initial RF for Analyzer B 11/29/10
CO	5	200	1000	5000	175.65	292.07
CH ₄	3	50	500	10,000	181.49	303.40
CO ₂	3	50	500	10,000	173.94	300.00
propane	2	20	3000	10,000	178.80	299.09

* USEPA Method 25 Protocol (2000) Reference Number

Report #10195

INITIAL CONDENSATE RECOVERY SYSTEM CHECKS**10.1.1.1* Carrier Gas and Auxiliary Gas Blank Check**Requirement: $\text{CO} + \text{CH}_4 + \text{CO}_2 + \text{NMO} \leq 5 \text{ ppm}$ **10.1.1.3* System Performance Check** March 1-8, 2000; Recovery Systems #1, 2, 3, 4

Volume Injected	Compound	Average % Recovery				% RSD			
50 μL	Hexane	101.0	102.0	98.8	104.6	0.058	0.101	1.680	0.229
50 μL	Decane	97.0	100.0	103.3	103.3	0.120	0.047	0.092	0.359
10 μL	Hexane	104.0	101.8	103.9	96.8	0.118	0.827	0.131	0.845
10 μL	Decane	98.0	97.0	99.6	99.0	0.119	0.232	1.360	0.092
Requirement:		100 \pm 5%				$\leq 2\%$			

INITIAL NMO ANALYZER PERFORMANCE CHECKS**10.1.2.1* Oxidation Catalyst Efficiency Check** Analyzer A, 4/8/98; Analyzer B, 4/21/98

FID response with reduction catalyst in bypass mode = 0, 0
 Requirement: $\leq 1\%$

10.1.2.2* Reduction Catalyst Efficiency Check Analyzer A, 4/8/98; Analyzer B, 4/21/98

Response of CH_4 with oxidation and reduction catalysts in series mode and response with both catalysts in bypass mode to be within 5% of the average:
 $1.05 \times \text{Average Response} > \text{Response} > 0.95 \text{ Average Response}$
 or Higher Response/Lower Response < 1.105263
 100.0%, 100.0% Requirement: $< 110.5\%$

Report #10195

10.1.2.3* Analyzer Linearity Check+NMO Calibration Analyzer A, 10/22/10; Analyzer B, 11/29/10

	$100 \times (1 - RF / RF_{\text{average}})$	Requirement:
max. dev. CO:	+1.876%, -1.989%	± 2.5%
max. dev. CH ₄ :	-1.775%, +2.455%	± 2.5%
max. dev. CO ₂ :	+1.738%, -2.176%	± 2.5%
max. dev. NMO:	+2.427%, -1.914%	± 2.5%
max. %RSD:	1.67%, 1.73%	≤ 2%
$\frac{RF(NMO)}{RF(CO_2)} =$	0.97, 1.00	1.0 ± 0.1

10.1.2.4* System Performance Check Analyzer A, 4/8/98; Analyzer B, 4/21/98, 5/1/98

	Measured Value, Expected Value		Requirement
	Analyzer A	Analyzer B	
Propane in Mix	19.6, 20.0	20.22, 20.0	± 5%
Hexane	50.6, 51.6	51.6, 51.6	± 5%
Toluene	20.3, 20.0	19.34, 20.0	± 5%
Methanol	104.5, 109.1	109.55, 109.0	± 5%

EQUIPMENT CHECKS

8.1.1* Clean Sampling Equipment Check

Sample Unit	ppmC totalDC	@ 100%
Trap	ppmC totalDC	@ 100%
Tank	ppmC NMO	@ 100%

8.1.2* Sample Tank Evacuation and Leak Check

Tank evacuated to ≤ 10 mm Hg absolute pressure, monitored for ≥ 1 hour, and passed for use if no pressure change (< 1 mm Hg/hr) is noted.

10.3* Sample Tank and ICV Volumes

Tank weighed empty, filled with deionized distilled water (temperature recorded), and weighed to the nearest 2 g. Volume calculated based on density of water at that temperature and results recorded in permanent file.

Triangle Environmental Services, Inc.

CALIBRATION DATA FOR THE ANALYSES

Client: Air/Compliance Consultants, Inc.

ID#10195

Project ID: ARG LO-CAT 09-160

Method 25

2-JAN-11: Analyzer B

Preanalysis Calibration


Compound	Conc.	Area(1)	Area(2)	Area(3)	Average	%RSD	RF	IRF	%Diff.
CO	200.5	59871	59266	59025	59387	0.7%	296.2	292.1	1.4%
CH4	49.1	14872	14747	14573	14731	1.0%	299.8	303.4	-1.2%
CO2	9950.0	3068108	3070163	3054688	3064320	0.3%	308.0	300.0	2.7%
C2+	61.7	17728	17796	17478	17667	0.9%	286.6	299.1	-4.2%

Postanalysis Calibration

Compound	Conc.	Area(1)	Area(2)	Area(3)	Average	RF(post)	RF(pre)	%Diff
CO	200.5	59749	59346	59437	59511	296.8	296.2	0.2%
CH4	49.1	14672	14497	14577	14582	296.8	299.8	-1.0%
CO2	9950.0	3059040	3052410	3051919	3054456	307.0	308.0	-0.3%
C2+	61.7	17792	17634	17565	17664	286.5	286.6	-0.0%

Sample #	1	259	/	BRT
	2	114	/	ALX
	3	251	/	AET

Conc. = concentration in ppmC, %RSD = % relative standard deviation,
 RF = response factor = Average Area/Conc., IRF = response factor from initial calibration,
 %Diff. = $\frac{RF-IRF}{IRF}$ for preanalysis = $\frac{RF(post)-RF(pre)}{RF(pre)}$, C2+ = propane



Title :
Run File : C:\STAR\RECALCB\TES_B896.RUN
Method File : C:\STAR\RECALCB.MTH
Sample ID : 1- P mix CC61467

Injection Date: 2-JAN-11 5:55 PM Calculation Date: 3-JAN-11 11:39 AM

Operator : Detector Type: ADCB (10 Volts)
Workstation: VOLUME 1 Bus Address : 16
Instrument : Varian Star #1 Sample Rate : 10.00 Hz
Channel : A = M25 Run Time : 16.002 min

***** Star Chromatography Workstation ***** Version 4.5 *****

Run Mode : Analysis - Subtract Blank Baseline
Peak Measurement: Peak Area
Calculation Type: External Standard

Peak No.	Peak Name	Result ()	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	CO	242.0294	2.013	0.043	59871	BV	4.4	C
2	CH4	59.4701	2.294	0.094	14872	VB	5.0	C
3		0.0000	2.526	0.000	10	TS	0.0	
4	CO2	12270.9580	3.478	-0.122	3068108	BB	11.4	C
5		0.0000	6.293	0.000	50	TS	0.0	
6	C2+	70.7644	11.500	-0.050	17728	GR	0.0	U
Totals:		12643.2219		-0.035	3160639			

Status Codes:

J - User-defined peak endpoint(s)
C - Out of calibration range

Total Unidentified Counts : 61 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 4

Multiplier: 1 Divisor: 1

Baseline Offset: 8 microVolts

Noise (used): 100 microVolts - monitored before this run

Could not format the injection information for this run.
Install the driver for the module at address 17 (type 8) to format this data.

Calib. out of range; No Recovery Action Specified


Error Log:

Could not format the error log for the module at address 17 (type 8).
Install the appropriate module driver to format this data.

ADC Board:

Original Notes:

Appended Notes:



Title :
 Run File : C:\STAR\RECALCB\TES_B907.RUN
 Method File : C:\STAR\AUTOSAM.MTH
 Sample ID : 2- tank 259

Injection Date: 2-JAN-11 9:16 PM Calculation Date: 2-JAN-11 9:32 PM

Operator : Detector Type: ADCB (10 Volts)
 Workstation: VOLUME 1 Bus Address : 16
 Instrument : Varian Star #1 Sample Rate : 10.00 Hz
 Channel : A = M25 Run Time : 16.002 min

***** Star Chromatography Workstation ***** Version 4.5 *****

Run Mode : Analysis - Subtract Blank Baseline
 Peak Measurement: Peak Area
 Calculation Type: External Standard

Peak No.	Peak Name	Result ()	Ret. Time (min)	Time Offset (min)	Area (counts)	Sep. Code	Width 1/2 (sec)	Status Codes
1	CO	2.9866	2.022	0.052	739	BP	4.5	
2	CH4	191.9787	2.297	0.097	48008	PB	5.0	C
3	CO2	2166.5496	3.500	-0.100	541702	BB	11.4	
4		0.0000	5.213	0.000	76	TS	0.0	
5	C2+	1269.1534	11.500	-0.050	317948	GR	0.0	UC
Totals:		3630.6683		-0.001	908473			

Status Codes:
 J - User-defined peak endpoint(s)
 } - Out of calibration range

Total Unidentified Counts : 76 counts

Detected Peaks: 6 Rejected Peaks: 0 Identified Peaks: 4

Multiplier: 1 Divisor: 1

Baseline Offset: -2 microVolts

Noise (used): 70 microVolts - monitored before this run

Could not format the injection information for this run.
 Install the driver for the module at address 17 (type 8) to format this data.

Calib. out of range; No Recovery Action Specified

Error Log:

Could not format the error log for the module at address 17 (type 8).
 Install the appropriate module driver to format this data.

ADC Board:

Original Notes:

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: Air/Compliance Consultants, Inc.

ID#10195 Analyzed: 1/1-2/11

Project ID: ARG LO-CAT 09-160

Sample # 1 Run 1 ARG LO-CAT

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	2.0	294.26	0.007	Tank 259:
Postsampling	533.9	266.48	2.004	Tank Volume = 0.008390 cu.m
Lab Receipt	590.0	299.15	1.972	Volume Sampled = 0.006461 dscm
Tank Final	1197.0	299.15	4.001	<u>Lab Receipt P/T</u> = 0.984
CV Final	1528.0	299.15	5.108	<u>Postsampling P/T</u>
				Trap BRT →
				Collection Vessel 14:
				CV Volume = 0.008349 cu.m

Response Factors (RF), Report Limits (RL), and Area Counts:

	RF (area/ppmC)	RL (ppmC)	Area 1	Area 2	Area 3
CO	296.2	11	739	743	739
CH4	299.8	7	48,008	47,811	47,750
CO2	308.0	7	541,702	540,382	539,508
Noncondensibles	286.6	5	317,948	316,295	317,645
Condensibles	308.0	8	18,295	18,014	18,002

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.6%

CO Blank = 5 area counts CO2 Blank = 3 ppm

Concentrations:

*=corrected for Blank	ppmC			%RSD
	Amount	±	SD	
CO*	< 11			
CH4	320	±	1	0.3
CO2*	3511	±	7	0.2
Noncondensibles	2219	±	6	0.3
Condensibles*	142	±	1	1.0
TGNMO	2361			

Mass Concentration 1179 mgC/cu.m

< # = Concentration Below Report Limit

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: Air/Compliance Consultants, Inc.

ID#10195 Analyzed: 1/1-2/11

Project ID: ARG LO-CAT 09-160

Sample # 2 Run 2 ARG LO-CAT

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	2.0	294.26	0.007	Tank 114:
Postsampling	520.7	266.48	1.954	Tank Volume = 0.008335 cu.m
Lab Receipt	566.0	299.15	1.892	Volume Sampled = 0.006259 dscm
Tank Final	1285.0	299.15	4.296	<u>Lab Receipt P/T</u>
CV Final	1440.0	299.15	4.814	Postsampling P/T = 0.968
				Trap ALX →
				Collection Vessel 29:
				CV Volume = 0.008369 cu.m

Response Factors (RF), Report Limits (RL), and Area Counts:

	RF (area/ppmC)	RL (ppmC)	Area 1	Area 2	Area 3
CO	296.2	12	699	642	665
CH4	299.8	7	42,680	42,556	42,121
CO2	308.0	7	363,739	367,155	365,200
Noncondensibles	286.6	5	277,969	278,563	277,622
Condensibles	308.0	8	17,845	17,781	18,088

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 102.7%

CO Blank = 5 area counts CO2 Blank = 3 ppm

Concentrations:

	Amount	±	SD	%RSD
*=corrected for Blank				
CO*	< 12			
CH4	312	±	2	0.7
CO2*	2610	±	12	0.5
Noncondensibles	2140	±	4	0.2
Condensibles*	137	±	1	1.0
TGNMO	2277			

Mass Concentration 1137 mgC/cu.m

< # = Concentration Below Report Limit

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: Air/Compliance Consultants, Inc.

ID#10195 Analyzed: 1/1-2/11

Project ID: ARG LO-CAT 09-160

Sample # '3 Run'3 ARG LO-CAT

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	2.0	294.26	0.007	Tank 251:
Postsampling	533.4	265.37	2.010	Tank Volume = 0.008381 cu.m
Lab Receipt	597.0	299.15	1.996	Volume Sampled = 0.006475 dscm
Tank Final	1185.0	299.15	3.961	<u>Lab Receipt P/T</u> = 0.993
CV Final	1435.0	299.15	4.797	Postsampling P/T
				Trap AET →
				Collection Vessel 148:
				CV Volume = 0.008367 cu.m

Response Factors (RF), Report Limits (RL), and Area Counts:

	RF (area/ppmC)	RL (ppmC)	Area 1	Area 2	Area 3
CO	296.2	10	881	874	885
CH4	299.8	6	48,940	48,601	48,488
CO2	308.0	6	213,215	212,578	211,980
Noncondensibles	286.6	4	306,327	304,632	304,454
Condensibles	308.0	8	23,923	23,198	23,376

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 102.6%

CO Blank = 5 area counts CO2 Blank = 3 ppm

Concentrations:

	Amount	±	SD	%RSD
*=corrected for Blank	< 10			
CO*	321	±	2	0.5
CH4	1359	±	4	0.3
CO2*	2105	±	7	0.3
Noncondensibles	175	±	3	1.7
Condensibles*	2281			
TGNMO				

Mass Concentration 1139 mgC/cu.m

< # = Concentration Below Report Limit

Chain of Custody

Triangle Environmental Services, Inc.

LABORATORY SAMPLE INFORMATION AND CHAIN-OF-CUSTODY FORM

Company Name: <u>Air Compliance Consultants, Inc.</u>		Project/Client ID: <u>AR6 LO-CAT 09-160</u>		Date: <u>12-9-10</u>
Contact Person: <u>Eric S. White</u>		Phone #: <u>1-412-826-3636</u>		Process Type: <u>De Sulfurization</u>
Latest Date Complete Set of Samples Expected at Lab: <u>12-13-10</u>		Results Due Date: <u>Normal</u>		Extra charge will apply for rush results
Note: Normal Turnaround is 15 working days after receipt of complete set of samples		Report Package Due Date: <u>Normal</u>		
Send Report to:		Send Invoice to:		
Person <u>Eric S. White</u>		Person <u>Ten Hartman</u>		
Company <u>Air Compliance Consultants, Inc.</u>		Company <u>Same as Report address</u>		
Address <u>1050 William Pitt Way</u>		Address		
<u>Pittsburgh, Pa 15238</u>		PO#		
Phone # <u>412-826-3636</u>		FAX # <u>412-826-3640</u>		

Analysis

✓ all applicable boxes

US EPA: <input checked="" type="checkbox"/> Method 25		<input type="checkbox"/> Method 3-C		<input type="checkbox"/> Method 25-C (NMOC as C [de fault])		<input type="checkbox"/> Method 10-B		SCAQMD: <input type="checkbox"/> Method 25.1 <input type="checkbox"/> Method 25.2	
# of Tank & Trap Samples: <u>6</u>		# of Tank-Only Samples: <u>3</u>		# of Trap-Only Samples: <u>3</u>		# of Bag Samples: <u>0</u>			
<input type="checkbox"/> Audit with Delay (extra charge)		<input type="checkbox"/> Rush Turnaround (extra charge)		<input checked="" type="checkbox"/> High Concentrations Possible		<input type="checkbox"/> Dilute High Concentrations (extra charge)			

Special Instructions:

Tanks for Analysis (Bags) (List IDs): <u>114, 251, 259</u>	Traps for Analysis (List IDs): <u>ALX, AET, BBT</u>
--	---

<input checked="" type="checkbox"/> TES Equipment	<input type="checkbox"/> Client Equipment
Tanks, Unused for Reconditioning (List IDs): <u>106</u>	
<input type="checkbox"/> Client Equipment to be Reconditioned	
Traps, Unused for Reconditioning (List IDs): <u>ATD</u>	

Relinquished by: <u>[Signature]</u>	Date: <u>12-9-10</u>	Time: <u>12:10</u>
Tanks received at TES by: <u>[Signature]</u>	Condition: <u>good</u>	Date: <u>12-13-10</u>
Tanks received at TES by: <u>[Signature]</u>	Condition: <u>good</u>	Date: <u>12-10-10</u>
		Time: <u>9:30</u>

APPENDIX D

Quality Assurance/Quality Control Data

Air/Compliance Consultants, Inc. (ACCI)

Thermocouple Calibration Data Sheet

Probe I.D.: 4'-1

Dry Gas Meter I.D.: 1595

Standard Used: NIST Certified Thermocouple
Probe ID # 920213

Temperature Scale: °F

Converted to: °R (Equation= 460 + °F result)


Post Test

Temperature Range	Reference Thermometer (°R)	Probe Thermometer (°R)	Absolute Temperature Difference (%)
Ice Bath	490	490	0
Room Temp.	525	525	0
Stack Temp.	582	580	0.3

Criteria are:


The Absolute Temperature Difference within 1.5% of Reference Standard used.

Section 10.3.2 of USEPA Method 2


Checked by:  12/9/10
(Signature / Date)

Air/Compliance Consultants, Inc. (ACCI)


Type S Pitot Tube Inspection Data Sheet





Degree indicating level position for determining α_1 and α_2 .




Degree indicating level position for determining β_1 and β_2 .



Degree indicating level position for determining θ .



Degree indicating level position for determining γ then calculate Z.



Allowable Range/Parameter	Pre-Test Value	Post-Test Value
Level and perpendicular?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
Obstruction?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
Damaged?	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
α_1 $(-10^\circ < \alpha_1 < +10^\circ)$	0	0
α_2 $(-10^\circ < \alpha_2 < +10^\circ)$	0	0
β_1 $(-5^\circ < \beta_1 < +5^\circ)$	0	0
β_2 $(-5^\circ < \beta_2 < +5^\circ)$	0	0
γ $(-2^\circ < \alpha_1 < +2^\circ)$	0	0
θ $(-1^\circ < \alpha_1 < +1^\circ)$	0	0
A (for 1/4" OD, 0.526 to 0.750 for 3/8" OD, 0.788 to 1.125)	.644	.644
Z = $A \sin \gamma (\leq 0.125")$	0	0
W = $A \sin \theta (\leq 0.03125")$	0	0
P_A (for 1/4" OD, 0.263 to 0.375 for 3/8" OD, 0.394 to 0.563)	.320	.320
P_B (for 1/4" OD, 0.263 to 0.375 for 3/8" OD, 0.394 to 0.563)	.324	.324
$P_A - P_B$ $(-0.063 \text{ to } 0.063")$	-.004	-.004
P_A/D_t (1.05 to 1.50)	1.285	1.285
P_B/D_t (1.05 to 1.50)	1.301	1.301
D_T $(3/16" \leq D_t \leq 3/8")$.249	.249

Certification:

I certify that the Type S Pitot Tube/Probe ID# 41-1 calibrated by Caliper ID # CAL-5 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a Pitot tube calibration factor C_p of 0.84.

Checked by:

[Signature]

(Signature / Date)

12/8/10

Air Compliance Consultants, Inc.

EPA Method 5

Meter Box Calibration

Pre-Test Orifice Method

English Meter Box Units, English K' Factor

Apex Orifices

	Previous Cal	New Cal	% Difference
Y	1.003	1.007	0.405
dH	1.766	1.760	0.351

Model #: C-5000

Serial #: 1595

Date: 10/28/10 80.00

Barometric Pressure: 29.31 (in. Hg)

Theoretical Critical Vacuum: 13.83 (in. Hg)

!!!!!!!

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

IMPORTANT The Critical Orifice Coefficient K' must be entered in English units, (ft³/(deg R)^{0.5}/(in.Hg)^{0.5}(min)).

!!!!!!!

- DRY GAS METER READINGS -										- CRITICAL ORIFICE READINGS -					
dH (in H2O)	Time (min)	Volume		Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	- Ambient Temperature -				
		Initial (cu ft)	Final (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)		
0.50	17.00	90.805	97.968	76.0	72.0	75.0	73.0	47	0.3241	21.5	69.0	70.0	69.5		
0.92	13.00	64.500	71.883	69.0	66.0	71.0	68.0	55	0.4409	20.0	69.0	69.0	69.0		
1.65	10.00	110.500	118.008	81.0	74.0	81.0	74.0	67	0.5737	18.5	70.0	70.0	70.0		
3.15	10.00	80.500	101.44	75.0	69.0	79.0	71.0	73	0.7830	16.5	69.0	69.0	69.0		
4.65	10.00	98.072	110.363	74.0	73.0	82.0	74.0	81	0.9440	15.5	70.0	70.0	70.0		

RESULTS

- DRY GAS METER -		- ORIFICE -	
VOLUME CORRECTED		VOLUME NOMINAL	
Vm(std) (cu ft)	Vm(std) (liters)	Vcr (cu ft)	Vcr (liters)
6.944	196.7	7.018	198.7
7.239	205.0	7.304	206.9
7.252	205.4	7.304	206.9
9.908	280.6	9.978	282.6
12.000	339.8	12.018	340.4

- DRY GAS METER -			- ORIFICE -		
CALIBRATION FACTOR			CALIBRATION FACTOR		
Y	Value (number)	Variation (number)	dH@	Value (mm H2O)	Variation (in H2O)
	1.011	0.004		1.681	-0.079
	1.009	0.002		1.684	-0.076
	1.007	0.000		1.771	0.011
	1.007	0.000		1.818	0.058
	1.002	-0.006		1.845	0.085

Avg Y--> 1.007 Avg dH@--> 1.760 44.70

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED:

Date: 10-29-10

Alternative Method 5 Post-Test Calibration Check			
Client:	ARG		
Facility:	Bradford, PA		
Source ID:	LO Cat Desulf		
Project Number:	09-160		
Date:	12/8/2010		
Control Box ID:	1595		
	Run 1	Run 2	Run 3
<u>Data Input</u>			
Test time (min)	30	30	30
Volume Dry Gas Metered (dacf)	22.127	22.048	22.355
Meter Temperature (F)	41.5	44.3	44.0
Barometric Pressure (in. Hg)	28.50	28.50	28.50
Orifice Pressure Drop (in. H ₂ O)	1.70	1.70	1.70
Dry Gas Molecular Weight (lb/lb mol)	28.84	28.84	28.84
Original Meter Correction Value	1.007	1.007	1.007
Meter DH _@ (in. H ₂ O)	1.76	1.76	1.76
<u>Calculated Values</u>			
Dry Gas Meter Calibration check value (Y _{qa})	0.999	1.005	0.991
Percent Difference (%)	-0.81%	-0.17%	-1.58%
<u>Results</u>			
Average Dry Gas Meter Calibration Check Val	0.998		
Original Meter Correction Value (Y _{orig})	1.007		
Percent Difference (%)	-0.85%	Pass	
Test conducted in accordance with EMC ALT-009 - Allowable ±5% $Y_{qa} = (\text{time}/\text{dacf}) * (\text{sqrt}((0.0319 * (T_m + 460)) / (DH_{@} * (P_{bar} + (DH_{avg}/13.6)))) * (29/M_d)) * \text{SQRT}(DH_{avg}))$			

**APEX INSTRUMENTS REFERENCE METER CALIBRATION
USING CRITICAL ORIFICE KIT
12-POINT ENGLISH UNITS**

Critical orifice information		
Orifice I.D.	Vacuum Needed	Part No.
Orifice #1	18" Hg/200 lpm	J-16-BR
Orifice #2	16.5" Hg/452 lpm	J-24-BR
Orifice #3	18" Hg/1,044 lpm	J-36-BR
Orifice #4	15" Hg/2,170 lpm	J-52-BR
Meter Gamma		1.00000

Red = Calculation; Do not change

Yellow = Entry Cell

Pink = Reference to another cell; Do not change

Blue = Do not change entry.

Calibration Conditions		
Date	Time	6-Dec-10
Barometric Pressure	29.5	in Hg
Calibration Technician	EW	
DGM Serial Number	8002649	

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K ₁	17.647	°R/in Hg

Calibration Data												Results		
Run Time	Dry Gas Meter						Calibration orifice theoretical results						Dry Gas Meter	
	Orifice Certification	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Volume Initial	Volume Final	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Calibration Value	Variation	Flowrate Std & Corr
Elapsed (s)		(V _{mf})	(V _{mf})	(t _{mf})	(t _{mf})	(V _{th})	(V _{th})	(t _{th})	(t _{th})	(t _{th})	(t _{th})	(Y)	(ΔY)	(Q _{measured})
min	lpm	lpm	lpm	°F	°F	lpm	lpm	°F	°F	°F	°F			cfm
10.00	0.200	0.000	2.121	78	78	0.000	2.000	78	78	0.9425	0.00177	0.9425	0.00177	0.193
10.00	0.200	2.121	4.245	79	80	0.000	2.000	79	80	0.9411	0.00044	0.9411	0.00044	0.193
10.00	0.200	4.245	6.375	80	82	0.000	2.000	80	82	0.9385	-0.00221	0.9385	-0.00221	0.192
												0.9407	Averages	0.193
10.00	0.452	0.000	4.785	82	83	0.000	4.520	82	83	0.9436	0.00000	0.9436	0.00000	0.433
10.00	0.452	4.785	9.564	83	83	0.000	4.520	83	83	0.9447	0.00118	0.9447	0.00118	0.433
10.00	0.452	9.564	14.355	84	84	0.000	4.520	84	84	0.9424	-0.00118	0.9424	-0.00118	0.432
												0.9436	Averages	0.432
5.00	1.044	0.000	5.300	84	85	0.000	5.220	84	85	0.9823	-0.00242	0.9823	-0.00242	0.996
5.00	1.044	5.300	10.597	85	85	0.000	5.220	85	85	0.9829	-0.00187	0.9829	-0.00187	0.996
5.00	1.044	10.597	15.861	85	86	0.000	5.220	85	86	0.9891	0.00429	0.9891	0.00429	0.995
												0.9848	Averages	0.996
5.00	2.170	0.000	10.498	86	87	0.000	10.850	86	87	1.0280	0.00153	1.0280	0.00153	2.064
5.00	2.170	10.498	21.010	87	87	0.000	10.850	87	87	1.0286	0.00016	1.0286	0.00016	2.062
5.00	2.170	21.010	31.541	87	87	0.000	10.850	87	87	1.0247	-0.00169	1.0247	-0.00169	2.062
												1.0264	Averages	2.062

Overall Average Y **0.9739**

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using the Precision Wet Test Meter # 11AE6, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature

Date

12-6-10

**APEX INSTRUMENTS REFERENCE METER CALIBRATION
USING CRITICAL ORIFICE KIT
12-POINT ENGLISH UNITS**

Critical orifice information		
Orifice I.D.	Vacuum Needed	Part No.
Orifice #1	18" Hg/200 lpm	J-16-BR
Orifice #2	16.5" Hg/452 lpm	J-24-BR
Orifice #3	18" Hg/1,044 lpm	J-36-BR
Orifice #4	15" Hg/2,170 lpm	J-52-BR
Meter Gamma		1.00000

Red = Calculation; Do not change

Yellow = Entry Cell

Pink = Reference to another cell; Do not change

Blue = Do not change entry.

Calibration Conditions		
Date	Time	6-Dec-10
Barometric Pressure		29.5 in Hg
Calibration Technician		ESW
DGM Serial Number		8002640

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K ₁	17.647	°R/in Hg

Calibration Data										Results		
Run Time	Dry Gas Meter					Calibration orifice theoretical results					Dry Gas Meter	
	Orifice Certification	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Volume Initial	Volume Final	Outlet Temp Initial	Outlet Temp Final	Calibration Factor Value	Variation	Flowrate Std & Corr
Elapsed (S)		(V _{md}) lpm	(V _{md}) lpm	(t _{md}) °F	(t _{md}) °F	(V _{md}) lpm	(V _{md}) lpm	(t _{md}) °F	(t _{md}) °F	(Y)	(ΔY)	(Q _{meas/corr}) cfm
min												
10.00	0.200	0.000	2.103	70	70	0.000	2.000	70	70	0.9505	0.00463	0.196
10.00	0.200	2.103	4.214	73	74	0.000	2.000	73	74	0.9469	0.00103	0.195
10.00	0.200	4.214	6.340	76	77	0.000	2.000	76	77	0.9403	-0.00565	0.194
										0.9459	Averages	0.195
10.00	0.452	0.000	4.789	79	79	0.000	4.520	79	79	0.9428	0.00150	0.436
10.00	0.452	4.789	9.581	80	80	0.000	4.520	80	80	0.9422	0.00091	0.435
10.00	0.452	9.581	14.390	80	81	0.000	4.520	80	81	0.9388	-0.00242	0.435
										0.9413	Averages	0.435
5.00	1.044	0.000	5.455	82	83	0.000	5.220	82	83	0.9544	-0.00352	1.000
5.00	1.044	5.455	10.891	83	84	0.000	5.220	83	84	0.9578	-0.00019	0.998
5.00	1.044	10.891	16.305	84	85	0.000	5.220	84	85	0.9617	0.00371	0.996
										0.9580	Averages	0.998
5.00	2.170	0.000	11.201	85	85	0.000	10.850	85	85	0.9634	-0.00236	2.069
5.00	2.170	11.201	22.364	86	87	0.000	10.850	86	87	0.9667	0.00092	2.064
5.00	2.170	22.364	33.521	87	87	0.000	10.850	87	87	0.9672	0.00144	2.062
										0.9658	Averages	2.065

Overall Average Y **0.9527**

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using the Precision Wet Test Meter # 11AE6, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature

Date

12-6-10

SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual

LET IT BE KNOWN THAT

ERIC S. WHITE

HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED
EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES
ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR

GASEOUS POLLUTANTS INSTRUMENTAL SAMPLING METHODS


ISSUED THIS 2ND DAY OF APRIL 2008 AND EFFECTIVE UNTIL APRIL 1ST, 2013


Peter R. Westlin, QSTI/QSTO Review Board



Glenn C. England, QSTI/QSTO Review Board


John R. Smith, QSTI/QSTO Review Board



Leroy C. Owens, QSTI/QSTO Review Board


C. David Bagwell, QSTI/QSTO Review Board

APPLICATION
NO.
2008-134



SOURCE EVALUATION SOCIETY



Qualified Source Testing Individual


LET IT BE KNOWN THAT

TODD A. HAAS


HAS SUCCESSFULLY PASSED A COMPREHENSIVE EXAMINATION AND SATISFIED
EXPERIENCE REQUIREMENTS IN ACCORDANCE WITH THE GUIDELINES
ISSUED BY THE SES QUALIFIED SOURCE TEST INDIVIDUAL REVIEW BOARD FOR


**MANUAL GAS VOLUME MEASUREMENTS AND ISOKINETIC PARTICULATE
SAMPLING METHODS**


ISSUED THIS 23RD DAY OF FEBRUARY 2009 AND EFFECTIVE UNTIL FEBRUARY 22ND, 2014


Peter R. Westlin, QSTI/QSTO Review Board



Peter S. Pakamitis, QSTI/QSTO Review Board


C. David Bagwell, QSTI/QSTO Review Board


Karen D. Kalliya-Mills, QSTI/QSTO Review Board


John R. Smith, QSTI/QSTO Review Board

APPLICATION
NO.
2009-305



APPENDIX E

Plant Production Data

METHOD 11 H₂S TEST

TEST #1 Date: 12/8/2009		START		END		
Time (Actual)		12:46PM	1:01PM	1:16PM	1:31PM	1:46PM
Time (min.)		0	15	30	45	60
RFG Throughput (scfm)		991	937	932	847	853
						912

TEST #2 Date: 12/8/2009		START		END		
Time (Actual)		1:53PM	2:08PM	2:23PM	2:38PM	2:53PM
Time (min.)		0	15	30	45	60
RFG Throughput (scfm)		981	1059	1017	1034	974
						1013

TEST #3 Date: 12/8/2009		START		END		
Time (Actual)		3:00PM	3:15PM	3:30PM	3:45PM	4:00PM
Time (min.)		0	15	30	45	60
RFG Throughput (scfm)		799	905	991	940	900
						907

APPENDIX F

Sample Calculations

M25 Volatile Organic Compounds

ACCI SAMPLE CALCULATIONS

Flow, Moisture, THC

ARG

09-160

Bradford, PA

LO Cat Desulf

mnoc

December 8, 2010

V-204 Vessel Outlet

Run 1

1	Vf	328.0	ml	Tstandard	68	F
2	Vi	200.0	ml	Pstandard	760	mm Hg
3	Wf	241.2	g	K1method 4	0.04706	scf/ml
4	Wi	236.2	g	K2method 4	0.04715	scf/g
5	Vm	22.231	dacf	K1method 5	17.64	R/in. Hg
6	Vm	0.000	dry actual liters	K4method 5	0.0945	
7	Yd	1.0070		V/n _{standard}	385.3	ft ³ /lb-mole
8	Pbar	28.50	in. Hg	Kp	85.49	
9	dHavg	1.70	in. H ₂ O			
10	Tm	48.1	F	π	3.141593	
11	O ₂	20.25	% dv	Ds (or L)	8.00	inches
12	CO ₂	0.10	% dv	Stack Width (W)	NA	inches
13	Pg	0.16	in. H ₂ O	Tsavg	122.8	F
14	Cp	0.84		Product rate	1.67	hr/day
15	(dP) ^{1/2} avg	0.297	in. H ₂ O ^{1/2}	F _d	na	dscf/MMBtu

17	TEST DATA		Total Hydrocarbons			
18	TGNMO as Carbon	2361	ppmdv			
19	TGNMO as Propane	787.00	ppmdv	Methane	320.00	ppm _{dv}
20	O ₂ Correction	7.0	%	Ethane	304.90	ppm _{dv}
21	MW Propane	44	lb/lb-mole			
22	MW Carbon	12	lb/lb-mole			

25	Volume of Water Vapor Condensed (Vwc)				
26	Vwc(std) = K1method 4 * (Vf - Vi)				
27	K1method 4=	0.04706	scf/ml		
28	Vf=	328.0	ml		
29	Vi=	200.0	ml		
30	Vwc(std)=	6.024	scf		

33	Volume of Water Vapor Collected in Silica Gel (Vwsg)				
34	Vwsg(std) = K2method 4 * (Wf - Wi)				
35	K2method 4=	0.04715	scf/g		
36	Wf=	241.2	g		
37	Wi=	236.2	g		
38	Vwsg(std)=	0.236	scf		

40	Total Volume of Water Vapor in Gas Sample (Vw)				
41	Vw(std) = Vwc(std) + Vwsg(std)				
42	Vwc(std)=	6.024	scf		
43	Vwsg(std)=	0.236	scf		
44	Vw(std)=	6.259	scf		

46

47

48 Volume of Gas Metered

49 $V_m = \text{Volume metered in dacf} + \text{Volume metered in dry actual liters} * (1 \text{ cf} / 28.317 \text{ liters})$

50 Volume metered in dacf= 22.231 dacf

51 Volume metered in dry actual liters= 0.000 dry actual liters

52 $V_m =$ 22.231 dacf

53

54 $V_m(m^3) = V_m * (1 \text{ m}^3 / 35.3145 \text{ cf})$

55 $V_m =$ 22.231 dacf

56 $V_m(m^3) =$ 0.630 dscm

57

58 Volume of Gas Metered , dry basis, STD

59 $V_m(std) = (K1method 5 * V_m * Y_d * (P_{bar} + (dH_{avg}/13.6))) / (T_m + 460)$

60 K1method 5= 17.64 R/in. Hg

61 $V_m =$ 22.231 dacf

62 $Y_d =$ 1.0070

63 $P_{bar} =$ 28.50 in. Hg

64 $dH_{avg} =$ 1.70 in. H2O

65 $T_m =$ 48.1 F

66 $V_m(std) =$ 22.249 dscf

67

68 $V_m(std)m^3 = V_m(std) * (1 \text{ m}^3 / 35.3145 \text{ cf})$

69 $V_m(std) =$ 22.249 dscf

70 $V_m(std)m^3 =$ 0.630 dscm

71

72 Water Vapor in the Gas Stream

73 Bws used = the lower of $SP_{H_2O@T_{savg}} / P_s$

74 and $V_w(std) / (V_m(std) + V_w(std))$

75

76 $Bws =$ $SP_{H_2O@T_{savg}} / P_s$ With a maximum allowable value of 1.0

77 $SP_{H_2O@T_{savg}} =$ The saturation pressure of water at stack temperature

78 1997 ASHRAE Handbook page 6.2 Eq. (6)

79 $EXP(C_8/T + C_9 + C_{10}*T + C_{11}*T^2 + C_{12}*T^3 + C_{13}*\ln(T)) * (29.921/14.696)$

80 $T = T_{savg} + 459.67$

81 $T_{savg} =$ 122.8 F

82 $T =$ 582.4 R

83 $C_8 =$ -1.044040E+04

84 $C_9 =$ -1.1294650E+01

85 $C_{10} =$ -2.702236E-02

86 $C_{11} =$ 1.289036E-05

87 $C_{12} =$ -2.478068E-09

88 $C_{13} =$ 6.545967E+00

89 $SP_{H_2O@T_{savg}} =$ 3.72 in. Hg

90 $P_s =$ 28.51 in. Hg

91 $Bws =$ 0.1306 vol. fraction

92

93 $Bws = V_w(std) / (V_m(std) + V_w(std))$

94 $V_w(std) =$ 6.259 scf

95 $V_m(std) =$ 22.249 dscf

96 $Bws =$ 0.2196 vol. fraction

97

98 $Bws \text{ used} =$ 0.1306 vol. fraction

99

100 Carbon Monoxide and Nitrogen in gas

101 $CO + N_2 = 100 - (CO_2 + O_2)$

102 $CO_2 =$ 0.10 % dv

103 $O_2 =$ 20.25 % dv

104 $CO + N_2 =$ 79.65 % dv

105

106		
107		
108	Molecular weight of dry gas stream	
109	$Md = 0.44 * CO2 \%dv + 0.32 * O2 \%dv + 0.28 * (CO + N2 \%dv)$	
110	CO2=	0.10 % dv
111	O2=	20.25 % dv
112	CO + N2=	79.65 % dv
113	Md=	28.83 lb/lb-mole
114		
115	Molecular weight of wet gas stream	
116	$Ms = Md * (1 - Bws) + 18 * Bws$	
117	Md=	28.83 lb/lb-mole
118	Bws=	0.1306 vol. fraction
119	Ms=	27.41 lb/lb-mole
120		
121	Stack Pressure	
122	$Ps = Pbar + Pg/13.6$	
123	Pbar=	28.50 in. Hg
124	Pg=	0.16 in. H2O
125	Ps=	28.51 in. Hg
126		
127	Average Stack Gas Velocity	
128	$Vs = Kp * Cp * (dP)^{1/2}_{avg} * ((Ts_{avg} + 460) / (Ps * Ms))^{1/2}$	
129	Kp=	85.49
130	Cp=	0.84
131	$(dP)^{1/2}_{avg}$ =	0.2973 in. H2O ^{1/2}
132	Tsavg=	122.8 F
133	Ps=	28.51 in. Hg
134	Ms=	27.41 lb/lb-mole
135	Vs=	18.44 ft/s
136		
137	Area of the Stack	If W = 0, the stack is circular.
138		Circular
139		$As = PI * (Ds)^2 / 4 * (1 \text{ ft} / 12 \text{ in.})^2$
140	PI=	3.141593
141	Ds=	8.00 inches
142	As=	0.35 ft2
143		
144	Rectangular	
145		$As = L * W * (1 \text{ ft} / 12 \text{ in.})^2$
146	L=	0.00 inches
147	W=	NA inches
148	As=	0.00 ft2
149		
150	Stack Gas Flow Rate, Actual	
151	$Q_{acfm} = Vs * As * 60$	
152	Vs=	18.44 ft/s
153	As=	0.35 ft2
154	Qacfm=	386 acfm
155		
156	$Q_{acm/min} = Q_{acfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
157	Qacfm=	386 acfm
158	Qacm/min=	11 acm/min
159		

160		
161		
162	Stack Gas Flow Rate, Standard	
163	$Q_{scfm} = Q_{acfm} * ((T_{standard} + 460) / (T_{avg} + 460)) * (P_s / P_{standard})$	
164	$Q_{acfm} =$	386 acfm
165	$T_{standard} =$	68 F
166	$T_{avg} =$	122.8 F
167	$P_s =$	28.51 in. Hg
168	$P_{standard} =$	29.92 in. Hg
169	$Q_{scfm} =$	333 scfm
170		
171	$Q_{scm/min} = Q_{scfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
172	$Q_{scfm} =$	333 scfm
173	$Q_{scm/min} =$	9 scm/min
174		
175	Stack Gas Flow Rate, Dry Standard	
176	$Q_{dscfm} = Q_{scfm} * (1 - B_{ws})$	
177	$Q_{scfm} =$	333 scfm
178	$B_{ws} =$	0.1306 vol. fraction
179	$Q_{dscfm} =$	290 dscfm
180		
181	$Q_{dscm/min} = Q_{dscfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
182	$Q_{dscfm} =$	290 dscfm
183	$Q_{dscm/min} =$	8 dscm/min
192		
193	Total Gaseous Non-Methane Organics (TGNMO) as Carbon converted to as Propane	
194	TGNMO as Propane = TGNMO as C ppm _{dv} /3	
195	Ethane as Propane = Ethane /1.5	
196		
197	TGNMO as Carbon	2361 ppm _{dv}
198	TGNMO as Propane	787.00 ppm _{dv}
199	Ethane Concentration	304.90 ppm _{dv}
200	Ethane Conc. As Propane	203.27 ppm _{dv}
201	NMEVOC Concentration as Propane	583.73 ppm _{dv}
202		
210		
211	NMEVOC emission rate as Propane (lb/hr)	
212	$THC(lb/hr) = C_{THC} / 1,000,000 * Q_{dscfm} * (60 \text{ min} / 1 \text{ hour}) / V/n_{standard} * Propane_{MW}$	
213	NMEVOC Concentration as Propane =	583.73 ppm _{dv}
214	$Q_{dscfm} =$	290 dscfm
215	$V/n_{standard} =$	385.3 ft ³ /lb-mole
216	Propane MW =	44.0 lb/lb-mole
217	NMEVOC Emission Rate as Propane =	1.16 lb/hr
219		

M11 Hydrogen Sulfide

ACCI SAMPLE CALCULATIONS

Flow, Moisture, Hydrogen Sulfide

ARG

09-160

Bradford, PA

LO Cat Desulf

mnoc

December 8, 2010

V-204 Vessel Outlet

Run 1

Vf	340.0	ml	Tstandard	68	F
Vi	200.0	ml	Pstandard	760	mm Hg
Wf	240.5	g	K1method 4	0.04706	scf/ml
Wi	238.3	g	K2method 4	0.04715	scf/g
	22.127	dacf	K1method 5	17.64000	R/in. Hg
	0.000	dry actual liters	K4method 5	0.09450	
Yd	1.0070		V/n _{standard}	385.3	ft ³ /lb-mole
Pbar	28.50	in. Hg	Kp	85.49	
dHavg	1.70	in. H ₂ O			
Tm	41.5	F	π	3.141593	
O ₂	20.70	% dv	Ds (or L)	8.00	inches
CO ₂	0.10	% dv	Stack Width (W)	NA	inches
Pg	0.15	in. H ₂ O	Dn	na	inches
Cp	0.84		Time	60	minutes
(dP) ^{1/2} avg	0.436	in. H ₂ O ^{1/2}	Tsavg	123.0	F
F _d	na	dscf/MMBtu	MW H ₂ S	34.08	lb/lb-mole

1. Volume of Water Vapor Condensed (Vwc)

$$Vwc(std) = K1method\ 4 * (Vf - Vi)$$

K1method 4= 0.04706 scf/ml

Vf= 340.0 ml

Vi= 200.0 ml

Vwc(std)= 6.588 scf

2. Volume of Water Vapor Collected in Silica Gel (Vwsg)

$$Vwsg(std) = K2method\ 4 * (Wf - Wi)$$

K2method 4= 0.04715 scf/g

Wf= 240.5 g

Wi= 238.3 g

Vwsg(std)= 0.104 scf

3. Total Volume of Water Vapor in Gas Sample (Vw)

$$Vw(std) = Vwc(std) + Vwsg(std)$$

Vwc(std)= 6.588 scf

Vwsg(std)= 0.104 scf

Vw(std)= 6.692 scf

4. Volume of Gas Metered

$V_m = \text{Volume metered in dacf} + \text{Volume metered in dry actual liters} * (1 \text{ cf} / 28.317 \text{ liters})$

Volume metered in dacf= 22.127 dacf

Volume metered in dry actual liters= 0.000 dry actual liters

$V_m = 22.127 \text{ dacf}$

$V_m(m^3) = V_m * (1 \text{ m}^3 / 35.3145 \text{ cf})$

$V_m = 22.127 \text{ dacf}$

$V_m(m^3) = 0.627 \text{ dscm}$

5. Volume of Gas Metered , dry basis, STD

$V_m(\text{std}) = (K1_{\text{method 5}} * V_m * Y_d * (P_{\text{bar}} + (dH_{\text{avg}}/13.6))) / (T_m + 460)$

$K1_{\text{method 5}} = 17.64 \text{ R/in. Hg}$

$V_m = 22.127 \text{ dacf}$

$Y_d = 1.0070$

$P_{\text{bar}} = 28.50 \text{ in. Hg}$

$dH_{\text{avg}} = 1.70 \text{ in. H}_2\text{O}$

$T_m = 41.5 \text{ F}$

$V_m(\text{std}) = 22.435 \text{ dscf}$

$V_m(\text{std})m^3 = V_m(\text{std}) * (1 \text{ m}^3 / 35.3145 \text{ cf})$

$V_m(\text{std}) = 22.435 \text{ dscf}$

$V_m(\text{std})m^3 = 0.635 \text{ dscm}$

6. Water Vapor in the Gas Stream

$B_{ws} \text{ used} = \text{the lower of } SP_{H_2O@T_{savg}} / P_s \text{ and } V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std}))$

$B_{ws} = SP_{H_2O@T_{savg}} / P_s$ With a maximum allowable value of 1.0

$SP_{H_2O@T_{savg}} =$ The saturation pressure of water at stack temperature

1997 ASHRAE Handbook page 6.2 Eq. (6)

$EXP(C_8/T + C_9 + C_{10}*T + C_{11}*T^2 + C_{12}*T^3 + C_{13}*\ln(T)) * (29.921/14.696)$

$T = T_{savg} + 459.67$

$T_{savg} = 123.0 \text{ F}$

$T = 582.7 \text{ R}$

$C_8 = -1.044040E+04$

$C_9 = -1.1294650E+01$

$C_{10} = -2.702236E-02$

$C_{11} = 1.289036E-05$

$C_{12} = -2.478068E-09$

$C_{13} = 6.545967E+00$

$SP_{H_2O@T_{savg}} = 3.75 \text{ in. Hg}$

$P_s = 28.51 \text{ in. Hg}$

$B_{ws} = 0.1315 \text{ vol. fraction}$

$$Bws = Vw(std) / (Vm(std) + Vw(std))$$

Vw(std)=	6.692 scf
Vm(std)=	22.435 dscf
Bws=	0.2298 vol. fraction

Bws used=	0.1315 vol. fraction
-----------	----------------------

7. Carbon Monoxide and Nitrogen in gas

$$CO + N_2 = 100 - (CO_2 + O_2)$$

CO ₂ =	0.10 % dv
O ₂ =	20.70 % dv
CO + N ₂ =	79.20 % dv

8. Molecular weight of dry gas stream

$$Md = 0.44 * CO_2 \%dv + 0.32 * O_2 \%dv + 0.28 * (CO + N_2 \%dv)$$

CO ₂ =	0.10 % dv
O ₂ =	20.70 % dv
CO + N ₂ =	79.20 % dv
Md=	28.84 lb/lb-mole

9. Molecular weight of wet gas stream

$$Ms = Md * (1 - Bws) + 18 * Bws$$

Md=	28.84 lb/lb-mole
Bws=	0.1315 vol. fraction
Ms=	27.42 lb/lb-mole

10. Stack Pressure

$$Ps = Pbar + Pg/13.6$$

Pbar=	28.50 in. Hg
Pg=	0.15 in. H ₂ O
Ps=	28.51 in. Hg

11. Average Stack Gas Velocity

$$Vs = Kp * Cp * (dP)^{1/2}_{avg} * ((Ts_{avg} + 460) / (Ps * Ms))^{1/2}$$

Kp=	85.49
Cp=	0.84
(dP) ^{1/2} _{avg} =	0.4364 in. H ₂ O ^{1/2}
Ts _{avg} =	123.0 F
Ps=	28.51 in. Hg
Ms=	27.42 lb/lb-mole
Vs=	27.06 ft/s

12. Area of the Stack

If W = 0, the stack is circular.

Circular

$$As = PI * (Ds)^2 / 4 * (1 ft / 12 in.)^2$$

PI=	3.141593
Ds=	8.00 inches
As=	0.35 ft ²

Rectangular
 $As = L * W * (1 \text{ ft} / 12 \text{ in.})^2$
 L= 0.00 inches
 W= NA inches
 As= 0.00 ft2

13. Stack Gas Flow Rate, Actual

$Q_{acfm} = V_s * As * 60$
 $V_s = 27.06 \text{ ft/s}$
 $As = 0.35 \text{ ft}^2$
 $Q_{acfm} = 567 \text{ acfm}$

$Q_{acm/min} = Q_{acfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 $Q_{acfm} = 567 \text{ acfm}$
 $Q_{acm/min} = 16 \text{ acm/min}$

14. Stack Gas Flow Rate, Standard

$Q_{scfm} = Q_{acfm} * ((T_{standard} + 460) / (T_{avg} + 460)) * (P_s / P_{standard})$
 $Q_{acfm} = 567 \text{ acfm}$
 $T_{standard} = 68 \text{ F}$
 $T_{avg} = 123.0 \text{ F}$
 $P_s = 28.51 \text{ in. Hg}$
 $P_{standard} = 29.92 \text{ in. Hg}$
 $Q_{scfm} = 489 \text{ scfm}$

$Q_{scm/min} = Q_{scfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 $Q_{scfm} = 489 \text{ scfm}$
 $Q_{scm/min} = 14 \text{ scm/min}$

15. Stack Gas Flow Rate, Dry Standard

$Q_{dscfm} = Q_{scfm} * (1 - B_{ws})$
 $Q_{scfm} = 489 \text{ scfm}$
 $B_{ws} = 0.1315 \text{ vol. fraction}$
 $Q_{dscfm} = 425 \text{ dscfm}$

$Q_{dscm/min} = Q_{dscfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 $Q_{dscfm} = 425 \text{ dscfm}$
 $Q_{dscm/min} = 12 \text{ dscm/min}$

16. Volume Metered Standardized

$V_{mstd} = V_m * Y_d * [(T_{std} * P_{bar}) / (T_m * P_{std})]$
 $V_m = 59.53 \text{ L}$
 $Y_d = 0.974$
 $T_{std} = 293.15 \text{ °K}$
 $P_{bar} = 723.90 \text{ mm. Hg}$
 $T_m = 290.65 \text{ °K}$
 $P_{std} = 760 \text{ mm. Hg}$
 $V_{mstd} = 55.70$

17. Hydrogen Sulfide Concentration (ppm)

$$CH_2S = 17040 * [(V_{IT} * N_I - V_{TT} * N_T)_{sample} - (V_{IT} * N_I - V_{TT} * N_T)_{blank}] / V_{mstd}$$

Sample		Blank	
V_{IT}	50.00 ml	V_{IT}	50.00 ml
N_I	0.01 g-eq/liter	N_I	0.01 g-eq/liter
V_{TT}	47.83 ml	V_{TT}	49.10 ml
N_T	0.01 g-eq/liter	N_T	0.01 g-eq/liter
CH ₂ S	3.89		
CH ₂ S = CH ₂ S * [24.45/34.07]			
CH ₂ S	2.74 ppm _{dv}		

18. Hydrogen Sulfide Emission Rate (lb/hr)

$$E_{H_2S} = E_{H_2S} * Q_{DSCFM} * 60 \text{ min/hr}$$

$E_{H_2S} =$	2.745E+00 ppm _{dv}
$Q_{DSCFM} =$	425 dscfm
$E_{H_2S} =$	0.006 lb/hr

Nomenclature

NOMENCLATURE

SYMBOL	DESCRIPTION
ACFM	- Actual cubic feet per minute
A_s	- Stack Area
AB	- Acetone Blank
AB1	- Acetone Blank Tare Weight 1
AB2	- Acetone Blank Tare Weight 2
ABF1	- Acetone Blank Final Weight 1
ABF2	- Acetone Blank Final Weight 2
AT1	- Acetone Rinse Tare Weight 1
AT2	- Acetone Rinse Tare Weight 2
A_n	- Nozzle Area
B_{wo}	- Moisture content of sample gas, measured impinger collection
B_{ws}	- Moisture content of sample gas, wet saturated
BTU	- British Thermal Units
C	- Carbon
C_3H_8	- Propane
Ca	- Acetone Blank Correction
C_M	- Average of initial and final system calibration bias check responses for the upscale gas, ppm
cf	- Cubic foot
C_{MA}	- Actual concentration of the upscale calibration gas, ppm
C_d	- Concentration of Particulate Emissions
C_O	- Average of initial and final system calibration bias check responses for the zero gas, ppm
CO	- Carbon monoxide
CO ₂	- Carbon dioxide
C_p	- Pitot co-efficient, 0.84 for S-type, 0.99 for standard (English units)
E_{NOX}	- Emission rate of Oxides of nitrogen as NO ₂ , lb/hr
DACF	- Dry actual cubic feet
DSCF	- Dry standard cubic feet
DACM	- Dry actual cubic meters
DSCFM	- Dry standard cubic feet per minute
dscf/MMBtu	- Dry standard cubic feet per Million British Thermal Units (units for Fd)
D_s	- Stack diameter
D_N	- Nozzle diameter
°F	- Degrees Fahrenheit
ft	- foot
F1	- Filter Final Weight 1
F2	- Filter Final Weight 2
FT1	- Filter Tare Weight 1
FT2	- Filter Tare Weight 2
F_c	- CO ₂ based F-Factor for natural gas (1,040 SCF/MMBtu)
F_d	- F-factor
Ft^2	- Square feet
Ft^3	- Cubic feet
FTIR	- Fourier Transform Infrared
ft ³ /lb-mole	- Cubic feet per pound mole
ft/sec	- Feet per second
g	- Grams
g/mL	- Gram per milliliter
gr/DSCF	- Grains per dry standard cubic feet

HI	-	Heat Input
ΔH_{avg}	-	Average pressure drop across the meter box during test run, inches H ₂ O
H ₂ O	-	Water
Hg	-	Mercury
hr	-	Hour
in Hg	-	Inches of Mercury
in H ₂ O	-	Inches of Water
$\sqrt{inH_2O}$	-	Square root of Inches of Water
I	-	Isokinetic Sampling
K1 method 5	-	Conversion to standard conditions, 17.64 °R/inches Hg
K1 method 4	-	Conversion to standard conditions, 0.04707 f3/ml
K2 method 4	-	Conversion to standard conditions, 0.04715 ft3/g
K4 method 5	-	Conversion to standard conditions, 0.0945
K _p	-	Pitot tube constant, 85.49 for English units
Kg	-	Killograms
L	-	Length of Stack if Rectangular
lb	-	Pound
lb/lb-mole	-	Pound per pound mole
lb-mole	-	Pound mole
lb/hr	-	Pound per hour
lb/MMBTU	-	Pound per million British thermal units
ma	-	Average Final (total) weight after evaporation - Average Tare Weight of Acetone Blank
m ³	-	Cubic meters
mg	-	Milligrams
mg/g	-	Milligrams per gram
mL	-	Milliliter
M _d	-	Molecular weight of stack gas mixture, dry basis
MMBTU	-	Million British Thermal Units
MMBtu/hr	-	Million British Thermal Units per hour
mm HG	-	Millimeters of Mercury
M _n	-	Mass of particulate matter, g
M _s	-	Molecular weight of stack gas mixture, wet basis
M _{SAT}	-	Ratio of vapor pressure of water at stack conditions to stack pressure
M _W	-	Molecular weight of a specific compound or element
N ₂	-	Nitrogen
O ₂	-	Oxygen
ng	-	Nanograms
NMNEVOC	-	Non-Methane, Non-Ethane Volatile Organic Compounds
NO _x	-	Oxides of Nitrogen
NO ₂	-	Nitrous Oxide
%	-	Percent
% Volume	-	Percent by volume
% dv	-	Percent by volume, dry basis
ΔP	-	Gas velocity pressure, in H ₂ O
P _a	-	Density of Acetone
P _{BAR}	-	Barometric pressure, in H ₂ O
P _S	-	Static Pressure, in H ₂ O
P _g	-	Total pressure of gas at stack conditions
P _{STD}	-	Standard pressure, 760 mmHG
$\sqrt{(P)_{avg}}$	-	Average of the square root of gas velocity pressure, in H ₂ O
ppm _{dv}	-	Parts per million, volume and dry basis
ppb _{dv}	-	Parts per billion, volume and dry basis
Q _{ACFM}	-	Flow rate of stack gas, actual cubic feet per minute
Q _{SCFM}	-	Flow rate of stack gas, standard cubic feet per minute
Q _{DSCFM}	-	Flow rate of stack gas, dry standard cubic feet per minute

°R	-	Degrees Rankin
°R/in. Hg	-	Degrees Rankin per inches of Mercury
scf/ml	-	Standard cubic feet per milliliter
scf/g	-	Standard cubic feet per gram
SCFM	-	Standard cubic feet per minute
SCM	-	Standard cubic meters
SCF	-	Standard cubic feet
SP _{H₂O@T_{avg}}	-	Saturation pressure of water at average stack temperature
STD	-	Standard
s	-	Second
T	-	Stack Temperature
tph	-	Tons per hour
ton/yr	-	Tons per year
T _M	-	Temperature of the dry gas meter
T _S	-	Temperature of the stack
T _{STD}	-	Standard temperature, 68 °F
THC	-	Total Hydrocarbons
ug	-	Micrograms
V _a	-	Volume of Acetone Blank, in mL
V _{aw}	-	Volume of Acetone Rinse, in mL
vol.	-	Volume
V/n _{std}	-	Volume mole in standard conditions, in cubic feet per pound mole
V _{lc}	-	Total volume of water vapor condensed, at STP
V _m	-	Volume of sample gas measured by the dry gas meter
V _{MSTD}	-	Volume of sample gas measured by the dry gas meter, corrected to standard conditions
VOC	-	Volatile Organic Compounds
V _S	-	Velocity of stack gas, ft/s
V _{Wc(std)}	-	Volume of water condensed, corrected to standard conditions
V _{Wsg(std)}	-	Volume of water collected in silica gel, corrected to standard conditions
V _{W(std)}	-	Volume of water vapor in gas stream, corrected to standard conditions
Y _d	-	Dry gas meter calibration factor
V _f	-	Final volume of water
V _i	-	Initial volume of water
W1	-	Acetone Rinse Final Weight 1
W2	-	Acetone Rinse Final Weight 2
W	-	Width of Stack if Rectangular
W _a	-	Weight of Acetone
W _f	-	Final weight
W _i	-	Initial weight
