

Source Collection Data Sheet

Contract No. 184380		Method Ooro Semi Volatiles		Page 2 of 2	
Facility Exxon Mobil BTRF		Init. System Leak Rate (ft3 @ "Hg) 0.006 @ 17" Hg		Operator S. Lockwood	
Source 1-601 Stack SRU		Final System Leak Rate (ft3 @ "Hg) 0.004 @ 18" Hg		Pitot No.	
Date 7-8-2011		Start Time 09:00		Meter No. 1446	
Condition Normal		End Time 13:26		PTCF 0.84	
Run No. 2		Duration (min) 240		DGMCF 0.9721	
Stat. Press. ("H2O) -0.96		Bar. Press. ("Hg) 29.90		Init. Pitot Leak Check ✓	
		Nozzle Diam. (") 0.462		Final Pitot Leak Check ✓	
				Kf 0.68	

[illegible]

Comments

Checked By:

_____(Project Manager or QA Manager - sign and date)



Sample Recovery Data Sheet

Contract No.	184380	Method	0010 Semi Volatiles
Condition	Normal	Run No.	2
Date	7-8-11	Operator	RPN

Impinger No.	Contents	Volume (mL)	Configuration	Final Wt. (g) - Initial Wt. (g) = Net Gain (g)
1	—		KO	620.0 - 359.5 = 260.5
2	Aspirator	100	Mod	682.7 - 693.3 = -10.6
3	✓	100	G-S	710.2 - 710.0 = 0.2
4	—	—	Mod	629.3 - 607.5 = 21.8
5	Sigal	~600	Mod	953.0 - 906.8 = 46.2
6				- =
7				- =
8				- =
9				- =
10				- =
				Total Net Gain (g) = 318.1

Comments:



Source Collection Data Sheet

Contract No. 184380	Method 0010 (Semi Vols)	Page 1 of 2
Facility Exxon Mobil BTRF	Init. System Leak Rate (ft3 @ "Hg) 0.002 @ 19" Hg	Operator S. Lockwood
Source T-601 Stack SRV	Final System Leak Rate (ft3 @ "Hg) 0.002 @ 19" Hg	Pitot No.
Date 7-8-2011	Start Time 13:55	Meter No. 1446
Condition Normal	End Time 1824	DGMCF .9421
Run No. 3	Duration (min) 240	ΔH@ 1.707
Stat. Press. ("H2O) -1.0	Bar. Press. ("Hg) 29.9	Nozzle Diam. (") 0.162
		Kf 0.68

Point	Time (24-hr)	Volume (ft3)	ΔP ("H2O)	ΔH ("H2O)	Temperatures (°F)						Vacuum ("Hg)	XAD
					Flue Gas	Probe	Filter	Impingers	Meter In	Meter Out		
N 51	13:55	419.713	4.6	3.12	102	255	249	69	102	101	14.5	64
1	14:00	424.69	2.6	1.77	102	266	251	62	105	102	9.0	58
2	14:05	428.052	2.7	1.84	102	263	253	58	107	102	10.0	53
2	14:10	430.65	2.7	1.84	102	266	257	58	107	102	10.0	53
3	14:15	432.83	2.9	1.97	103	256	254	59	108	103	10.0	53
3	14:20	437.125	Stop	Adj	Pump	oil						
Start	14:21	437.185	3.8	2.58	102	253	254	65	105	104	12.0	60
3	14:26	441.64	3.5	2.38	102	255	255	68	110	105	12.5	63
4	14:31	446.26	3.7	2.51	102	263	254	69	109	105	12.5	63
4	14:36	451.07	4.6	3.12	103	267	254	69	110	105	16.0	63
5	14:41	456.23	4.6	3.12	104	253	254	68	111	106	16.0	63
5	14:46	461.48	4.6	3.12	103	267	254	67	111	106	16.0	61
6	14:51	466.53	4.6	3.12	103	252	253	68	111	107	16.0	61
6	14:56	471.76	5.0	3.4	103	263	255	69	110	107	16.0	63
7	15:01	476.90	5.0	3.4	103	257	253	68	110	108	16.5	61
7	15:06	482.14	5.1	3.47	103	253	248	68	110	108	16.5	61
8	15:11	487.37	4.7	3.19	103	263	253	69	109	108	16.0	61
8	15:16	492.58	4.7	3.19	103	265	252	70	109	108	16.0	63
9	15:21	497.83	3.9	2.65	103	252	251	70	109	108	13.5	63
9	15:26	502.63	3.8	2.58	104	251	253	71	108	107	13.0	63
10	15:31	507.36	3.8	2.58	103	267	253	70	110	107	13.0	63
10	15:36	512.00	3.2	2.17	102	265	253	71	109	106	11.0	68
11	15:41	516.43	2.9	1.97	103	258	253	73	109	107	10.0	68
11	15:46	520.64	2.9	1.97	103	253	254	72	109	106	10.0	65
12	15:51	524.87	2.7	1.84	103	263	256	71	109	106	10.0	63
12	15:56	528.83	2.6	1.77	102	265	255	68	110	106	9.0	61
End	16:01	532.740										
W 51	16:24	533.484	2.3	1.56	103	248	253	67	104	104	9.0	61
1	16:29	537.18	2.1	1.43	103	247	254	66	105	104	8.5	60

Comments	Interim Leak Checks
	1 - 0.002 @ 19" 2 - 0.002 @ 19"

Checked By: _____

(Project Manager or QA Manager - sign and date)

Source Collection Data Sheet

Contract No. 184380	Method Comb Semi-Volatiles	Page 2 of 2
Facility Exxon Mobil BTRF	Init. System Leak Rate (ft3 @ "Hg) 0.002 @ 19" Hg	Operator S. Lockwood
Source T-601 Stack SRW	Final System Leak Rate (ft3 @ "Hg) 0.002 @ 19" Hg	Pitot No.
Date 7-8-2011	Start Time 13:55	Meter No. 1446
Condition Normal	End Time 1824	DGMCF 0.9721
Run No. 3	Duration (min) 240	$\Delta H @$ 1.707
Stat. Press. ("H2O) -1.0	Bar. Press. ("Hg) 29.90	Nozzle Diam. (") 0.162
		PTCF 0.84
		Init. Pitot Leak Check <input checked="" type="checkbox"/>
		Final Pitot Leak Check <input checked="" type="checkbox"/>
		Kf 0.68

[illegible]

Comments

Checked By:

_____(Project Manager or QA Manager - sign and date)



Sample Recovery Data Sheet

Contract No.	184380	Method	0010	Semi Volatiles
Condition	Normal	Run No.	3	
Date	7-8-11	Operator	ru	

Impinger No.	Contents	Volume (mL)	Configuration	Final Wt. (g) - Initial Wt. (g) = Net Gain (g)
1	—	—	KO	848.6 - 482.5 = 366.1
2	HPLC H ₂ O	100	Mod	701.1 - 705.0 = -3.9
3	↓	100	G/S	622.3 - 626.0 = -3.7
4	—	—	Mod	589.2 - 584.0 = 5.2
5	Sigel	~600	Mod	1031.2 - 980.6 = 50.6
6				- =
7				- =
8				- =
9				- =
10				- =
				Total Net Gain (g) = 414.3

Comments:

Meter Box: Orifice Full Calibration

Date: 2/22/2011
 Prev. Calib. Date: 1/19/2010
 Location: TRC Austin, TX Lab
 Technician: MRL
 Meter Serial No: 1446
 Meter Box ID: 1446.00
 Atm. Pressure (corr. in H₂O): 29.41 in. Hg. (required minimum)
 Critical Vacuum + 2 in H₂O: 16 in. Hg. (required minimum)
 Prev. Calib Factor (Y): 0.9861


Reference Orifice Set		Orifice (#)	K' Factor
Manufacturer:	Apex Instruments	40	0.2353
Model:	LA40-73	48	0.3451
Tested By:	EW	55	0.4549
		63	0.5886

Orifice Serial #	K' coefficient (see above)	dH (in. H ₂ O)	Time (min)	Vol (initial) (cu ft)	Vol (final) (cu ft)	Vol. Total (cu ft)	Initial Temperatures		Final Temperatures		Vacuum (in Hg)	Ambient Temperatures	
							Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)		Initial (deg F)	Final (deg F)
40	0.2353	0.27	31	929.125	938.912	9.787	73	73	73	74	24	73.0	74.0
48	0.3451	0.57	29	938.912	952.369	13.457	73	74	74	74	21	74.0	75.0
55	0.4549	1.1	38	952.369	975.626	23.257	74	74	75	75	19	75.0	76.0
63	0.5886	1.8	39	975.626	#####	30.853	75	75	78	76	17	76.0	78.0

Meter Box Dry Gas Meter			Critical Orifice		Dry Gas Meter Calibration Factor (Y)		Orifice Calibration Factor (dH@)	
Volume Corrected	Volume Corrected	Flow Rate	Volume Corrected	Volume Corrected	Value	Variation	Value	Variation
Vm (std) (cu ft)	Vm (std) (liters)	Rate (CFM)	Vcr (std) (cu ft)	Vm (std) (liters)	Value (#)	Variation (#)	Value (in H ₂ O)	Variation (in H ₂ O)
9.53	269.77	0.316	9.29	262.97	0.975	0.003	1.640	-0.07
13.10	370.87	0.464	12.73	360.46	0.972	0.000	1.617	-0.09
22.63	640.90	0.612	21.97	622.03	0.971	-0.002	1.803	0.10
29.99	849.32	0.791	29.13	824.87	0.971	-0.001	1.768	0.06

Meter Box Calibration Test Results			Pass/Fail
* Average Y:	0.9721		PASS
Ave Y w/in 5% of previous value			YES
0.95 >= Y <= 1.05			PASS
** Average dH:	1.707		PASS

Criteria:
 * Y- ratio of the reading of the calibration meter (critical orifice) to the Meter Box DGM. Acceptable tolerance of individual values from the average is +/- 0.02.
 ** dH- the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air flow at 68 F and 29.92 in Hg, acceptable tolerance of individual values from the average.





Console No.

1442

S. O. P. Reference

AM - 103

Temperature Display Type

Jenco-765

Calibrator Type

Omega Model XL23A

Temperature Display Serial No.

JC 08171

Calibrator Serial No.

T-239267

Display Channel No.	Reference Temperature (°F)		Reference Temperature (°F)		Reference Temperature (°F)		Reference Temperature (°F)		Reference Temperature (°F)	
	Measured Temperature (°F)	Relative Error (%)	Measured Temperature (°F)	Relative Error (%)	Measured Temperature (°F)	Relative Error (%)	Measured Temperature (°F)	Relative Error (%)	Measured Temperature (°F)	Relative Error (%)
1 (Stack)	29	0.6	211	0.1	498	0.2	999	0.1	1499	0.1
2 (Probe)	30	0.4	211	0.1	497	0.3	999	0.1	1499	0.1
3 (Filter)	29	0.6	210	0.3	496	0.4	998	0.1	1498	0.1
4 (Dryer)	28	0.8	210	0.3	496	0.4	998	0.1	1498	0.1
5 (Aux)	28	0.8	209	0.4	496	0.4	998	0.1	1498	0.1
6 (DGM Inlet)	28	0.8	210	0.3	495	0.5	998	0.1	1498	0.1
7 (DGM Outlet)	30	0.4	209	0.4	495	0.5	999	0.1	1498	0.1

Relative Error must meet criteria of +/- 1.5 % (absolute temperature, R)

Operator

Date 3/23/2011

Note:

Display Type - type J, K, T etc...

Calibrator Type - must match display type

Display Serial Number - Located on T/C readout, not the same as meter box number

Enter data in shaded boxes

ExxonMobil Baytown Texas Refinery

SCU2 T-601 ICR Test

SW-846 Method 0011

Aldehydes

Project Number	184380		
Client / Location	ExxonMobil SRU		
Source	T801		
Sampling Location			
Sample Type / Method	0011(Aldehyde/Ketone)		
Condition Number	Normal	Normal	Normal
Run Number	1	2	3
Method Number	11	11	11
Date	07/07/11	07/08/11	07/08/11
Time Start (24-hr clock)	1134	900	1355
Time Stop (24-hr clock)	1529	1226	1724
Total Collection Time (min)	120	120	120
Pitot Tube Correction Factor	0.84	0.84	0.84
Nozzle Diameter (in.)	0.162	0.162	0.162
Nozzle Area (ft ²)	0.000143	0.000143	0.000143
Equivalent Duct Diameter (in)	48.00	48.00	48.00
Equivalent Duct Diameter (ft)	4.00	4.00	4.00
Duct Cross-Sectional Area (ft ²)	12.566	12.566	12.566
Barometric Pressure (in. Hg)	29.90	29.90	29.90
Elevation of Sampling Location Relative to Barometer (ft)	150.00	150.00	150.00
Barometric Pressure at Sampling Location (in. Hg)	29.75	29.75	29.75
Static Pressure (in. H ₂ O)	-2.00	-0.96	-1.00
Absolute Stack Pressure (in. Hg)	29.60	29.68	29.68
O ₂ (%)	0.0	0.0	0.0
CO ₂ (%)	0.0	0.0	0.0
Dry Molecular Weight (g/g-mole)			
Condensate (mL)	166.1	164.5	172.9
Moisture Content (%) (measured)	7.13	6.96	7.33
Moisture Content at Saturation (%)	6.31	6.39	6.88
Moisture Content (%) (used in further calculations)	7.13	6.96	7.33
Wet Molecular Weight (g/g-mole)	27.29	27.30	27.27
Initial Meter Volume (ft ³)	356.017	469.535	581.276
Final Meter Volume (ft ³)	466.424	580.819	692.657
Leak Check Volume (ft ³)	0.483	0.490	0.610
Meter Volume (ft ³)	109.924	110.794	110.771
Meter Calibration Factor, Y	0.986	0.986	0.986
Average Meter Temperature (F)	103.5	98.7	102.4
Absolute Meter Temperature (F)	563.5	558.7	562.4
Average Delta H (in. H ₂ O)	2.3	2.3	2.3
Elevation of Meter Relative to Barometer (ft)	0.0	0.0	0.0
Corrected Meter Volume (dscf)	102.076	103.758	103.060
Average Stack Temperature (F)	99.0	99.5	101.9
Absolute Stack Temperature (R)	559.0	559.5	561.9
Average Delta P (in. H ₂ O)	3.43	3.43	3.43
Average Square Root of delta P	1.84	1.85	1.84
Unadjusted Gas Velocity (ft/sec)	110.14	110.12	110.30
WAF	1.00	1.00	1.00
Adjusted Gas Velocity (ft/sec)	110.14	110.12	110.30
Adjusted Gas Velocity (ft/min)	6,608	6,607	6,618
Actual Flow Rate (acfh)	4,982,393	4,981,559	4,990,031
Actual Flow Rate (acfm)	83,040	83,026	83,167
Corrected Flow Rate (wscfh)	4,656,566	4,663,641	4,650,674
Corrected Flow Rate (wscfm)	77,609	77,727	77,511
Corrected Flow Rate (kwscfh)	4,657	4,664	4,651
Corrected Flow Rate (kwscfm)	78	78	78
Corrected Flow Rate (dscfh)	4,324,764	4,339,278	4,309,770
Corrected Flow Rate (dscfm)	72,079	72,321	71,830
Corrected Flow Rate (kdscfh)	4,325	4,339	4,310
Corrected Flow Rate (kdscfm)	72	72	72
Isokinetic Sampling Rate (%)	103.61	104.96	104.97
		Tabulated Data	
		Calculations	
		Data Entry	

STP is defined as 528 R and 29.92 "Hg

Run Data

Impinger No.	Initial Wt. (g)	Final Wt. (g)	Total Gain (g)
1	832.6	946.8	114.2
2	667.8	696.6	28.8
3	615.6	615.8	0.2
4	635.0	638.0	3
5	973.1	993.0	19.9
6			
		sum =	166.1

dP	Temperatures			dH	SQRT dP	SQRT dH
	Stack	Meter Inlet	Meter Outlet			
2.40	95	94	93	1.65	1.55	1.28
2.40	95	94	92	1.65	1.55	1.28
2.60	96	96	93	1.77	1.61	1.33
3.10	96	97	93	2.11	1.76	1.45
3.50	96	99	93	2.38	1.87	1.54
3.50	96	100	94	2.38	1.87	1.54
4.60	97	103	99	3.13	2.14	1.77
4.40	97	104	98	2.99	2.10	1.73
3.70	98	105	99	2.52	1.92	1.59
3.10	98	106	99	2.11	1.76	1.45
2.70	98	106	99	1.84	1.64	1.36
2.70	98	107	99	1.84	1.64	1.36
2.90	99	100	99	1.97	1.70	1.40
2.70	101	106	102	1.84	1.64	1.36
2.70	101	109	103	1.84	1.64	1.36
3.50	101	112	104	2.38	1.87	1.54
4.10	101	113	105	2.79	2.02	1.67
4.40	101	114	105	2.99	2.10	1.73
3.7	101	114	106	2.52	1.92	1.59
4.2	102	114	107	2.86	2.05	1.69
4.4	102	115	107	2.99	2.10	1.73
3.9	102	115	108	2.65	1.97	1.63
3.6	102	115	108	2.45	1.90	1.57
3.6	102	115	109	2.45	1.90	1.57
3.43	99.0	103.5		2.34	1.84	1.52

Run 2

Impinger No.	Initial Wt. (g)	Final Wt. (g)	Total Gain (g)
1	816.0	940.0	124
2	765.2	780.6	15.4
3	718.5	720.8	2.3
4	618.2	620.8	2.6
5	916.8	937.0	20.2
6			0
sum =			164.5

Temperatures						
dP	Stack	Meter Inlet	Meter Outlet	dH	SQRT dP	SQRT dH
2.90	99	89	85	1.97	1.70	1.40
2.90	99	91	86	1.97	1.70	1.40
3.40	100	94	88	2.31	1.84	1.52
3.70	100	95	89	2.52	1.92	1.59
4.10	99	97	89	2.79	2.02	1.67
4.00	100	99	90	2.72	2.00	1.65
4.00	100	101	92	2.72	2.00	1.65
4.30	100	102	93	2.92	2.07	1.71
3.90	100	103	94	2.65	1.97	1.63
3.00	99	104	95	2.04	1.73	1.43
3.00	100	105	96	2.04	1.73	1.43
3.20	99	104	97	2.18	1.79	1.48
3.20	99	101	100	2.18	1.79	1.48
3.00	100	104	100	2.04	1.73	1.43
3.20	100	105	100	2.18	1.79	1.48
3.10	100	106	100	2.11	1.76	1.45
3.60	100	106	100	2.45	1.90	1.57
4.40	99	106	101	2.99	2.10	1.73
4.6	99	106	101	3.13	2.14	1.77
4.1	99	106	101	2.79	2.02	1.67
3.2	99	105	101	2.18	1.79	1.48
2.8	99	104	100	1.9	1.67	1.38
2.6	99	104	100	1.77	1.61	1.33
2.2	99	104	100	1.5	1.48	1.22
3.43	99.5	98.7		2.34	1.85	1.52

Run 3

Run Data

Impinger No.	Initial Wt. (g)	Final Wt. (g)	Total Gain (g)
1	831.5	942.5	111
2	672.1	708.8	36.7
3	617.9	616.4	-1.5
4	639.5	640.6	1.1
5	942.2	967.8	25.6
6			0
sum =			172.9

Temperatures						
dP	Stack	Meter Inlet	Meter Outlet	dH	SQRT dP	SQRT dH
3.00	101	98	98	2.04	1.73	1.43
3.00	102	100	99	2.04	1.73	1.43
3.40	102	102	99	2.31	1.84	1.52
3.70	102	103	99	2.51	1.92	1.58
3.90	102	103	99	2.65	1.97	1.63
4.60	102	104	100	3.13	2.14	1.77
3.70	102	104	101	2.51	1.92	1.58
3.80	102	104	101	2.58	1.95	1.61
3.30	102	105	102	2.25	1.82	1.50
3.30	103	105	102	2.25	1.82	1.50
2.10	102	105	103	1.43	1.45	1.20
2.10	102	106	103	1.43	1.45	1.20
2.70	103	102	102	1.84	1.64	1.36
2.70	102	102	102	1.84	1.64	1.36
3.10	102	104	102	2.11	1.76	1.45
3.80	101	104	102	2.58	1.95	1.61
4.30	101	105	102	2.92	2.07	1.71
4.60	101	105	102	3.13	2.14	1.77
3.7	102	104	102	2.51	1.92	1.58
3.2	102	104	101	2.18	1.79	1.48
3.6	102	104	101	2.45	1.90	1.57
4.1	102	105	101	2.79	2.02	1.67
3.3	102	105	102	2.25	1.82	1.50
3.3	102	105	102	2.25	1.82	1.50
3.43	101.9	102.4		2.33	1.84	1.52



Source Collection Data Sheet

Contract No. 184380	Method 0011 (Aldehyde/ketone)	Page 1 of 1
Facility ExxonMobil BTRF	Init. System Leak Rate (ft3 @ "Hg) 0.007 @ 12" Hg	Operator A. Nava
Source SRU T-601 Stack	Final System Leak Rate (ft3 @ "Hg) 0.008 @ 14" Hg	Pitot No.
Date 7-7-11	Start Time 1134	Meter No. 1442
Condition No (M4)	End Time 1529	DGMCF 0.9860
Run No.	Duration (min) 120	ΔH@ 1.698
Stat. Press. ("H2O) -2.8	Bar. Press. ("Hg) 29.90	Nozzle Diam. (") 0.162
		Kf 0.68
		PTCF 0.84
		Init. Pitot Leak Check ✓
		Final Pitot Leak Check ✓

Point	Time (24-hr)	Volume (ft3)	Δ P ("H2O)	Δ H ("H2O)	Temperatures (°F)						Vacuum ("Hg)	
					Flue Gas	Probe	Filter	Impingers	Meter In	Meter Out		
1	1134	356.017	2.4	1.65	95	253	257	66	94	93	6	
2	1139	359.83	2.4	1.65	95	253	257	65	94	92	6	
3	1144	363.67	2.6	1.77	96	252	257	64	96	93	6	
4	1149	367.54	3.1	2.11	96	250	257	58	97	93	8	
5	1154	372.08	3.5	2.38	96	257	257	57	99	93	8	
6	1159	376.30	3.5	2.38	96	255	257	58	100	94	10	
7	1236	380.944	4.6	3.13	97	255	258	67	103	99	12	
8	1241	386.15	4.4	2.99	97	249	256	66	104	98	12	
9	1246	391.35	3.7	2.52	98	250	259	64	105	99	10	
10	1251	395.21	3.1	2.11	98	254	261	61	106	99	10	
11	1256	400.63	2.7	1.84	98	253	257	62	106	99	8	
12	1301	404.87	2.7	1.84	98	252	259	60	107	99	7	
Stop	1306	408.770	—	—	—	—	—	—	—	—	—	—
W 12	1429	409.253	2.9	1.51	99	257	257	65	100	97	7	
11	1434	413.46	2.7	1.84	101	247	260	62	106	102	7	
10	1439	417.62	2.7	1.84	101	252	258	62	109	103	7	
9	1444	421.96	3.5	2.38	101	249	259	63	112	104	9	
8	1449	426.63	4.1	2.79	101	254	258	61	113	105	10	
7	1454	431.53	4.4	2.99	101	247	257	60	114	105	10	
6	1459	436.71	3.7	2.52	101	247	258	60	114	106	9	
5	1504	441.68	4.2	2.86	102	254	258	60	114	107	10	
4	1509	446.55	4.4	2.99	102	247	257	61	115	107	11	
3	1514	451.77	3.9	2.65	102	250	256	62	115	108	10	
2	1519	456.76	3.6	2.45	102	245	257	64	115	108	9	
1	1524	461.69	3.6	2.45	102	254	258	65	115	109	9	
Stop	1529	466.424	—	—	—	—	—	—	—	—	—	—

Comments 1204: stopped due to m6610 probe in way
1236 resumed testing
Post "S" part leak check 0.004 @ 15" Pre "W" leak check 0.008 @ 15"

Checked By: _____

(Project Manager or QA Manager - sign and date)



Sample Recovery Data Sheet

Contract No.	184380	Method	001	Alddehydes
Condition	Normal	Run No.	1	
Date	7-7-2011	Operator	Rm	

Impinger No.	Contents	Volume (mL)	Configuration	Final Wt. (g) - Initial Wt. (g) = Net Gain (g)
1	DNPH soln	200	Mod	946.8 - 832.6 = 114.2
2	↓	100	6/s	696.6 - 667.8 = 28.8
3	↓	100	Mod	615.8 - 615.6 = 0.2
4	↓	—	↓	638.0 - 635.0 = 3.0
5	Sigal	~500	↓	993.0 - 973.1 = 19.9
6				- =
7				- =
8				- =
9				- =
10				- =
				Total Net Gain (g) = 166.1

Comments:

Balance calSCOUT PRO
1D 7131231039ActualMeasured

500g

499.9g

1000g

999.8g

50g

50.0g



Source Collection Data Sheet

Contract No. 184380	Method 0011 Aldehydes	Page 1 of 1
Facility Exxon Mobil BTRF	Init. System Leak Rate (ft3 @ "Hg) 0.003 @ 17"Hg	Operator R. Nak
Source SRU T.601	Final System Leak Rate (ft3 @ "Hg) 0.004 @ 13"Hg	Pitot No.
Date 7-8-11	Start Time 0900	Meter No. 1442
Condition Normal	End Time 1226	DGMCF 0.9860
Run No. 2	Duration (min) 120	ΔH@ 1.698
Stat. Press. ("H2O) -0.96	Bar. Press. ("Hg) 29.9	Nozzle Diam. (") 0.162
		Kf 0.68
		PTCF 0.84
		Init. Pitot Leak Check ✓
		Final Pitot Leak Check ✓

Point	Time (24-hr)	Volume (ft3)	Δ P ("H2O)	Δ H ("H2O)	Temperatures (°F)						Vacuum ("Hg)	
					Flue Gas	Probe	Filter	Impingers	Meter In	Meter Out		
1	0900	469.535	2.9	1.97	99	253	256	67	89	85	6	
2	0905	473.83	2.9	1.97	99	251	258	61	91	86	6	
3	0910	477.99	3.4	2.31	100	247	256	60	94	88	7	
4	0915	482.47	3.7	2.52	100	247	255	61	95	89	8	
5	0920	487.31	4.1	2.79	99	254	257	64	97	89	9	
6	0925	492.22	4.0	2.72	100	248	258	65	99	90	9	
7	0930	497.21	4.0	2.72	100	246	260	65	101	92	9	
8	0935	502.18	4.3	2.92	100	250	260	62	102	93	9	
9	0940	507.31	3.9	2.65	100	249	259	60	103	94	9	
10	0945	512.20	3.0	2.04	99	251	260	60	104	95	7	
11	0950	516.58	3.0	2.04	100	249	258	59	105	96	7	
12	0955	520.89	3.2	2.18	99	250	260	59	104	97	7	
stop	1000	525.342	—	Post "5"	per	0.006 @	12" / Pre "W"	per	0.005 @	12		
W1	1126	525.832	3.2	2.18	99	258	256	66	101	100	7	
2	1131	530.22	3.0	2.04	100	253	257	60	105	100	7	
3	1136	534.59	3.2	2.18	100	252	257	55	105	100	7	
4	1141	539.02	3.1	2.11	100	259	250	55	106	100	7	
5	1146	543.44	3.6	2.45	100	256	258	55	106	100	9	
6	1151	548.24	4.4	2.99	99	260	261	56	106	101	11	
7	1156	553.53	4.6	3.13	99	254	259	57	106	101	11	
8	1201	558.77	4.1	2.79	99	255	257	58	106	101	10	
9	1206	563.912	3.2	2.18	99	258	261	55	105	101	8	
10	1211	568.55	2.8	1.90	99	255	260	52	104	100	7	
11	1216	572.84	2.6	1.77	99	262	260	52	104	100	7	
12	1221	577.01	2.2	1.50	99	258	257	51	104	100	7	
stop	1226	580.819	—	—	—	—	—	—	—	—	—	

Comments

Checked By: _____

(Project Manager or QA Manager - sign and date)



Sample Recovery Data Sheet

Contract No. 184380	Method 0011 Aldehydes
Condition SRU T-601 Stack	Run No. 2
Date 7-8-11	Operator km

Impinger No.	Contents	Volume (mL)	Configuration	Final Wt. (g) - Initial Wt. (g) = Net Gain (g)
1	DNPH soln	200	Med	940.0 - 816.0 = 124.0
2	↓	100	G/S	780.6 - 765.2 = 15.4
3	↓	100	Med	720.8 - 718.5 = 2.3
4	-	-	↓	620.8 - 618.2 = 2.6
5	Sigal	~600	↓	937.0 - 916.8 = 20.2
6				- =
7				- =
8				- =
9				- =
10				- =
				Total Net Gain (g) = 164.5

Comments:



Source Collection Data Sheet

Contract No. 184380	Method 0011 Aldehydes	Page 1 of 1
Facility Exxon Mobil BTRF	Init. System Leak Rate (ft3 @ "Hg) 0.001 @ 15"Hg	Operator A. N. J.
Source SRU T-601 Stack	Final System Leak Rate (ft3 @ "Hg) 0.003 @ 17"Hg	Pitot No.
Date 7-8-11	Start Time 1355	Meter No. 1442
Condition Normal	End Time 1724	DGMCF 0.9860
Ruin No. 3	Duration (min) 120	ΔH@ 1.69E
Stat. Press. ("H2O) -1.0	Bar. Press. ("Hg) 29.90	Nozzle Diam. (") 0.162
		Kf 0.68
		PTCF 0.84
		Init. Pitot Leak Check ✓
		Final Pitot Leak Check ✓

Point	Time (24-hr)	Volume (ft3)	Δ P ("H2O)	Δ H ("H2O)	Temperatures (°F)						Vacuum ("Hg)	
					Flue Gas	Probe	Filter	Impingers	Meter In	Meter Out		
W1	1355	581.276	3.0	2.04	101	256	258	67	98	98	9	
2	1400	585.5	3.0	2.04	102	253	260	65	100	99	9	
3	1405	589.91	3.4	2.31	102	252	261	62	102	99	9	
4	1410	594.36	3.7	2.51	102	248	260	61	103	99	12	
5	1415	599.11	3.9	2.65	102	251	261	63	103	99	13	
6	1420	603.97	4.6	3.13	102	257	257	61	104	100	15	
7	1425	609.22	3.7	2.51	102	252	259	60	104	101	13	
8	1430	614.20	3.8	2.58	102	258	260	60	104	101	14	
9	1435	618.98	3.3	2.25	103	251	260	58	105	102	11	
10	1440	623.52	3.3	2.25	102	253	259	59	105	102	11	
11	1445	628.91	2.1	1.43	102	249	252	60	105	103	7	
12	1450	628.32	2.1	1.43	102	250	251	60	105	103	7	2nd
Stop	1455	635.686	Leak check port "W" 0.003 @ 17" Leak check port "S" 0.001 @ 17"									
51	1624	636.296	2.7	1.84	102	252	272	66	102	102	7	
2	1629	640.45	2.7	1.84	102	255	266	60	102	102	7	
3	1634	644.59	3.1	2.11	101	252	268	59	104	102	9	
4	1639	648.91	3.8	2.58	101	254	254	61	104	102	9	11
5	1644	653.77	4.3	2.92	101	248	256	63	105	102	13	
6	1649	659.00	4.6	3.13	102	249	255	63	105	102	15	
7	1654	664.34	3.7	2.51	102	249	254	64	104	102	12	
8	1659	669.19	3.2	2.18	102	250	255	64	104	101	10	
9	1704	673.88	3.6	2.45	102	254	256	63	104	101	11	
10	1709	678.44	4.1	2.79	102	254	257	62	105	101	13	
11	1714	683.43	3.3	2.25	102	254	254	63	105	102	11	
12	1719	688.06	3.3	2.25	102	252	256	59	105	102	11	
Stop	1724	692.65	—	—	—	—	—	—	—	—	—	—

Comments

Checked By: _____

(Project Manager or QA Manager - sign and date)



Sample Recovery Data Sheet

Contract No.	184380	Method	0011 Aldehydes
Condition	Normal	Run No.	3
Date	7-8-11	Operator	LNN

Impinger No.	Contents	Volume (mL)	Configuration	Final Wt. (g) - Initial Wt. (g) = Net Gain (g)
1	DNPHT soln	200	Mod	942.5 - 831.5 = 111.0
2	↓	100	G/S	708.8 - 672.1 = 36.7
3	↓	100	Mod	616.4 - 617.9 = -1.5
4	—	—	↓	640.6 - 639.5 = 1.1
5	Sig el	~600	↓	967.8 - 942.2 = 25.6
6				- =
7				- =
8				- =
9				- =
10				- =
				Total Net Gain (g) = 172.9

Comments:

Balance cal Scout Pro 7131231039

Actual

500g

1000g

50g

Measured

499.9g

999.8g

50.0g

Meter Box: Orifice Full Calibration

Date: 9/14/2010
Prev. Calib. Date: 1/26/2009
Location: TRC Austin, TX Lab
Technician: MRL
Meter Serial No: 9543627
Meter Box ID: 1442
Atm. Pressure (corr. in Hg): 29.28 **ncorrected:** 29.52
Critical Vacuum + 2 in Hg: 16 **in. Hg. (required minimum)**
Prev. Calib Factor (Y): 0.9790

Reference Orifice Set		Orifice (#)	K' Factor
Manufacturer:	Apex Instruments	40	0.2332
Model:	SX40-73	48	0.339
Tested By:	EW	55	0.4426
Date:	10/5/09	63	0.6126

Orifice Serial #	K' coefficient (see above)	dH (in. H ₂ O)	Time (min)	Vol (initial) (cu ft)	Vol (final) (cu ft)	Vol. Total (cu ft)	Initial Temperatures		Final Temperatures		Vacuum (in Hg)	Ambient Temperatures	
							Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)		Initial (deg F)	Final (deg F)
40	0.2332	0.25	10	28.170	31.248	3.078	69	69	70	70	24	74.7	75.2
48	0.339	0.55	10	31.248	35.756	4.508	70	70	71	70	23	75.2	75.1
55	0.4426	0.96	10	35.756	41.591	5.835	71	70	72	70	22	75.3	75.9
63	0.6126	1.97	10	41.591	49.520	7.929	72	72	72	73	20	76.1	76.3

Meter Box Dry Gas Meter			Critical Orifice		Dry Gas Meter Calibration Factor (Y)		Orifice Calibration Factor (dH@)	
Volume Corrected	Volume Corrected	Flow Rate	Volume Corrected	Volume Corrected				
Vm (std) (cu ft)	Vm (std) (liters)	Rate (CFM)	Vcr (std) (cu ft)	Vm (std) (liters)	Value (#)	Variation (#)	Value (in H ₂ O)	Variation (in H ₂ O)
3.00	85.07	0.308	2.95	83.60	0.983	-0.003	1.599	-0.10
4.40	124.51	0.451	4.29	121.50	0.976	-0.010	1.662	-0.04
5.69	161.18	0.584	5.60	158.57	0.984	-0.002	1.705	0.01
7.73	218.96	0.793	7.75	219.35	1.002	0.016	1.826	0.13


Meter Box Calibration Test Results		Pass/Fail
* Average Y: 0.9860		PASS
Ave. Y w/in 5% of previous value:		YES
0.95 >= Y <= 1.05:		PASS
** Average dH: 1.698		PASS

Criteria:

* Y- ratio of the reading of the calibration meter (critical orifice) to the Meter Box DGM. Acceptable tolerance of individual values from the average is +/- 0.02.

** dH- the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air flow at 68 F and 29.92 in Hg, acceptable tolerance of individual values from the average is +/- 0.2.

Differential Pressure vs. Flow Rate



TRC

Console No.

1446

S. O. P. Reference

AM - 103

Temperature Display Type

Jenco - 765

Calibrator Type

Omega Model CL23A

Temperature Display Serial No.

2856R-078

Calibrator Serial No.

T239267

	Reference Temperature (° F)	32	Reference Temperature (° F)	212	Reference Temperature (° F)	500	Reference Temperature (° F)	1000	Reference Temperature (° F)	1500
Display Channel No.	Measured Temperature (° F)	Relative Error (%)	Measured Temperature (° F)	Relative Error (%)	Measured Temperature (° F)	Relative Error (%)	Measured Temperature (° F)	Relative Error (%)	Measured Temperature (° F)	Relative Error (%)
1 (Stack)	32	0.0	209	0.4	496	0.4	1000	0.0	1498	0.1
2 (Probe)	31	0.2	209	0.4	497	0.3	1001	-0.1	1498	0.1
3 (Filter)	30	0.4	209	0.4	497	0.3	1000	0.0	1498	0.1
4 (Dryer)	30	0.4	209	0.4	498	0.2	1001	-0.1	1499	0.1
5 (Aux)	31	0.2	208	0.6	498	0.2	1001	-0.1	1499	0.1
6 (DGM Inlet)	30	0.4	208	0.6	498	0.2	999	0.1	1499	0.1
7 (DGM Outlet)	31	0.2	208	0.6	498	0.2	999	0.1	1498	0.1

Relative Error must meet criteria of +/- 1.5 % (absolute temperature, ° R)

Operator

Neal Appleback

Date

4/19/11

APPENDIX D: CEMS DATA CO, THC, O2, CO2

07-08-2011 07:24:24

File Name: C:\Program Files\STRATA\T-601 ICR\config.str

Operator: J Glass
Plant Name: ExxonMobil BTRF
Location: SCU2 T-601
Run Length: 60 minutes
Sample Rate: 30 per minute
Average Calibration Results: 0.5 minutes
Automatic Sequence, Calibration Error: No
Automatic Sequence, System Bias: No
Max Response Time: Manual
Max Response Time: 1.5 minutes
Traverse During Run: No

Active	Chan.	Analyte Name	Units	Span Units	Span Volts	Offset Volts
Yes	1	O2	%	20.44	0.81	0
Yes	2	CO2	%	19.82	0.79	0
Yes	3	CO	ppm	404.2	0.8	-0.004
Yes	6	THC	ppm	100	10	0

Measurement System Preparation Table

Gas	Reference Cylinder Numbers															
Name	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
O2	Z	M	H					L								
CO2	Z	M	H					L								
CO	Z			M	H				L							
THC	Z					L	M	H								

Measurement System Preparation Table

Gas	Reference Cylinder Numbers
Name	17 18 19 20 21 22 23 24
O2	
CO2	
CO	
THC	

Gas	Zero Reference Cylinder			Low Reference Cylinder		
Name	No.	Conc	ID Number	No.	Conc	ID Number
O2	1	0	CC321614	8	4	
CO2	1	0	CC321614	8	4	
CO	1	0	CC321614	9	20	
THC	1	0	CC321614	6	25.07	CC128844

Gas	Mid Reference Cylinder			High Reference Cylinder		
Name	No.	Conc	ID Number	No.	Conc	ID Number
O2	2	10	XC031366B	3	20.44	CQ183442
CO2	2	10.01	XC031366B	3	19.82	CQ183442
CO	4	201.8	CC334116	5	404.2	CC40835N
THC	7	45.4	SG9165626BAL	8	85.74	SG9142486BAL

Seq Num	Calibration Error Test Sequence			
	O2	CO2	CO	THC
1	Zero	Zero	Zero	
2	High	High		
3	Mid	Mid		
4			High	
5			Mid	
6				Zero
7				High
8				Mid
9				Low
10				
11				
12				
13				
14				
15				

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

Seq Num	Calibration Error Valve Sequence															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	X															
2			X													
3		X														
4					X											
5				X												
6	X															
7								X								
8							X									
9						X										
10																
11																
12																
13																
14																
15																

Seq Num	System	Bias	Check	Sequence
1	O2	CO2	CO	THC
2	Zero	Zero	Zero	Zero
3	Mid	Mid		
4			Mid	
5				Mid
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

Seq Num	System	Bias	Valve	Sequence
1	X			
2		X		
3			X	
4				X
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				

Seq	Calibration	Error	Valve	Sequence
-----	-------------	-------	-------	----------

Num	17	18	19	20	21	22	23	24
-----	----	----	----	----	----	----	----	----

1								
---	--	--	--	--	--	--	--	--

2								
---	--	--	--	--	--	--	--	--

3								
---	--	--	--	--	--	--	--	--

4								
---	--	--	--	--	--	--	--	--

5								
---	--	--	--	--	--	--	--	--

6								
---	--	--	--	--	--	--	--	--

7								
---	--	--	--	--	--	--	--	--

8								
---	--	--	--	--	--	--	--	--

9								
---	--	--	--	--	--	--	--	--

10								
----	--	--	--	--	--	--	--	--

11								
----	--	--	--	--	--	--	--	--

12								
----	--	--	--	--	--	--	--	--

13								
----	--	--	--	--	--	--	--	--

14								
----	--	--	--	--	--	--	--	--

15								
----	--	--	--	--	--	--	--	--

Seq	System Bias Valve Sequence
Num	17 18 19 20 21 22 23 24
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	

STRATA Configuration End

Calibration Error Test, Run 1 STRATA Version 3.2

Operator: J Glass
Plant Name: ExxonMobil BTRF
Location: SCU2 T-601

	Reference Cylinder Numbers			
	Zero	Low-range	Mid-range	High-range
O2	CC321614		XC031366B	CC183442
CO2	CC321614		XC031366B	CC183442
CO	CC321614		CC334116	CC40835N
THC	CC321614	XC028402B	CC334116	969142406DAL

CC40835N AJ
PASSED

Date/Time	07-07-2011		08:26:24	
Analyte	O2	CO2	CO	THC
Units	%	%	ppm	ppm
Zero Ref Cyl	0.000	0.000	0.00	0.00
Zero Avg	0.085	0.009	0.49	0.27
Zero Error%	0.4%	0.0%	0.1%	0.1%
Low Ref Cyl				151.50
Low Avg				152.54
Low Error%				0.2%
Mid Ref Cyl	10.000	10.010	201.80	266.60
Mid Avg	10.025	10.124	203.62	269.28
Mid Error%	0.1%	0.6%	0.5%	0.5%
High Ref Cyl	20.440	19.820	404.20	437.70
High Avg	20.529	19.817	400.46	437.70
High Error%	0.4%	0.0%	0.9%	0.0%

Calibration Error Test End

Initial System Bias Check, Run 1 STRATA Version 3.2

Operator: J Glass
Plant Name: ExxonMobil BTRF
Location: SCU2 T-601

Reference Cylinder Numbers

	Zero	Span
O2	CC321614	XC031366B
CO2	CC321614	XC031366B
CO	CC321614	CC334116
THC	CC321614	CC334116

Date/Time 07-07-2011 08:34:55 PASSED

Analyte	O2	CO2	CO	THC
Units	%	%	ppm	ppm
Zero Ref Cyl	0.000	0.000	0.00	0.00
Zero Cal	0.085	0.009	0.49	0.27
Zero Avg	0.035	0.063	0.96	-0.19
Zero Bias%	0.2%	0.3%	0.1%	0.1%
Zero Drift%				
Span Ref Cyl	10.000	10.010	201.80	266.60
Span Cal	10.025	10.124	203.62	269.28
Span Avg	9.906	9.984	203.19	268.98
Span Bias%	0.6%	0.7%	0.1%	0.1%
Span Drift%				

System Bias Check End

Start Check

	O2 %	CO2 %	CO ppm	THC ppm
Begin calculating run averages				
07-07-2011 08:43:38	0.083	7.914	325.07	40.58
07-07-2011 08:44:38	0.073	7.873	325.13	40.10
07-07-2011 08:45:38	0.090	7.933	319.52	38.42
07-07-2011 08:46:38	0.091	7.957	301.81	38.52
07-07-2011 08:47:38	0.093	7.903	294.87	39.24
07-07-2011 08:48:38	0.089	7.876	303.87	39.14
07-07-2011 08:49:38	0.107	7.930	300.11	38.54
07-07-2011 08:50:38	0.098	7.952	296.68	38.84
07-07-2011 08:51:38	0.099	7.950	291.27	38.06
07-07-2011 08:52:38	0.104	7.924	288.30	38.31
07-07-2011 08:53:38	0.102	7.907	300.77	38.07
07-07-2011 08:54:38	0.106	7.963	311.97	38.76
07-07-2011 08:55:38	0.113	7.996	313.04	38.74
07-07-2011 08:56:38	0.109	8.010	317.94	38.48
07-07-2011 08:57:38	0.110	8.046	321.13	39.26
07-07-2011 08:58:38	0.112	8.037	330.06	41.15
07-07-2011 08:59:38	0.106	7.912	346.62	40.85
07-07-2011 09:00:38	0.113	7.962	342.86	39.09
07-07-2011 09:01:39	0.109	7.960	318.06	37.86
07-07-2011 09:02:39	0.115	7.890	306.34	37.80
07-07-2011 09:03:39	0.109	7.905	302.05	37.42
07-07-2011 09:04:39	0.111	7.887	283.95	37.48
07-07-2011 09:05:39	0.115	7.883	282.74	36.79
07-07-2011 09:06:39	0.112	7.870	282.88	36.40
07-07-2011 09:07:39	0.110	7.921	280.78	37.15
07-07-2011 09:08:39	0.121	7.924	283.24	37.49
07-07-2011 09:09:39	0.108	7.881	295.86	38.08
07-07-2011 09:10:39	0.119	7.940	298.93	37.82
07-07-2011 09:11:39	0.111	7.950	292.02	38.34
07-07-2011 09:12:39	0.121	8.018	295.22	38.48
07-07-2011 09:13:39	0.123	7.981	308.19	39.42
07-07-2011 09:14:39	0.111	7.940	340.16	39.38
07-07-2011 09:15:39	0.123	8.033	358.46	39.29
07-07-2011 09:16:39	0.117	7.955	356.20	39.69
07-07-2011 09:17:39	0.121	7.856	357.52	38.99
07-07-2011 09:18:39	0.118	7.869	351.62	39.04
07-07-2011 09:19:39	0.119	7.895	337.10	38.98
07-07-2011 09:20:39	0.120	7.804	324.74	39.03
Run Averages	0.108	7.930	313.10	38.66

07-07-2011 09:21:36 0.108 7.930 313.10 38.66
 Operator: J Glass
 Plant Name: ExxonMobil BTRF
 Location: SCU2 T-601
 Test Run 1 End

02

CO2

0.1026

7.9536

- 0.124

14

7.9013

- 0.1131

- 0.1190

7.9166

Initial System Bias Check, Run 1 STRATA Version 3.2

Operator: J Glass
Plant Name: ExxonMobil BTRF
Location: SCU2 T-601

Reference Cylinder Numbers

	Zero	Span
O2	CC321614	XC031366B
CO2	CC321614	XC031366B
CO	CC321614	CC334116
THC	CC321614	CC334116

Date/Time	07-07-2011		10:09:01	PASSED
Analyte	O2	CO2	CO	THC
Units	%	%	ppm	ppm
Zero Ref Cyl	0.000	0.000	0.00	0.00
Zero Cal	0.085	0.009	0.49	0.27
Zero Avg	0.164	0.088	1.19	-0.90
Zero Bias%	0.4%	0.4%	0.2%	0.2%
Zero Drift%				
Span Ref Cyl	10.000	10.010	201.80	266.60
Span Cal	10.025	10.124	203.62	269.28
Span Avg	10.006	10.004	202.38	268.26
Span Bias%	0.1%	0.6%	0.3%	0.2%
Span Drift%				

System Bias Check End

	O2 %	CO2 %	CO ppm	THC ppm
Begin calculating run averages				
07-07-2011 11:31:19	0.161	7.940	379.66	30.88
07-07-2011 11:32:19	0.158	7.929	390.24	32.04
07-07-2011 11:33:19	0.159	7.925	398.22	32.55
07-07-2011 11:34:19	0.164	7.875	396.87	32.24
07-07-2011 11:35:19	0.159	7.861	383.85	30.61
07-07-2011 11:36:19	0.154	7.907	367.84	31.08
07-07-2011 11:37:19	0.165	7.859	350.13	31.64
07-07-2011 11:38:17	0.158	7.789	352.34	33.35
07-07-2011 11:39:17	0.165	7.772	353.47	34.83
07-07-2011 11:40:17	0.159	7.847	345.63	36.17
07-07-2011 11:41:17	0.161	7.840	331.86	37.47
07-07-2011 11:42:17	0.162	7.850	339.15	38.60
07-07-2011 11:43:17	0.160	7.874	340.81	38.94
07-07-2011 11:44:17	0.158	7.877	335.99	40.68
07-07-2011 11:45:17	0.164	7.857	342.39	41.26
07-07-2011 11:46:17	0.156	7.828	345.06	42.64
07-07-2011 11:47:17	0.163	7.872	349.55	40.79
07-07-2011 11:48:17	0.164	7.988	362.62	39.15
07-07-2011 11:49:17	0.165	8.032	366.23	37.38
07-07-2011 11:50:18	0.157	7.959	374.78	36.67
07-07-2011 11:51:18	0.160	7.961	391.30	35.20
07-07-2011 11:52:18	0.165	7.939	379.28	34.14
07-07-2011 11:53:18	0.162	7.872	359.80	33.82
07-07-2011 11:54:18	0.162	7.890	355.98	32.69
07-07-2011 11:55:18	0.161	7.892	348.39	32.43
07-07-2011 11:56:18	0.163	7.850	347.01	31.45
07-07-2011 11:57:18	0.161	7.902	344.07	32.10
07-07-2011 11:58:18	0.160	7.871	338.80	32.41
07-07-2011 11:59:18	0.168	7.918	343.76	32.18
07-07-2011 12:00:18	0.164	7.881	334.96	31.26
07-07-2011 12:01:18	0.158	7.883	338.02	30.81
07-07-2011 12:02:18	0.162	7.951	347.54	31.55
07-07-2011 12:03:18	0.166	7.924	348.14	34.31
07-07-2011 12:04:18	0.161	7.953	368.75	35.55
07-07-2011 12:05:18	0.169	7.995	381.79	34.41
07-07-2011 12:06:18	0.167	7.985	389.48	35.04
07-07-2011 12:07:18	0.166	7.981	387.27	32.99
07-07-2011 12:08:18	0.163	7.906	364.56	34.85
07-07-2011 12:09:19	0.166	7.858	354.41	35.23
07-07-2011 12:10:19	0.164	7.822	351.81	35.09
07-07-2011 12:11:19	0.171	7.857	351.16	34.18
07-07-2011 12:12:19	0.163	7.844	345.15	32.14
07-07-2011 12:13:19	0.161	7.859	331.98	34.64
07-07-2011 12:14:19	0.169	7.882	322.98	33.34
07-07-2011 12:15:17	0.165	7.840	319.44	33.22
07-07-2011 12:16:17	0.165	7.839	325.09	32.47
07-07-2011 12:17:17	0.167	7.924	333.95	33.19
07-07-2011 12:18:17	0.173	7.927	335.17	33.08
07-07-2011 12:19:17	0.165	7.858	344.61	32.13
07-07-2011 12:20:18	0.167	7.848	352.77	33.55
07-07-2011 12:21:18	0.170	7.873	360.29	31.85
07-07-2011 12:22:17	0.169	7.985	363.78	33.13
07-07-2011 12:23:17	0.162	7.970	369.40	34.48
07-07-2011 12:24:17	0.166	8.040	376.34	33.86
07-07-2011 12:25:17	0.173	7.944	370.61	32.89
07-07-2011 12:26:17	0.171	7.882	368.65	33.52
07-07-2011 12:27:17	0.167	7.906	362.74	32.71
07-07-2011 12:28:17	0.168	7.861	348.11	32.85
07-07-2011 12:29:17	0.168	7.865	352.10	33.32
07-07-2011 12:30:17	0.171	7.855	340.24	30.37
Run Averages	O2 %	CO2 %	CO ppm	THC ppm
07-07-2011 12:30:17	0.164	7.896	355.97	34.12
Operator:	J Glass			
Plant Name:	ExxonMobil BTRF			
Location:	SCU2 T-601			
Test Run 1 End				

Final System Bias Check, Run 1 STRATA Version 3.2

Operator: J Glass
 Plant Name: ExxonMobil BTRF
 Location: SCU2 T-601

Reference Cylinder Numbers

	Zero	Span
O2	CC321614	XC031366B
CO2	CC321614	XC031366B
CO	CC321614	CC334116
THC	CC321614	CC334116

Date/Time	07-07-2011	12:39:38	PASSED
Analyte	O2	CO2	CO
Units	%	%	ppm
Zero Ref Cyl	0.000	0.000	0.00
Zero Cal	0.085	0.009	0.49
Zero Avg	0.197	0.078	1.09
Zero Bias%	0.5%	0.3%	0.1%
Zero Drift%	0.2%	-0.1%	0.0%
Span Ref Cyl	10.000	10.010	201.80
Span Cal	10.025	10.124	203.62
Span Avg	10.002	9.949	201.36
Span Bias%	0.1%	0.9%	0.6%
Span Drift%	0.0%	-0.3%	-0.3%
Ini Zero Avg	0.164	0.088	1.19
Ini Span Avg	10.006	10.004	202.38
Run Avg	0.164	7.896	355.97
Co	0.180	0.083	1.14
Cm	10.004	9.976	201.87
Correct Avg	-0.017	7.905	356.72
System Bias Check End			