

Date 1-31-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

WORK ORDERS

Jobs Completed

Employees on Job

KM

Vehicles or Equip. Used

11

Sewer Department

Address

Superior

Removed Pump Pad on Superior  
Turned off STATIONS FOR VILLAGE

Job Completed

DT - KM

Install Control Panel + Wire  
Pump + Panel AT Lady of the Snows  
Lift Station

Employees on Job

BS  
BF

Vehicles or Equip. Used

7-14

Meter Readers

Employees on Job

TC

ROAD AREAS 1-2

Areas - Read

1-2

Vehicles Used

3

General Foreman

B. D. Dural

Date 1-30-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job C.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD + BELLEVUE - RAN BLUFF FOR 1/2 HOUR AT END OF DAY
Job Completed	REMOVED FALSE FLOOR FOR PUMP AT SUPERIOR - NEED TO REMOVE OUTER ROBE & GRIND FLOOR FOR WELDING
Employees on Job F.P. - B.S. - K.M.	
Vehicles or Equip. Used 7-14-15 - TORCH SET	

Meter Readers

Employees on Job T.C.	FINISHED 16, 25, 27, 30
Areas - Read	
Vehicles Used 8	

General Foreman Frank J. Pace



Date 1-29-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W/O.
Jobs Completed	
Employees on Job G.F. - T.C. JHR	
Vehicles or Equip. Used 8-11	

Sewer Department

Address	REMOVED PUMP #2 CLEANED OUT SUMP W/EL & SUMP PUMP, CLEANED FLOOR. PRIMED PUMP T-1 & GOT PUMPING - PUMPING NOW
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST. <b>Ex. 7f (Water Infra.)</b> BELLEVUE
Employees on Job F.P. - B.S. - K.M.	CYCLED BLOWERS AT OAKLAND & CROCKETTS CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 14-7-15	BY-PASS PUMP AT CLINTON KICKING OUT STARTER - NEEDS PULLED

Meter Readers

Employees on Job G.F. - T.C. GHR	FINISHED 22-T.C. 23-24-26-G.F.
Areas - Read	
Vehicles Used 8-11	
General Foreman <u>Frank J. Price</u>	

Date 1-26-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		REPAIRED MAIN BREAK AT SADDLE AT Ex. 6 (Personal Privacy) ONE 4" P.V.C. JOINT, REPAIR CLAMP WITH 2" IRP & ONE 3/4" X 3/4" COPR. STOP BACK FILLED WITH SPOIL
Jobs Completed		TURNED ON COPR STOP AT MAIN, installed meter & turned on for cust at Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S.		REBUILT SERVICE AT Ex. 6 (Personal Privacy) ONE 3/4" P.V.C. BARB X 3/4" COMP. FITTING, ONE 3/4" X 3/4" COMP. FITTING, ONE METER SHUT OFF, ONE METER COUPLING ONE 18" X 30" P.V.C. METER BOX & 15' OF 3/4" COPPER
Vehicles or Equip. Used 14 - BACKHOL		BACK FILLED WITH SPOIL GRADED ROCK AT CHURCH Ex. 6 (Personal Privacy)

<u>Sewer Department</u>		Comments
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 715 Ex. 7f (Water Infra.) RICE BOX
Employees on Job K.M.		CYCLED PUMP AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT BARKLEY Ex. 7f (Water Infra.) CYCLED BY-PASS PUMP AT CLINTON
Vehicles or Equip. Used 15		

<u>Meter Readers</u>		Comments
Employees on Job G.F. - K.M.		FINISHED 20 & 21 - G.F. 24 - K.M.
Areas - Read		STARTED 22 - G.F. 26 - K.M.
Vehicles Used 11		

General Foreman	Frank J. Pace
-----------------	---------------

Date 1-25-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	REPLACED LEAKING SADDLE AT USED ONE 4" A.C. SADDLE, ONE 3/4" x 3/4" COMP. STOP, ONE 3/4" x 3/4" COMP. FITTING, 2' OF 3/4" COPPER ONE LOAD CLEAN ROCK FOR BACKFILL - NEEDED 6" x 6" Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - G.P. GHR	EXPOSED VALVES COVERED IN STREET & EXERCISED AT Ex. 6 (Personal Privacy) PREP FOR LEAK REPAIR	
Vehicles or Equip. Used	11-14 - BACKHOLE	
<u>Sewer Department</u>		
Address	JACKETED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) JACKETED LATERAL TOO	
Job Completed		
Employees on Job K.M. - T.C. JHR		
Vehicles or Equip. Used	15-9	
<u>Meter Readers</u>		
Employees on Job T.C. - K.M. GHR	STARTED 24-K.M. 20-T.C.	
Areas - Read	FINISHED 23-K.M.	
Vehicles Used	8-15	
General Foreman	Frank J. Pace	



Date 1-24-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

Ex. 6 (Personal Privacy)

Repaired 14" x 1" MAIN AT  
- with compression  
FITTINGS + BARB -

Jobs Completed

EXPOSED RUSTED OFF SADDLE  
AT

Ex. 6 (Personal Privacy)

Employees on Job

Vehicles or Equip. Used

14-15 - BACK HOE  
DUMP TRUCK - HAMMER

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

*B. Smith*

Date 1-23-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

Service TRUCK WORK ORDERS

Jobs Completed

REPAIRED LEAK AND RETIRED SERVICE  
AT **Ex. 6 (Personal Privacy)**

Employees on Job

GF  
BS FP

SPREAD ROCK AT CHOKCH

**Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

11  
14 BACK HOESewer Department

Address

INSTALLED NEW MOTOR AT  
PUMPED DOWN 71ST - PUMP NEEDS  
PULLED AT 75TH **Ex. 6 (Personal Privacy)****Ex. 6 (Personal Privacy)**

Job Completed

PULLED PUMP AT SNOWS + REMOVAL  
RAGS - WOULDN'T RUN - BROUGHT TO  
SHOP

Employees on Job

PULLED PUMP BEHIND  
FOUND NO RAGS**Ex. 7f (Water Infra.)****Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

RE-SET PUMP - STARTER  
STILL KICKING OUT

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 1-22-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	OVERTIME	
Jobs Completed	REPAIRED 6" C.I.F. MAIN BREAK AT <div style="background-color: black; color: red; padding: 2px;">Ex. 6 (Personal Privacy)</div> PUT OUT BELL, TWO 501 EXTREMES, 18" OF C-900 P.R.C., ONE LOAD OF CLEAN ROCK - REFER TO D.J.S. FROM 1-22-18	
Employees on Job F.P. - B.S. - K.M.		
Vehicles or Equip. Used 14-15-BACKHOE		
<b>Sewer Department</b>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<b>Meter Readers</b>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	



Date 1-22-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.D. - 4HR ONLY REPAIRED 3" C.I. MAIN BREAK AT USED ONE 2" C.I. S.S. REPAIR CLAMP - BACKFILLED WITH CLEAN ROCK & C-MG ROCK FROM STOP	
Jobs Completed	REPLACED SADDLE FOR USED ONE 6" PVC SADDLE, ONE 2" X 1/2" COUPLER, STOP, 2' OF 3/4" COPPER TUBING. BACKFILLED WITH SPOIL - NEEDED TO REPLACE WITH ROCK	
Employees on Job	REPAIRED 6" C.I. MAIN BREAK AT CUT OUT 18" OF MAIN AROUND BELL - USED TWO 6" SOF EXTRUDERS & 18" OF 6" C-900 P.V.C. BACKFILLED WITH ONE LOAD CLEAN ROCK AROUND	
C.F. - F.P. - B.S. - K.M. 4HR 2HR		
Vehicles or Equip. Used	MAIN - NEED TO REPLACE CULVERT & REPAIR DRIVEWAY 11-14-15 - BOTH BACKHOES	
Sewer Department		
Address	CHECKED STATIONS	
Job Completed	REMOVED MOTOR FROM OAKLAND - WIRED UP NEW MOTOR FOR OAKLAND	
Employees on Job	K.M. 6HR	
Vehicles or Equip. Used	15	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky. Pace</u>		

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Date 1-19-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

OVERTIME - 1 HR

Jobs Completed

REPAIRED MAIN BREAK AT  
CAROL - REFER TO 1-19-18 REPORT  
FOR PARTS

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C.

Vehicles or Equip. Used

14-6 - BOTH  
BACKHOESSewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

F. J. P. [Signature]

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED MAIN BREAK AT <b>Ex. 6 (Personal Privacy)</b> USED ONE 8" SOI DRESSER, ONE 2" COMEX 2" LPL FITTING, ONE 2" LPT & 4" M.J. FITTING, ONE SOI EXTREME DRESSER, 12" OF SDR 21 2" P.P.C., 102"	
Employees on Job F.P. - B.S. - G.F. - T.C.	O.F.C. - 900 4" P.V.C., BLOCKING UNDER FITTINGS * BEHIND 22" FITTING, BACKFILLED WITH ONE LOAD CLEAN ROCK & SPOIL	
Vehicles or Equip. Used BOTH <b>Ex. 6 (Personal Privacy)</b> 11-14-6 - BACKHOES	REPAIRED 2" C.I. MAIN BREAK AT USED ONE 2" C.I. SS REPAIR CLAMP - BACKFILLED WITH LOAD CLEAN ROCK & LOAD C.M.-6 ROCK FROM SHOP	

Sewer Department		Comments
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX CALVIN BLVD	
Job Completed	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b> CYCLED BY-PASS PUMP AT CLINTON	
Employees on Job K.M.		
Vehicles or Equip. Used 15		

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Franky-Pace



<u>Water Department</u>	
Comments	
Address	SERVICE TRUCK W.O. REPLACED LEAKING 8" C.I. CLAMP & FILLED HOLE WITH ROCK & GRAVEL AT <b>Ex. 6 (Personal Privacy)</b>
Jobs Completed	EXPOSED BROKEN MAIN ON <b>Ex. 6 (Personal Privacy)</b> FOUNDA BRRAK ON 90° FITTING - NEED PARTS TO REPAIR
Employees on Job F.P. - B.S. - G.F. - T.C. GWR	
Vehicles or Equip. Used	
11-14-6 - BACKHOLE	
<u>Sewer Department</u>	
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLER PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLER BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b> CYCLER BY-PASS PUMP AT CLINTON
Employees on Job K.M. - T.C. JWR	TESTED LINE TO RELIEVE BACKUP IN <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used	
15-9	
<u>Meter Readers</u>	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	<u>Frank J. Pace</u>

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	SHUT DOWN VALVES + INSTALLED CLAMP AT <b>Ex. 6 (Personal Privacy)</b> CLAMP LEAKING 2 MEAS REPLACED VALVES DON'T SHUT DOWN
Employees on Job F.P. - B.S. - K.M. G.F. - T.C. 4 HR	Installed New Clamp over Rust + debris New Clamp leaking.
Vehicles or Equip. Used	
6-11-14-15 BACKHOLE	

Sewer Department

Address	REMOVED ASSEMBLY + CLEANED RAGS OUT OF ASSEMBLY + OUT OF CHECK VALVE - REPLACED FLAPPER - PUMPING NOW
Job Completed	
Employees on Job F.P. - B.S. - K.M. 4 HR	
Vehicles or Equip. Used	
14-15	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 1-16-18 APPENDIX B #5

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>	
Comments	
Address	OVERTIME 1 HR
Jobs Completed	WORKED THROUGH LUNCH & 1/2 OVR AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job <i>F.R. - G.R. - T.C. - R.M.</i>	
Vehicles or Equip. Used	
<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <i>Frank J. Pace</i>	



Date 1-16-18

APPENDIX B #5

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	BROKE OUT ROAD WITH HYDRO HAMMER EXPOSED STORM SEWER, DUPO WATER MAIN, OLD GAS MAIN, OUR 3" WATER MAIN, TO REPAIR BREAK, PUMPS FROZE UP & COULD
---------	--

Jobs Completed	NOT MAKE REPAIR, RIBBONED OFF HOLE SHUT DOWN 5 VALVES AT JEROME
----------------	---

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Employees on JobF.P. - G.F. - T.C. - K.M.  
4HRVehicles or Equip. Used14-6-15- BOTH  
BACKHOESSewer DepartmentAddressJob CompletedBY-PASS PUMPS WITH 3" GAS PUMP AT  
71ST

Ex. 7f (Water Infra.)

PILL BOX

Employees on JobK.M.  
4HRCYCLED PUMP AT  
CYCLED BLOWERS AT  
CYCLED BY-PASS PUMP AT CLINTON

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

15

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Rose

<u>Water Department</u>		Comments
Address	CALL OUT - DOUBLE TIME	
Jobs Completed	CHECKED LEAK AT CAMOKIA - GOING INTO STORM SEWER CALLED IN LOCATE	
Employees on Job	F.P.	
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Ex. 6 (Personal Privacy)

Date 1-15-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

**Meter Readers**

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. PaceHOL  
DAYM  
L  
K.

DAY



Water Department		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	SHUT OFF CORP, STOP AT MAIN TO STOP LEAK AT <b>Ex. 6 (Personal Privacy)</b> TO MAKE PULL UNDER ROAD TO RESTORE SERVICE	
Employees on Job F.P. - B.S. - G.P.	REBUILT SERVICE AT <b>Ex. 6 (Personal Privacy)</b> IMPROVED LINK OUTSIDE BOX, INSTALLED NEW SHUT OFF 7-18" X 30" P.V.C. WATER BOX, BACKFILLED WITH SPOIL & ONE BUCKET OF C-M-G ROCK	
Vehicles or Equip. Used 11-14-BACKHOLE	GRADED ROCK WHERE MAIN BREAK WAS REPAIRED AT JEROME <b>Ex. 6 (Personal Privacy)</b>	
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job T.C.	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b> CYCLED BY-PASS PUMPS AT CLINTON <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	TRIED TO OPERATE SHUT OFF AT BUT COULDN'T GET OPEN - CUST WITHOUT SERVICE DUG OUT BOX - OLD SET CAN'T CRIMP OFF - NEEDS REBUILT	
Employees on Job G.F.	REMOVED JUMPER AT	
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address	JETTED LINE TO RELIEVE BACKUP AT	
Job Completed	CYCLED PUMP AT WILLIE FORMAS CYCLED BLOWERS AT OAK CYCLED BY-PASS PUMP AT	
Employees on Job T.C. - B.S. 4MR	CRACKED ROCK IN ROAD AT CHECKED STATIONS - FLOAT BALL BAD ON PUMP BEHIND	
Vehicles or Equip. Used 9-15 - BACKHOLE		
Meter Readers		
Employees on Job F.P. - T.C. 4MR	FINISHED 3-F.P.	
Areas - Read	STARTED 6-T.C.	
Vehicles Used 8-14		
General Foreman	Frank J. Rose	



Date 1-16-18

Daily Job Sheet

Sheet     of    

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	REPAIRED 4" A.C. MAIN BREAK AT CUT OFF OLD LEAKING REPAIR CLAMP & REPLACED WITH A JOY LONG X 4" A.C. S.S. REPAIR CLAMP BACKFILLED WITH ONE BUCKET CLEAN ROCK & SPOL Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - G.F. - T.C. 5.5 HRS	HOOKED UP SERVICE LINE TO FILLED HOLE IN ROAD WITH CLEAN ROCK & C-M-G ROCK WHERE SADDLE WAS REPLACED FOR Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 11-14-G-BACKHOE	FILLED HOLE WITH CLEAN ROCK & C-M-G ROCK WHERE MAIN BREAK WAS REPAIRED AT Ex. 6 (Personal Privacy)	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job G.F. - T.C. 2.5 HRS	FINISHED 29	
Areas - Read		
Vehicles Used 8		
General Foreman	Frank J. Pace	



ate 1-9-18

## Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Department	Comments
IS	SERVICE TRUCK W.O.
Completed	REPAIRED 4" C.I. MAIN BREAK AT COOPER - USED ONE 4" C.I. S.S. REPAIR CONDUIT NEED TO BACKFILL
Employees on Job F.P. - B.S. - G.F. - T.C. 4 HR	REPLACED SADDLE FOR INSTALLED CORP STOP FOR EXISTING SADDLE - USED ONE 2" x 3/4" A.S.C. SADDLE
Vehicles or Equip. Used 11-14-G - BOTH BACKHOES	TWO 3/4" CORP STOPS - NEED TO HOOK SERVICE & BACKFILL
<b>Sewer Department</b>	
Address	JETTED LINE TO RELIEVE BACKUP ON HER LATERAL IS STILL HOLDING OUR LINES DOWN
Job Completed	WORKED WITH CITY OF CENTREVILLE IN 2 1/2 HRS
Employees on Job K.M. - T.C. 4 HR	BY-PASS PUMPED AT NEED TO JET LINE TO RELIEVE BACKUP IN OR.
Vehicles or Equip. Used 15-9	BY-PASS PUMPED CALVIN BLVD. CYCLED
<b>Meter Readers</b>	
Employees on Job	Note: WAS DAMAGED
Areas - Read	when Repairing Leak at AT 1-9-18
Vehicles Used	
General Foreman	From J. Foss

Date 1-8-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	BROKE PAVEMENT WITH HYDRO HAMMER EXPOSED MAIN + FOUND LEAK AT <b>Ex. 6 (Personal Privacy)</b> REPAIRED LEAK	
Employees on Job F.P. - B.S. - G.F. - T.C. 3 HR	WITH ONE 6" C.I. SS REPAIR CLAMP BACKFILLED WITH ONE 1/2 TRUCK LOADS OF CLEAN ROCK FROM QUARRY THREE	
Vehicles or Equip. Used 11-6 - 14-15 - BOTH BACKHOES	BACKHOLE BUCKETS OF C-17-6 ROCK FROM SHOP - STOCK PILED SOME SPOIL ON HOWELL IN VACANT LOT.	
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX	
Employees on Job K.M. 5 HR	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS A CYCLED BY-PASS PUMP AT CLINTON	
Vehicles or Equip. Used 15		
<b>Meter Readers</b>		
Employees on Job T.C. - G.F. - K.M. 4 HR 5 HR 1 HR	STARTED <b>Ex. 6 (Personal Privacy)</b> SIED	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		



Water Department		Comments
Address	SERVICE TRUCK W.O. TOOK APART HYDRO-HAMMER	
Jobs Completed	REPAIRED 6" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) HAMMERED OUT ROAD WITH HYDRO HAMMER & EXPOSED MAIN/LEAK INSTALLED	
Employees on Job F.P. - B.S. - G.F. - T.C. - K.M. 3MR	ONE 6" S.S. REPAIR CLAMP - BACKFILLED WITH ONE LOAD CLEAN ROCK & 1/2 LOAD C-M-G ROCK	
Vehicles or Equip. Used HYDRO HAMMER 6-11-14-15 BOTH BACKHORS	HAULED ROCK TO SHOP FROM QUARRY LOOKED FOR LEAK ON RANCH BETWEEN HOWELL Ex. 6 (Personal Privacy) HAMMER BROKE	

Sewer Department		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 7159 Ex. 7f (Water Infra.) LL BOX, BELLEVUE	
Employees on Job K.M. 5MR	CYCLED PUMP AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED BY-PASS PUMP AT CLINTON	
Vehicles or Equip. Used 15	SNOWS NOT PUMPING	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Franky. Pace

Date 1-4-18

APPENDIX B #5

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	OVAR TIME TIME + 1/2	
Jobs Completed	REPLACED LEAKING 4" x 4" x 4" TEE AT <b>Ex. 6 (Personal Privacy)</b> REFER TO DAILY JOB SHEET ON 1-4-18 FOR PARTS	
Employees on Job F.P. - B.S. - T.C. - K.M.		
Vehicles or Equip. Used		
BOTH BACKHOES - C-14-15		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 1-4-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W/O.

Jobs Completed

REPAIRED ROAD AT **Ex. 6 (Personal Privacy)**  
WHERE MAIN BREAK WAS REPAIRED  
USED ONE LOAD CLEAN ROCK & 1/2 LOAD  
C-M-G ROCK

Employees on Job

F.P. - B.S. - G.F. - T.C. - K.M.

REPLACED LEAKING TEE AT **Ex. 6 (Personal Privacy)**  
SPARKS - HAMMERED OUT ROAD, CUT OUT  
TEE & REPLACED - USED ONE 4"X4"X4"  
TEE, 7' OF C-900 4" P.V.C. PIPE, ~~2" TEE~~

Vehicles or Equip. Used

TWO 4" 501 EXTREME DRILLERS & FOUR  
4" FLANGE KITS - BACKFILLED WITH TWO  
TRUCK LOADS OF CLEAN ROCK & 1/2 LOAD  
OF C-M-G ROCK FROM SHOP6-11-14-15 BOTH  
BACKHOESSewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-3-18

APPENDIX B #5

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address

*OVERTIME - TIME 4 1/2*

Jobs Completed

*REPAIRED 4" C.I. MAIN BREAK AT  
USED ONE 4" C.I.  
S.S. REPAIR CLAMP - BACKFILL WITH SOIL*

Ex. 6 (Personal Privacy)

Employees on Job

*F.P. - B.S. - T.C.  
8 HR 6 HR 6 HR**SHUT DOWN SPRINKLER SYSTEM FOR*

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

*14-15 - BACKHOL*Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

*Frank J. Pace*



Date 1-3-18 APPENDIX B #5

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O. PUMPED WATER AWAY FOR 6 HR - THEN REPAIRED 6" MAIN BREAK AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> USED ONE 4" C.I. S.S. REPAIR CLAMP BACKFILLED WITH SPOIL	
Jobs Completed	REPAIRED 4" C.I. MAIN BREAK AT COOPER <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> BROKE ROAD CURB WITH HYDRO HAMMER & CHASED MAIN TO FIND BREAK - REPAIRED WITH 4" C.I. S.S.	
Employees on Job	REPAIR CLAMP - BACKFILLED WITH ONE TRUCK LOAD OF CLEAN ROCK - NEEDED MORE CLEAN ROCK & C-M-G ROCK ON TOP. BARRICADED & RIBBONED OFF HOLE	
Vehicles or Equip. Used	LOCATED, THAWED WITH TORCH & SHUT DOWN VALVES FOR MAIN BREAK AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span>	
G-11-14-15 - BOTH BACKHOES		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

<u>Water Department</u>		Comments
Address	OVERTIME TIME 7 1/2	
Jobs Completed	FINISHED GRADING ROCK AT CLARITA WHERE 6" MAIN BREAK WAS REPAIRED	
Employees on Job F.P. - T.R. - K.M.	LOCATED, DUG UP & SHUT OFF TWO VALVES ACROSS FROM BOND	
Vehicles or Equip. Used 14-15-6 - BACKHOE	SHUT OFF WATER METER AT RANGE DUE TO BROKEN PIPES IN HOUSE	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	



Date 1-2-18 APPENDIX B #5

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	REPAIRED 6" C.T. MAIN BREAK AT OLD MC [REDACTED] LAYED ONE 6" C.I. S.S. REPAIR CLAMP. BACKFILLED WITH ONE TRUCK LOAD OF CLEAN ROCK & 2 BUCKETS OF C.M. & ROCK FROM SHOP	
Jobs Completed		
Employees on Job F.P. - T.C. - K.M. 4 HR		
Vehicles or Equip. Used 6-14-15 BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST [REDACTED] FILL BOX	
Job Completed	CYCLED PUMP AT [REDACTED] CYCLED BLOWERS AT OAKLAND [REDACTED] CYCLED BY-PASS PUMPS AT CLIN [REDACTED]	
Employees on Job K.M. 4 HR		
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 2-28-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	EXPOSED CORP STOP & TURNED ON & INSTALLED R.R. METER & LID AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S. - G.F.	EXPOSED CORP STOP & SHUT OFF, REPLACED BROKEN METER SHUT OFF AT <b>Ex. 6 (Personal Privacy)</b> R.R. METER BELT - USED ONE 7/8" X 3/4" COMP. FITTING & ONE METER SHUT OFF & 8' OF 3/4" COPPER TUBING.	
Vehicles or Equip. Used 11-14-BACKHOLE	EXPOSED GAS MAIN & 8" C.I. WATER MAIN, FOUND TAP FOR <b>Ex. 6 (Personal Privacy)</b>	

Sewer Department

Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> 7116 BOX, CALVIN BLVD.	
Employees on Job K.M.	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A CYCLED BY-PASS PUM	
Vehicles or Equip. Used 15		

Meter Readers		
Employees on Job T.C.	FINISHED 29, 30, 27, 25	
Areas - Read	STARTED 16 & 1	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 2-27-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.D.
Jobs Completed	REPLACED LEAKING SADDLE AT CUT ROAD & EXPOSED MAIN, REMOVED CEARING SADDLE & REPLACED WITH 6" A.C. SADDLE, 3/4" X 3/4" CORR. STOP, 3/4" X 3/4" CORR. FITTING, 1' OF 3/4" COPPER TUBING - BACK FILLED WITH SPOIL IN YARD & C-M-L ROCK IN ROAD
Employees on Job F.P. - B.S. - G.F.	
Vehicles or Equip. Used 11-14 - BACKHOL	

Ex. 6 (Personal Privacy)

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job T.C. - K.M.	FINISHED 29
Areas - Read	
Vehicles Used 7	
General Foreman Frank J. Pace	



Date 2-26-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W/O.  
LOCATORS

Jobs Completed

Employees on Job

F.P. - B.S. - T.C. - G.F.  
6 HRREPLACED SADDLE ON MAIN FOR  
BENEDICT - USED ONE 6" A.C. SADDLE, ONE 3/4" X 1/2"  
CORP STOP, ONE 3/4" P.V.C. BARBX CORR. FITTING, 10'  
OF 3/4" COPPER TUBING, BACKFILLED WITH SPOILT  
Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

2 BUCKETS OF C-MG ROCK WHERE SIDE WALK  
WAS REMOVED.

6-11-14 - BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
TIST Ex. 7f (Water Infra.) PILL BOX

Job Completed

CYCLED PUMP AT Ex. 6 (Personal Privacy)  
CYCLED BLOWERS AT  
CYCLED BY-PASS PUMP Ex. 7f (Water Infra.)

Employees on Job

K.M. F.P. - B.S. - T.C.  
4 HR 2 HRPULLED PUMP BEHIND  
+ CLEANED OUT RACE - CHANGED BURNED  
WIRE ON BREAKER - PUMP NOT PUMPING  
IMPELLER IS FREE - INSTALLED JUMPER WIRE  
Ex. 7f (Water Infra.)

Vehicles or Equip. Used

15-14-8 - BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank P. Pace



Date 2-23-18

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address	Service TRUCK WORK ORDERS DISCONNECTED <b>Ex. 6 (Personal Privacy)</b> from WATER MAIN - CLEANED UP	
Jobs Completed	JOB SITE AT <b>Ex. 6 (Personal Privacy)</b> SWEEP THE GARAGE	
Employees on Job GF BS TC	CHECKED OUT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 11 14		
<u>Sewer Department</u>		
Address	BY PASSED 71ST + CHICK BLOWERS AT 73RD ALSO RAN	
Job Completed	75TH <b>Ex. 7f (Water Infra.)</b> CHECKED PH 2 STATIONS	
Employees on Job Km BS	CUSTOMERS PROBLEM AT NELSON + <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 15 14		
Meter Readers		
Employees on Job Km BS		
Areas - Read		
Vehicles Used		
General Foreman	<u>B. Shurt</u>	

Date 2-22-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

Service TRUCK w/o's  
GRADED ROCK AT 50TH

Ex. 6 (Personal Privacy)

Jobs Completed

Employees on Job

GF  
BS

Vehicles or Equip. Used

11  
BACK HOESewer Department

Address

PULLED PUMP AT 50TH ST - REMOVED PUMPS  
BACK IN SERVICE -

Job Completed

FITTED UP INTAKE AT SUPERIOR ON NEW  
PUMP - BY PASSED 75TH

Employees on Job

BS TC  
KM

UNSUCCESSFULLY JETTED

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

JET - 14-15

Meter Readers

Employees on Job

GF  
TC

Areas - Read FINISH 22

READ 26

Vehicles Used

11  
8

General Foreman

Boris [Signature]



Date 2-21 18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

Service TRUCK work orders

Jobs Completed

Employees on Job

BS  
GF

Vehicles or Equip. Used

14  
11Sewer Department

Address

Pumped Belview 4 HRS -  
Pumped 71ST - cycled BLOWERS AT 73rd

Job Completed

Ex. 6 (Personal Privacy)

Employees on Job

- Km  
BS-DTRemoved RIGGS FROM Bridgedale  
+ Re-SET STARTER

Vehicles or Equip. Used

15  
14

Meter Readers

Employees on Job

GF  
TCAreas - Read 20<sup>th</sup> 21<sup>st</sup> STARTED 22<sup>nd</sup>

23-24 FINISHED

Vehicles Used

11  
8

General Foreman

B. [Signature]



Date 2-20-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

Km

GF

Vehicles or Equip. Used

11-8

Sewer Department

Address

BY PASSED 75TH CYCLED  
BLOWAS AT 73rd

Job Completed

REPLACED TARP AT BEECHLAND  
BRIDGEDALE HAS RAGS IN IT

Employees on Job

BS

Km

J LAURA LEE WELL RUNNING  
OVER - PUMP NOT WORKING

Vehicles or Equip. Used

14 BS  
15 Km

ALL OTHER STATIONS OK

Meter Readers

Employees on Job

BS-GF


Areas - Read

19

Vehicles Used

14

General Foreman



Date 2-16-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TROCK W.O.

Jobs Completed

Employees on Job

B.S. G.F. F.P.  
1 HR 1 HR

Vehicles or Equip. Used

11 &amp; 14

**Sewer Department**

Address

Job Completed

BY-PASS PUMPS WITH 3" GAS PUMP AT  
ZIST4 **Ex. 7f (Water Infra.)** TILL BOX

Employees on Job

K.M.

CYCLED PUMP AT  
CYCLED BLOWERS AT**Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

15

**Meter Readers**

Employees on Job

G.F. - F.P.  
5 7 HR

FINISHED

17-F.P.

13-G.F.

Areas - Read

STARTED

10-F.P.

14-G.F.

Vehicles Used

General Foreman

Frank J. Pace

Date \_\_\_\_\_

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		Service truck W.O.
Jobs Completed 14+18 AREAS		
Employees on Job GF 5 hrs		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		
Job Completed		Bypass pumped with 3" gas pump at 71 <sup>st</sup> Ex. 7f (Water Infra.) box, belleview
Employees on Job 12M		Cycled pumps at Ex. 6 (Personal Privacy) cycled blowers at oakland Ex. 7f (Water Infra.)
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job GF 2 hrs		Finished 14+18 GF
Areas - Read		
Vehicles Used		
General Foreman <u>John McCall</u>		



Date 2-15-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

LOCATES

Jobs Completed

REPAIRED 4" A.C. MAIN AT  
CUT OFF OLD LEAKING METAL COUPLING  
INSTALLED ONE 4" A.C.S.S. REPAIR CLAMP

Ex. 6 (Personal Privacy)

Employees on Job

9 AM 30 min  
K.M. Co. F. - F.P. - B.S.  
1 HR

Vehicles or Equip. Used

11-14-BACKHOC

**Sewer Department**

Address

REMOVED OLD 4" GATE VALVE, 4" SPOOL,  
6" X 4" ELBOW, 6" SPOOL AT SUPERIOR FOR PUMP 2  
PRINTED PUMP 1 - PUMPING NOW

Job Completed

Employees on Job

F.P. - B.S. - K.M.  
4 HR 5 HR 2 HR

Vehicles or Equip. Used

14-15

**Meter Readers**

Employees on Job

T.C. - K.M. FINISHED  
6 HR 11 & 12 - K.M. 15 - T.C.

Areas - Read

STARTED  
17 - T.C.

Vehicles Used

8-15

General Foreman

Frank J. Pace

Date 2-14-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

BY-PASS PUMPED WITH 2" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** 71st BoxCYCLED PUMP AT  
CYCLED BLOWERS**Ex. 7f (Water Infra.)**

Job Completed

PRIMED PUMP #1 AT SUPERIOR - PUMPING NOW.  
SET 3/4" X 40" VALVE BOX AROUND BY-PASS VALVE.  
HOOKED UP LATERAL INTO WELL AT SUPERIOR.  
REMOVED CHECK VALVE FOR PUMP #2.

Employees on Job

F.P. - B.S. - K.M. - T.C.  
3 HRJETTIED LINE & REMOVED DEBRIS FROM MAIN  
HOLE TO RELIEVE BACKUP IN **Ex. 6 (Personal Privacy)**  
OF LAKE DR.

Vehicles or Equip. Used

9-14-15- BACKHOLE

**Meter Readers**

Employees on Job

G.F. - T.C.  
4 HR - 5 HR

FINISHED

9 - G.F.

Areas - Read

STARTED  
11 - T.C.

Vehicles Used

11-8

General Foreman

Franky Pace

Date 2-13-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.  
3 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

BY-PASS

CUT IN VALVE, TEE INTO DISCHARGE LINE  
AT SUPERIOR - USED ONE 4" GATE VALVE, ONE  
4" X 4" X 4" TEE, ONE 4" C.I. SOLID SLEEVE.

Job Completed

ONE 4" M.J. X 4" FLANGE VALVE, ONE 4" FLANGE  
X 3" I.P. FEMALE THREAD PLATE, ONE 3" QUICK  
COUPLING X 3" I.P. MALE THREAD FITTING, ONE  
VALVE BOX BOTTOM, 54" PIECE OF SDR35

Employees on Job

F.P. - B.S. - K.M. T.C.  
JHR6" P.V.C. PIPE FOR VALVE BOX, ONE P.V.C. X  
VALVE BOX LID ADAPTER, ONE TRUCK LOAD OF  
CLEAN ROCK FOR BACKFILL.

Vehicles or Equip. Used

G-14-15 - BACKHOE

Meter Readers

Employees on Job

T.C.  
G.F.  
5 HR

FINISHED

8-G.F.

Areas - Read

STARTED  
9-T.C.

Vehicles Used

11-8

General Foreman

Frank Pace



Date 2-12-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

GIF

Vehicles or Equip. Used

11

Sewer Department

Address

JETTED LINES TO RELIEVE BACKUPS AT

**Ex. 6 (Personal Privacy)**CHECKED BACKUP AT **Ex. 6 (Personal Privacy)** 15TH STREET

Job Completed

EXPOSED 4" DISCHARGE LINE &amp; APPROVED 6" CONCRETE LATERAL BROKEN INTO WELLS AT SUPERIOR - C.I. 4.78 O.D. + CONC. 7.98 O.D.

Employees on Job

R.M. - F.P. - B.S. - T.C.  
4 HRSBY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** ICE BOX  
75TH

Vehicles or Equip. Used

14-15-9-BACKHOE

CYCLED PUMP AT  
CYCLED BLOWERS AT**Ex. 7f (Water Infra.)**Meter Readers

Employees on Job

T.C.

FINISHED  
7

Areas - Read

STARTED  
8

Vehicles Used

7

General Foreman

Date 2-9-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

C.F.

Vehicles or Equip. Used

11

**Sewer Department**

Address

SETTLED LINE & CLEANED OUT MANHOLE ON  
DISCHARGE LINE FROM AMES STATION  
PULLED PUMP AT CLINTON & CLEANED OUT RAB  
PUMP STILL NOT PUMPING. NEED TO CHECK STATION.

Job Completed

ELECTRIC.

SHORTENED HARD WALL DISCHARGE LINE & THROTTLED  
UP BY-PASS PUMP AT SHOWS - PUMPING FULL  
PIPE NOW

Employees on Job

K.M. - F.P. - B.S. - T.C.  
4 HR

BY-PASS PUMPED WITH 3" GAS PUMP AT  
TIST. Ex. 7f (Water Infra.)  
BLVD, [REDACTED] ALL BOX, CALVIN

Vehicles or Equip. Used

CYCLED PUMP AT  
CYCLED BLOWERS AT

Ex. 7f (Water Infra.)

9-14-15 - BACKHOLE

**Meter Readers**

Employees on Job

T.C.  
4 HR

FINISHED  
5

Areas - Read

Vehicles Used

7

General Foreman

Franky Pace



Date 2-8-18

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**SERVICE TRUCK W.O.  
LOCATES**Jobs Completed**REBUILT SERVICE AT **Ex. 6 (Personal Privacy)**  
USED ONE 3/4" X 3/4" COMP. FITTING, ONE 3/4" P.V.C.  
BARBX 3/4" COMP. FITTING, ONE WATER SHUT OFF,  
ONE 1/2" NPTX COUPLING, 12' OF 3/4" COPPER TUBING,**Employees on Job**C.P. - F.P. - B.S.  
6 HRONE 18" X 30" P.V.C. WATER BOX, BACKFILLED  
WITH SPOIL**Vehicles or Equip. Used**

11-14- BACKHOL

**Sewer Department****Address**BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** PILL BOX,  
BELLVIEW**Job Completed**CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)****Employees on Job**K.M. - F.P. - B.S.  
2 HRPRIMED PUMP, CHECKED FOR RAGS IN PUMP  
& GOT PUMPIII PUMPING AT SUPERIOR**Vehicles or Equip. Used**

14-15

**Meter Readers****Employees on Job**

T.C.

FINISHED

344

**Areas - Read**STARTED  
5**Vehicles Used**

8

**General Foreman**Franky. Rice



Date 2-7-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	MADE FULL UNDER ROAD AT <b>Ex. 6 (Personal Privacy)</b> USED 50' OF 3/4" COPPER TUBING, ONE 3/4" FLARE X COMP. FITTING, ONE 3/4" X 3/4" COMP. FITTING, ONE METER SHUT OFF, ONE METER COUPLER, ONE 18" X 30" P.V.C.	
Employees on Job F.P. - B.S. - G.P.	METER BOX, BACKFILLED WITH SPOIL & ONE BUCKET OF C-M-G ROCK IN DRIVEWAY OF 1103	
Vehicles or Equip. Used 8-14-BACKHOE	HAULED IN TWO BUCKETS OF C-M-G ROCK GRADED ROAD AT COOPER'S <b>Ex. 6 (Personal Privacy)</b> <b>Ex. 6 (Personal Privacy)</b> HERE LEAKS WERE REPAIRED	
<b>Sewer Department</b>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<b>Meter Readers</b>		
Employees on Job K.M.	STARTED 4:27	
Areas - Read	FINISHED 6	
Vehicles Used 15		
General Foreman <u>Frank J. Pace</u>		

Date 2-6-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address <u>2-6-18</u>	SERVICE TRUCK W.D.
Jobs Completed	
Employees on Job <u>G.F. - K.M.</u>	
Vehicles or Equip. Used <u>8-15</u>	

Sewer Department

Address	CUT & GROUND DOWN WELDS FOR FALSE FLOOR - SET NEW PUMP IN WELL AT SUPERIOR
Job Completed	
Employees on Job <u>F.P. - B.S.</u>	
Vehicles or Equip. Used <u>7-14 - BACKHOE</u>	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 2-5-18

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**

SERVICE TRUCK W.O.  
CHECKED FOR LEAKS AT **Ex. 6 (Personal Privacy)**  
**Ex. 6 (Personal Privacy)** BOTH SERVICE LEAKS -  
LOCATES CALLED IN

**Jobs Completed****Employees on Job**

F.P. - T.C.  
1 HR

**Vehicles or Equip. Used**

11-14

**Sewer Department****Address**

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** HILL BOX,  
BELLEVUE

**Job Completed**

CYCLED PUMP AT **Ex. 7f (Water Infra.)**  
CYCLED BLOWERS AT

**Employees on Job**

K.M. - F.P. - T.C.  
7 HR

PULLED PUMP #1 BEHIND **Ex. 6 (Personal Privacy)**  
CLEANED OUT RAGS

**Vehicles or Equip. Used**

14-15 - BACKHOE

PULLED BY-PASS PUMP AT VIOLETA **Ex. 6 (Personal Privacy)**  
REWIRED BAD SPOT IN LINE TO STATION -  
PUMPING NOW

**Meter Readers****Employees on Job**

CHECKED FOR BACKUPS AT 4+ **Ex. 6 (Personal Privacy)**  
CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**  
ALL 3 CUSTOMER PROBLEMS

**Areas - Read****Vehicles Used****General Foreman**

Frank J. Rose



Date 2-2-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		
Jobs Completed		
Employees on Job 68	WORK ORDERS	
Vehicles or Equip. Used 14		
<b>Sewer Department</b>		
Address		
Job Completed		
Employees on Job KM		
Vehicles or Equip. Used 15	BY PASS PUMPED 7151 PILL BOX, TEST <b>Ex. 7f (Water Infra.)</b> CROCHETS 3/13/18	
<b>Meter Readers</b>		
Employees on Job TG GP	STARTED 6 + PASSED OUT 1710 STARTED 3 FINISHED 10	
Areas - Read 3, 4, 10		
Vehicles Used 9 14		
General Foreman <u>M. H. Rios</u>		

Date 2-1-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

Re-READS &  
WORK orders

Jobs Completed

Employees on Job

TC  
Km - GF

Vehicles or Equip. Used

11-8-15

Sewer Department

Address

SNOWS

VACced OFF TOP & SET  
PUMP-

Job Completed

Re-SET BREAKER AT SIST  
Ex. 7f (Water Infra.) checked sewers

Employees on Job

BS  
TCIN PARKFIELD - BY PASS  
PUMP IN well is OUT

Vehicles or Equip. Used

VAL TRUCK  
BACK HOE - 14

Meter Readers

Employees on Job

GF Km

Areas - Read

29

Vehicles Used

8

General Foreman

Date 3-30-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pice

HOZ  
1 DAY  
GOOS  
FR  
DAY



Date 3-28-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
**Ex. 7f (Water Infra.)** FRONT

Job Completed

PUMPED OUT STATION CANS AT BELLEVIEW,  
BLUFF, OAKLAND, 63RD  
FRONT **Ex. 7f (Water Infra.)**

Employees on Job

F.P. - B.S. - K.M.

**Ex. 7f (Water Infra.)** MARKET OFFAMES OFF WATER OVER MOTOR AT BLUFF,  
BELLEVIEW, **Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

14-15

PULLED BACK OFF PUMP & CLEANED OUT RAGS  
TWICE AT BRIDGEDALEMeter Readers

Employees on Job

T.C.

FINISHED  
16-25, 27, 30

Areas - Read

STARTED  
10

Vehicles Used

8

General Foreman

Frank J. Pace

Date 3-29-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

C.F.

Vehicles or Equip. Used

11

Sewer Department

Address

PULLED BACK OFF PUMP & CLEANED OUT  
RACS AT BRIDGE DALE - DID THIS TWICE TODAY

Job Completed

BY-PASS PUMPED WITH 3" AMP AT  
FRONT  
SIST.

Ex. 6 (Personal Privacy)

**Ex. 7f (Water Infra.)**

Employees on Job

F.P. - B.S. - K.M.

CHECKED STATIONS - PUMPED OUT CANS AT  
BLUFF, BELLEVUE, OAKLAND - E. ST. LOUIS UP  
AT LAURA, BUT TAKING A LITTLE

Vehicles or Equip. Used

14 - 15

RESET G.F.I. AT  
SUMP HOLE - PUMPING NOW**Ex. 7f (Water Infra.)**

Meter Readers

Employees on Job

T.C.

FINISHED

3

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 3-27-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job	F.P. - B.S. - G.F. - K.M. 2 HR                      4 HR	
Vehicles or Equip. Used	11-14-15	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED CALVIN BLVD. SHUT OFF <b>Ex. 7f (Water Infra.)</b> REAR, BELLVIEW, AMES, SNOWS, DUE TO HIGH WATER	
Job Completed	PULLED PUMP & CLEANED OUT RAGS BEHIND <b>Ex. 6 (Personal Privacy)</b> PULLED BACK OFF PUMP AT BRIDGE DALE & CLEANED OUT RAGS	
Employees on Job	CHECKED STATIONS - E.S. LOUIS NOT TAKING INSTALLED LIGHT RECEPTICLES AT BRIDGE DALE STILL DON'T WORK? F.P. - B.S. - K.M. 6 HR                      4 HR	
Vehicles or Equip. Used	53RB <b>Ex. 7f (Water Infra.)</b> MARKET ON 14-15-BACKHOLE	
Meter Readers		
Employees on Job	T.C.                      FINISHED 102	
Areas - Read	STARTED 16	
Vehicles Used	8	
General Foreman	Frank J. Pace	



Date 3-26-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	PULLED BY-PASS PUMPS AT VIOLET WET WELL & BEHIND OUT RAGS FROM BOTH PUMPS & RE-SET
Job Completed	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST PILL BOX
Employees on Job F.P. - B.S. - K.M.	CYCLER PUMP AT CYCLER BLOWERS AT CYCLER BY-PASS PUMP
Vehicles or Equip. Used 14-15 - BACKHOLE	WORKED ON NEW PUMP INSTALLATION AT SUPERIOR

Meter Readers

Employees on Job G.F. - T.C. 7 HR	FINISHED 29 - G.F. & T.C.
Areas - Read	STARTED 16 - T.C.
Vehicles Used 8	

General Foreman Frank J. Pace

Date 3-23-18

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address	Service TRUCK  LOCATES	
Jobs Completed		
Employees on Job 11 14		
Vehicles or Equip. Used TC BS		
<u>Sewer Department</u>		
Address	By PASSAL 71ST-CYCLED BLOWERS ON 73rd, 75th <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CHANGED OIL IN OAKLAND BLOWER JETTED BEHIND #3 <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job KM BS-TC	JETTED MAIN ON FRONTAGE RD CHECKED STATIONS	
Vehicles or Equip. Used VAC 14 15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>B. Luv</u>	

Date 3-22-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES
Jobs Completed	REPAIRED 6" A.C. MAIN BREAK AT JEROME Ex. 6 (Personal Privacy) USED ONE 6" A.C. S.S. REPAIR CLAMP BACKFILLED WITH 4 BUCKETS CLEAN ROCK FROM SHOP & C-M-G FROM QUARRY
Employees on Job F.P. - B.S. - T.C. 4 HR	K.M. 2 HR BROKE OUT CURB & SIDEWALK WITH HYDRO HAMMER
Vehicles or Equip. Used 11-6-14-BACKHOES	BOTH

Sewer Department

Address

INSTALLED PUMP BEHIND

Ex. 6 (Personal Privacy)

Job Completed

WORKED WITH JAT TRUCK AT  
MARKET FOR CENTREVILLE

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C.  
4 HR

CYCLED VIOLAT

Vehicles or Equip. Used

14-9-BACKHOLE

Meter Readers

Employees on Job

K.M.  
6 HRFINISHED  
23, 24, 26

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace



Date 3-20-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job K.M. 5	
Vehicles or Equip. Used 11	

Sewer Department

Address	CHECKED 51ST Ex. 7f (Water Infra.) LL GOOD PULLED PUMP BEHIND Ex. 6 (Personal Privacy) CLEANED OUT RAGS - PUMP TURNING SLOW - BROUGHT TO SHOP
Job Completed	CHECKED FOR BACKUP AT Ex. 6 (Personal Privacy) OURLINKS DOWN - CUST. PROBLEM CYCLED PUMPS AT Ex. 6 (Personal Privacy) BY-PASS PUMPED BEHIND Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S.	PULLED PUMP BEHIND Ex. 6 (Personal Privacy) ADJUSTED DISCHARGE LINE SO FLOAT BALL OPERATES FREELY - RE-SET PUMP CHECKED BELLOVIEW - NOT DOWN ANY
Vehicles or Equip. Used 14 - BACKHOLE	WORKED ON SUPERIOR - INSTALLED PLATE BETWEEN CHECK & VALVE - LOOKS GOOD FOR WELDING

Meter Readers

Employees on Job K.M. - T.C. 3	FINISHED 19-K.M. & T.C. - 20 & 21 - T.C.
Areas - Read	
Vehicles Used 8	

General Foreman

Frank J. Pace

Date 3-21-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	REBUILT & RECONNECTED SERVICE AT HELEN CT. - USED ONE 3/4" BARBXCOMP. FITTING, ONE 3/4" X 1/2" COMP. FITTING, ONE METER SHUT OFF, ONE METER COUPLING, 10' OF 3/4" COPPER TUBING	
Employees on Job F.P. - B.S. - T.C. 6 HR 2 HR	CUT HOLE IN LID FOR R.R. ANTENNA, RE-USED CLAY METER BOX & RING, INSTALLED R.R. METER BACKFILLED WITH SPOIL - TURNED ON METER	
Vehicles or Equip. Used	14-11-BACKHOE	
<u>Sewer Department</u>		
Address	BY PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) MILL BOX, PITTSBURG	
Job Completed	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS CYCLED BY-PASS AL	
Employees on Job F.P. - B.S. - K.M. 3 HR	CHECKED STATIONS - 82ND NOT DOWN 53RD Ex. 7f (Water Infra.) CYCLED Ex. 6 (Personal Privacy) EPS KICKING OUT OVER NIGHT	
Vehicles or Equip. Used	CHECKED BACK UP Ex. 6 (Personal Privacy) DUE TO PUMP OUT BEHIND TALKED TO CUST - TALKED TO CUST. AT Ex. 6 (Personal Privacy)	
<u>Meter Readers</u>		
Employees on Job T.C. 6 HR	FINISHED 22	
Areas - Read	STARTED 23	
Vehicles Used	8	
General Foreman <u>Frank J. Pace</u>		



Date 3-19-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job	T.C. GAR	
Vehicles or Equip. Used	11	
<u>Sewer Department</u>		
Address		RESET BREAKER ON POLE AT 51ST Ex. 6 (Personal Privacy)
Job Completed		ADJUSTED FLOAT BALLS FOR BY-PASS PUMP AT BELLEVUE & TIED OFF DISCHARGE HOSE TO EXISTING DISCHARGE LINE - E.S.L. NEEDS TO SET LINK PULLED BOTH PUMPS AT Ex. 6 (Personal Privacy) CLEANED RAGS OUT OF PUMP #1 & PIECE OF 1" X 2" LATH WOOD OUT OF PUMP #2 - PUMPING NOW PULLED BACK & CLEANED OUT RAGS AT BRIDGE DALE
Employees on Job	F.P. - B.S.	CHECKED STATIONS - PUMP BEHIND Ex. 6 (Personal Privacy) NEEDS PULLED - NOT PUMPING - VIOLET KICKED OUT - CYCLED IT DOWN - FLOATBALL HUNG UP BEHIND Ex. 6 (Personal Privacy) ADJUSTED PUMP AWAY FROM STEPS
Vehicles or Equip. Used	14 - BACKHOE	BY-PASS PUMPED AT 71ST Ex. 7f (Water Infra.) CYCLED PUMP Ex. 7f (Water Infra.) AT OAKLAND & 75TH Ex. 7f (Water Infra.) PULL BOX CYCLED SLOWERS BY-PASS PUMP AT
Meter Readers		
Employees on Job	T.C. 2 PR	STARTED 20
Areas - Read		
Vehicles Used	8	
General Foreman	Frank Pace	



Date 3-16-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	REPAIRED 4" C.I. MAIN BREAK WITH 4" C.I. SS. REPAIR CLAMP AT <b>Ex. 6 (Personal Privacy)</b> REPAIRED SERVICE LINE FOR 334 ROSE THAT WAS NOT USED ON A 3/4" x 3/4" COMP. FITTING
Jobs Completed	SERVICE TRUCK W.D. LOCATES
Employees on Job F.P. - B.S. - T.C. 5HR 4HR 4.5HR	
Vehicles or Equip. Used 11-14 - BACKHOLE	

Sewer DepartmentAddressBY-PASS PUMPED WITH 3" GAS PUMP AT 71ST **Ex. 7f (Water Infra.)** RE BOXJob CompletedCYCLED PUMP AT **Ex. 7f (Water Infra.)**  
CYCLED BLOWER  
CYCLED BY-PASS PUMP AT 75TH **Ex. 7f (Water Infra.)**Employees on JobK.M. - F.P.  
6HR 3HRINSTALLED BY-PASS PUMP AT BELLEVUE  
PUMPING NOW - NEED TO ADJUST FLOATBALLSVehicles or Equip. Used

7-14

Meter ReadersEmployees on JobT.C.  
3.5 HRFINISHED  
17+18Areas - ReadVehicles Used

8

General Foreman

Frank J. Pace

Date 3-15-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT BACK SIDE AT <b>Ex. 6 (Personal Privacy)</b> USED ONE $\frac{3}{4}$ " x $\frac{3}{4}$ " COMP. FITTING, ONE METER SHOT OFF & 4' OF $\frac{3}{4}$ " COPPER TUBING	
Employees on Job F.P. - B.S. - C.F. 6HR 2HR	MET PLUMBER AT <b>Ex. 6 (Personal Privacy)</b> SAUGET ABOUT SHUTTING DOWN DOMESTIC SERVICE FOR REPAIRS - REMOVED READER FOR 8" METER	
Vehicles or Equip. Used	11-14 - BACKHOLE	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX BELLEVUE, RAN BLUFF FOR 2 HRS.	
Job Completed	COVERED MANHOLE AT <b>Ex. 6 (Personal Privacy)</b> PUMP #1 KICKED ON RUNNING #2 NOW	
Employees on Job K.M. - F.P. - B.S. 2HR	ELECTRICAL PROBLEM AT 51ST <b>Ex. 7f (Water Infra.)</b> CAUSING BACKUP - PUMPING FOR NOW PULLED BACK OFF PUMP & CLEANED OUT RAGS AT BRIDGE DALE	
Vehicles or Equip. Used	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS CYCLED BY-PASS PUMP AT 75TH <b>Ex. 7f (Water Infra.)</b> 7-14	
<u>Meter Readers</u>		
Employees on Job C.F. T.C. 6HR	FINISHED 14 & 15 - G.F. 17 - T.C.	
Areas - Read	STARTED 18 - T.C.	
Vehicles Used	11-8	
General Foreman <u>Frank J. Pace</u>		

Date 3-14-18 Daily Job Sheet Sheet 1 of 1

<u>Water Department</u>		Comments
Address	Service TRUCK W.O.'S DID LOCATES	
Jobs Completed	REPAIRED MAIN BREAK AT CAMP JACKSON	
Employees on Job	BS GF TC	
Vehicles or Equip. Used	11-14- DUMP- VAC BACKHOE	
<u>Sewer Department</u>		
Address	BY PASSED TEST RAN STATION. CYCLED 73rd BLOWERS + TURNED ON CLINTON - PUMPED	
Job Completed	Bellevue	
Employees on Job	RM	
Vehicles or Equip. Used	7	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>B. Smith</u>	

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)



Date 3-13-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT BELLEVUE - RAN BLUFF BUT SURCHARGED IN STREET INSTALLED PUMP AT VIOLA Ex. 6 (Personal Privacy)	
Job Completed	PULLED PUMP & CLEANED OUT RAGS AT 50TH Ex. 6 (Personal Privacy) PUMPING NOW ADJUSTED FLOAT BALL AT SNOWS - PUMPING NOW	
Employees on Job F.P. - B.S. - K.M.	CHECKED FOR BACK UP AT PROBLEM - TALKED TO COST CYCLED OAKLAND, CROCKETTS, 75TH Ex. 6 (Personal Privacy) Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 14 - 7 - BACKHOLE	PULLED BACK OFF PUMP & CLEANED OUT MOP AT BRIDGEDALE	
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 12 & 13	
Areas - Read	STARTED	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATED RE-READS	
Jobs Completed	PULLED NEW LINE UNDER ROAD FOR HALLORAN ST. - USED 59' OF 3/4" COPPER TUBING, ONE FLARE X 3/4" COMP. STREET ELB, ONE 3/4" X 3/4" COMP. FITTING, ONE METER COUPLING, ONE METER SHUT OFF. BACKFILL WITH SPOIL - USED ONE 18" X 30" P.V.C. METER BOX	
Employees on Job	F.P. - B.S. - G.F. 4 HR	
Vehicles or Equip. Used	11-14-BACKHOLE	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TISD BLVD.	
Job Completed	CYCLED PUMP AT CYCLED BLOWERS & CYCLED BY-PASS PUMP	
Employees on Job	K.M.	
Vehicles or Equip. Used	7	
Meter Readers		
Employees on Job	G.F. 4 HR	
Areas - Read	FINISHED 11	
Vehicles Used	11	
General Foreman <u>Frank J. Pace</u>		

Date 3-9-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. RE-READS	
Jobs Completed		
Employees on Job	F.P. - B.S. - G.F. 2 HR 1 HR	
Vehicles or Equip. Used	7-14	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT T1ST Ex. 6 (Personal Privacy) PILL BOX, BELLVIEW	
Job Completed	CYCLED PUMP AT CYCLED BLOWERS A CYCLED BY-PASS P. Ex. 7f (Water Infra.)	
Employees on Job	K.M. - F.P. - B.S. 1 HR PUT PLYWOOD - PALLET OVER MANHOLE ACROSS FROM Ex. 6 (Personal Privacy) PUMP #2 AT KICKING OFF PUMP #1 NOW	
Vehicles or Equip. Used	DIRECTED FOR BACKUP AT Ex. 6 (Personal Privacy) PROB 15-14	
Meter Readers		
Employees on Job	G.F. TAK FINISHED 9	
Areas - Read	STARTED	
Vehicles Used	8	
General Foreman	Frank J. Pace	



Date 3-8-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK WASH
Jobs Completed		
Employees on Job	G.F.	
Vehicles or Equip. Used	8	
<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT BELLEVUE PUMPED OUT CAN AT BLUFF
Job Completed		DISCONNECTED PUMP FROM JUNCTION BOX AT Ex. 6 (Personal Privacy) + BROUGHT TO SHOP PICKED UP BROKEN M.H. RING & LID FROM ACROSS Ex. 6 (Personal Privacy)
Employees on Job	K.M. - F.P. - B.S.	LOCATED WORKED ON NEW PUMP ASSEMBLY AT SUPERIOR
Vehicles or Equip. Used	14-15 - BACKHOLE	
<u>Meter Readers</u>		
Employees on Job	T.C.	FINISHED 8 WALKING 349 R.R.
Areas - Read		STARTED 9 R.R.
Vehicles Used	7	
General Foreman <u>Franky Force</u>		

Date 3-7-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	REPAIRED 4" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) USED ONE 4" C.I. S.S. REPAIR CLAMP - BACKFIELD ROAD WITH ONE TRUCK LOAD OF CLEAN ROCK & 1/4 TRUCK LOAD OF C-MG ROCK
Employees on Job F.P. - B.S. - T.C. - G.F. 4 HR	
Vehicles or Equip. Used B-14-6 - BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715 Ex. 6 (Personal Privacy) FIRE BOX BELLEVILLE
Job Completed	WORKED ON STATION AT 51ST WITH DENNY Ex. 7f (Water Infra.)
Employees on Job F.P. - B.S. - K.M. 4 HR	CYCLED BLOWERS AT OAKLAND & CROCKETTS CYCLED PUMP AT Ex. 6 (Personal Privacy) CYCLED BY-PASS PUMP AT 75TH Ex. 7f (Water Infra.)
Vehicles or Equip. Used 15-14	CHECKED VOLTAGE ON PUMP BEHIND R.S. REMOVED PULLEY FROM MOTOR FOR 51ST Ex. 7f (Water Infra.)

Meter Readers

Employees on Job G.F. T.C. 4 HR 4 HR	FINISHED 6-G.F. - 7-T.C.
Areas - Read	STARTED 8-T.C.
Vehicles Used 7	

General Foreman Frank J. Pace

Date 3-6-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address	2 HR O.T. CALL OUT
Jobs Completed	TURNOED ON METER AT
Employees on Job C.F.	
Vehicles or Equip. Used 8	

Ex. 6 (Personal Privacy)

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace



Date 3-6-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O, RE-READS - PUMPED OUT P.O.W. VAULTS WITH 3" PUMP & READ METERS	
Jobs Completed	REPAIRED PIN HOLE IN COPPER SERVICE LINE AT <b>Ex. 6 (Personal Privacy)</b> SED ONE 3/4" COMP FITTING & 4' OF 3/4" COPPER - BACKFILLED ROAD	
Employees on Job F.P. - B.S. - G.F. - T.C. Time 4:00 1:50 PM	WITH ONE TRUCK LOAD OF CLEAN ROCK & ONE BUCKET OF C-M-G ROCK - HAULED OFF SITE	
Vehicles or Equip. Used 814-14-6 - BACKHOLE		
<u>Sewer Department</u>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT BLUEVIEW - DID NOT GET DOWN MUCH LOT OF BLOW-BACK	
Employees on Job B.S. 4:00 PM	CYCLED BLOWERS AT OAKLAND & CROCKETTS PUMPED DOWN 75TH <b>Ex. 7f (Water Infra.)</b> BY-PASS PUMP ON HAND	
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job T.C. G.F. PM	FINISHED 5	
Areas - Read	STARTED 6	
Vehicles Used 7		
General Foreman	Franky Rice	

Date 3-5-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.C. LOCATES	
Jobs Completed		
Employees on Job F.P. - B.S. 1 HR		
Vehicles or Equip. Used 14		
<u>Sewer Department</u>		
Address	INSTALLED TWO NEW FLOAT BALLS & HUNG PUMP FROM NEW HANGER (PIPE) AT 75TH Ex. 7f (Water Infra.)	
Job Completed	POURED BACK OFF PUMP & CLEANED OUT RAGS/ MOP HEAD AT 51ST Ex. 7f (Water Infra.) CHECKED STATIONS	
Employees on Job F.P. - B.S. K.M. 2 HR	BY-PASS PUMPER WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PIPE BOX, 63RD Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 14-15	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS CYCLED BY-PASS PUMP AT 75TH Ex. 7f (Water Infra.)	
Meter Readers		
Employees on Job T.C.	FINISHED 4	
Areas - Read	STARTED 5	
Vehicles Used 8		
General Foreman	Frank J. Price	



Date 3-2-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	CUT & CAPPED 2" C.I. MAIN AT MARKET - ALSO CUT & CAPPED 2" PVC MAIN AT ALLEY WAY & 5TH ST. - USED Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - G.F. 6 HR	TWO 2" CAPS, M.S. GASKETS & FLANGES BACKFILLED WITH SPOIL & ROCK IN ROAD.
Vehicles or Equip. Used 11-14-BACKHOLE	REPAIRED SERVICE LEAK AT USED ONE 3/4" x 3/4" COMP. FITTING & ONE 3/4" BARB x 3/4" COMP. FITTING & 6' OF 3/4" COPPER TUBING, BACKFILLED WITH SPOIL Ex. 6 (Personal Privacy)

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX, & BELLEVUE
Job Completed	CYCLED PUMP AT CYCLED BLOWERS CYCLED BY-PASS PUMP AT 75TH Ex. 7f (Water Infra.)
Employees on Job K.M. - F.P. - B.S. 3 HR	PULLED PUMP AT LAURALAN Ex. 7f (Water Infra.) TO SHOP FOR REPAIR
Vehicles or Equip. Used 14-15-BACKHOLE	

Meter ReadersEmployees on Job

T.C.

FINISHED  
10-3Areas - ReadVehicles Used

8

General Foreman

Frank J. Pace



Date 3-1-18 APPENDIX B #5

## Daily Job Sheet

Sheet     of    **Water Department****Comments**

<b>Address</b>	SERVICE TRUCK W.O.
<b>Jobs Completed</b>	EXPOSED MAINS, LOCATED & EXERCISED VALVES, CLEARED ALLEY, IN PREP TO CUT & CAP MAIN AT 5TH OFF <b>Ex. 6 (Personal Privacy)</b>
<b>Employees on Job</b> F.P. - B.S. - G.F. - T.C. - K.M. 1 HR 4 HR	
<b>Vehicles or Equip. Used</b> 11-14-15-9-BACKHOLE	

**Sewer Department**

<b>Address</b>	CHECKED FOR BACKUP AT <b>Ex. 6 (Personal Privacy)</b> PUMP IN WELL AT LAURALEE <b>Ex. 7f (Water Infra.)</b> NOT PUMPING - SHUT OFF BREAKER
<b>Job Completed</b>	
<b>Employees on Job</b> K.M. - T.C. 1 HR	
<b>Vehicles or Equip. Used</b> 8	

**Meter Readers**

<b>Employees on Job</b> K.M. - T.C. 3 HR 6 HR	FINISHED RADIO READS IN PASSPORT K.M. 142-T.C.
<b>Areas - Read</b>	
<b>Vehicles Used</b> 8-15	
<b>General Foreman</b> <u>Frank J. Pace</u>	

Date 4-30-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F. 4PM	
Vehicles or Equip. Used 11	

Sewer Department

Address	CHECKED FOR BACKUPS AT Ex. 6 (Personal Privacy) CUST PROBLEM - Ex. 6 (Personal Privacy) CHECKED ONE M.H. & IT WAS DOWN - CANT FIND 2ND M.H. THINK ITS CUST. PROB - TALKED TO CUSTOMERS
Job Completed	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX
Employees on Job G.F. F.P. 4PM JPK	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS AT
Vehicles or Equip. Used 14-15	

Meter Readers

MANUALS

Employees on JobT.C. F.P.  
6PM

FINISHED

6-F.P. 3-T.C.

Areas - ReadSTARTED  
4-T.C.Vehicles Used

14-15

General Foreman

Frank J. Pace



Date 4-27-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

<b>Address</b>	SERVICE TRUCK W.O.
<b>Jobs Completed</b>	CHANGED METERS TO RADIO READ METERS ON DORIS
<b>Employees on Job</b> F.P. - Giff	
<b>Vehicles or Equip. Used</b> 14-11	

**Sewer Department**

<b>Address</b>	
<b>Job Completed</b>	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
<b>Employees on Job</b> T.C.	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS
<b>Vehicles or Equip. Used</b> 15	

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used**

General Foreman

Frank J. Pace



Date 4-26-18

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**

SERVICE TRUCK W.O.

**Jobs Completed****Employees on Job**G.F. F.P.  
6 1HR**Vehicles or Equip. Used**

11-14

**Sewer Department****Address**PULLED PUMP BEHIND **Ex. 6 (Personal Privacy)**  
CLEANED OUT RAGS & RE-ATTACHED  
CHAIN WITH 5.8 BOLTS & NUTS**Job Completed****Employees on Job**F.P. - K.M.  
2HR 2HR**Vehicles or Equip. Used**

14-BACKHOLE

**Meter Readers****Employees on Job**K.M. - F.P. - G.F.  
2HR 5HR 2HR

FINISHED

29-MANUALS - F.P. - K.M. - G.F.

**Areas - Read****Vehicles Used**

14

**General Foreman**

Frank A. Pacer

Date 4-25-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F. 2HR	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 Ex. 7f (Water Infra.) PILL BOX, 6320W. Ex. 7f (Water Infra.)
Job Completed	CYCLAD PUMP AT Ex. 7f (Water Infra.) CYCLAD BLOWERS
Employees on Job F.P. - K.M. - D.T. 6HR 2HR	WELDED MOTOR & PUMP BRACKETS TO FLOOR AT SUPERIOR STATION CHECKED SOME STATIONS - 82ND NOT TAKING AT E. ST. LOUIS BRICK M.H. - NEED TO PULL
Vehicles or Equip. Used 14-15-9	PUMP BEHIND Ex. 6 (Personal Privacy) WORKED WITH CENTREVILLE AT 3TH Ex. 7f (Water Infra.) F.P.-D.T. & UNIT 9 - PUMPED AT SMOOKY TUNSA.

**Meter Readers**

Employees on Job G.F. - F.P. 1HR 2HR	FINISHED MANUAL 26 - G.F.
Areas - Read	STARTED MANUAL 1 - F.P.
Vehicles Used 11-14	

General Foreman

Frank J. Pace

Date 4-24-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

F.P. - B.S. - G.F.  
5HR 6HR 2HR

Vehicles or Equip. Used

11-14

**Sewer Department**

Address

PULLED BACK OFF PUMP & CLEANED OUT  
RAGS/MOP HEAD AT BRIDGE DALE

Job Completed

Employees on Job

Vehicles or Equip. Used

**Meter Readers**

Employees on Job

G.P. - K.M. - F.P.  
6HR 4HR 3HR

FINISHED  
21-22-G.F. 23-K.M. - 24-F.P. & K.M.

Areas - Read

STARTED  
26-F.P. PASSPORT DIED

Vehicles Used

8-11

General Foreman

Frank J. Pace



Date 4-23-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P. - G.F.  
3 HR 2 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP  
71ST Ex. 7f (Water Infra.) PILL BOX,  
Ex. 7f (Water Infra.) BLVD.

Job Completed

CYCLED PUMP AT Ex. 7f (Water Infra.)  
CYCLAS BLOWERS

Employees on Job

K.M.

Vehicles or Equip. Used

15

**Meter Readers**

Employees on Job

F.P. - G.F.  
5 HR 2 HR

FINISHED MANUALS

19-F.P. &amp; G.F. 20-F.P.

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Rose

## Comments

SERVICE TRUCK W/O.  
INSTALLED R.R. METERS ON BORIS

<b>Employees on Job</b>	<b>Employees on Layoff</b>	<b>Total Employees</b>
100	0	100
90	10	100
80	20	100
70	30	100
60	40	100
50	50	100
40	60	100
30	70	100
20	80	100
10	90	100
0	100	100

Conf.

**Vehicles or Equip. Used**

11

**Address**

PULLED PUMP & CLEANED OUT RAGS  
BEHIND **Ex. 6 (Personal Privacy)**

### Ex. 6 (Personal Privacy)

**Job Completed**

WORKED ON PUMP #2 AT SUPERIOR -  
GROUND FLOOR FOR MOTOR - INSTALLED  
BASE FOR PUMP

	Employees on Job
1970	68,000
1971	68,000
1972	68,000
1973	68,000
1974	68,000
1975	68,000
1976	68,000
1977	68,000
1978	68,000
1979	68,000
1980	68,000
1981	68,000
1982	68,000
1983	68,000
1984	68,000
1985	68,000
1986	68,000
1987	68,000
1988	68,000
1989	68,000
1990	68,000
1991	68,000
1992	68,000
1993	68,000
1994	68,000
1995	68,000
1996	68,000
1997	68,000
1998	68,000
1999	68,000
2000	68,000
2001	68,000
2002	68,000
2003	68,000
2004	68,000
2005	68,000
2006	68,000
2007	68,000
2008	68,000
2009	68,000
2010	68,000
2011	68,000
2012	68,000
2013	68,000
2014	68,000
2015	68,000
2016	68,000
2017	68,000
2018	68,000
2019	68,000
2020	68,000
2021	68,000
2022	68,000
2023	68,000
2024	68,000
2025	68,000
2026	68,000
2027	68,000
2028	68,000
2029	68,000
2030	68,000
2031	68,000
2032	68,000
2033	68,000
2034	68,000
2035	68,000
2036	68,000
2037	68,000
2038	68,000
2039	68,000
2040	68,000
2041	68,000
2042	68,000
2043	68,000
2044	68,000
2045	68,000
2046	68,000
2047	68,000
2048	68,000
2049	68,000
2050	68,000
2051	68,000
2052	68,000
2053	68,000
2054	68,000
2055	68,000
2056	68,000
2057	68,000
2058	68,000
2059	68,000
2060	68,000
2061	68,000
2062	68,000
2063	68,000
2064	68,000
2065	68,000
2066	68,000
2067	68,000
2068	68,000
2069	68,000
2070	68,000
2071	68,000
2072	68,000
2073	68,000
2074	68,000
2075	68,000
2076	68,000
2077	68,000
2078	68,000
2079	68,000
2080	68,000
2081	68,000
2082	68,000
2083	68,000
2084	68,000
2085	68,000
2086	68,000
2087	68,000
2088	68,000
2089	68,000
2090	68,000
2091	68,000
2092	68,000
2093	68,000
2094	68,000
2095	68,000
2096	68,000
2097	68,000
2098	68,000
2099	68,000
2100	68,000

P.P.B.S. = K.M.

BY-PASS PUMPED WITH 3" GAS PUMP  
AT 71ST Ex. 7f (Water Infra.) Pic Box

### Ex. 7f (Water Infra.)

Picc Box

Ex. 7f (Water Infra.)

**Vehicles or Equip. Used**

CYCLAD PUMP AT  
CYCLAD BLOWERS

### Ex. 7f (Water Infra.)

14-15- ВАСИЛИОН

## Meter Readers

Employees on Job	Employees on Job	Employees on Job	Employees on Job
1	2	3	4
5	6	7	8
9	10	11	12
13	14	15	16
17	18	19	20
21	22	23	24
25	26	27	28
29	30	31	32
33	34	35	36
37	38	39	40
41	42	43	44
45	46	47	48
49	50	51	52
53	54	55	56
57	58	59	60
61	62	63	64
65	66	67	68
69	70	71	72
73	74	75	76
77	78	79	80
81	82	83	84
85	86	87	88
89	90	91	92
93	94	95	96
97	98	99	100

### Areas - Read

### Vehicles Used

## General Foreman

Frank J. Rice



Date 4-19-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W/O.
Jobs Completed	INSTALLED RADIO READ METERS ON DORIS AVE.
Employees on Job G.F. - K.M.	
Vehicles or Equip. Used 8-11	

**Sewer Department**

Address	CLEANED + GROUND FLOOR FOR WELDING AT SUPERIOR STATION PUMP #2.
Job Completed	WIRED UP MOTOR FOR PUMP #2 AT SUPERIOR STATION
Employees on Job F.P. - B.S.	CHECKED STATIONS ON SOUTH SIDE - PUMP NEEDS PULLED BRITING LAURALLE - TURNED OFF
Vehicles or Equip. Used 14	

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used**General Foreman Frank J. Pace

Ex. 6 (Personal Privacy)



Date 4-18-18

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

<b>Address</b>	WORK ORDERS - measured meters for Radio Read AT HOLTON
<b>Jobs Completed</b>	Repaired yard AT Did LOCATES
<b>Employees on Job</b> GF BS TC	
<b>Vehicles or Equip. Used</b> 11 14 BACKHoe	

Ex. 6 (Personal Privacy)

**Sewer Department****Address**BY PASSED 71ST - BOTH SPOTS  
AND cycled Blowers AT 73rd**Job Completed**

Ex. 7f (Water Infra.)

ADJUSTED FLOAT  
BAUS AT 75TH

Ex. 7f (Water Infra.)

**Employees on Job**BS  
TC  
Km

Ex. 6 (Personal Privacy)

checked PH 1  
STATIONS**Vehicles or Equip. Used**14  
15

BY PASSED CALVIN

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 4-17-18 APPENDIX B #5

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

WORK ORDERS

Jobs Completed

Fixed YARD ON ROBT  
RICE WHERE LEAK WAS REPAIRED

Employees on Job

GF  
BS TC

Vehicles or Equip. Used

11  
14 BACKHOE**Sewer Department**

Address

UNITED FLOAT BATHS AT 75TH  
Ex. 7f (Water Infra.)  
CYPRESS 73RD - TURNED ON  
BELLEVUE

Job Completed

PUMPED DOWN VIOLET  
SETTLED LINE ON BATES

Employees on Job

CHECKED OUT #2 LLOYD  
SEWER PROB- WE ARE OK

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

B. Smith



Date 4-16-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

HAULLED OFF SPOIL FROM  
HAULLED OFF SPOIL FROM

Ex. 6 (Personal Privacy)

Employees on Job

G.P. - K.M. - F.P. - B.S. - T.C.  
4HR 1HR 2HR 4HR

Vehicles or Equip. Used

**Sewer Department**

Address

JACKED UP PUMP #2 + BLOCKED, WASHED +  
CLEANED FLOOR, CLEANED OUT SUMP HOLE  
+ SET FAN TO DRY FLOOR AT SUPERIOR

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
7151 Ex. 7f (Water Infra.) PILL BOX

Employees on Job

K.M. - F.P. - B.S. - T.C.  
4HR 4HRCYCLED PUMP AT  
CYCLED BLOWERS A  
CYCLED BY-PASS PUMP AT 15TH

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

9-14-15

CHECKED STATIONS - BELLVIEW ON  
JATTED LINE ON BATES TO RELIEVE HOOSING  
BACKUP - GOT ONE BLOCK BUT STILL HOLDING

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pore



Date 4-13-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

HAULED OFF SPOIL FROM SUPERIOR  
HAULED OFF SPOIL FROM CHURCH RD &

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - G.F.  
GHR

PRESSURE TEST AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11-14-6

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST  
63A  
PILL BOX

Ex. 7f (Water Infra.)

Job Completed

CYCLED PUMP AT  
CYCLED BLOWERS AT  
CYCLED BY-PASS PUM

Ex. 7f (Water Infra.)

Employees on Job

F.P. K.M.  
2HR

CHECKED STATIONS

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 4-12-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address	SERVICE TRUCK W/O.	
	LOCATES	
	MOVED BREAKER BEHIND <b>Ex. 6 (Personal Privacy)</b> PUMPING & CYCLING NOW	
Jobs Completed	CLEANED UP ROAD + SAW CUT PATCH AT MOUSKITH <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job G.F. - F.P. - B.S.	DUG OUT BOX FOR METER CHANGE AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 11-14 - BACKHOE	SPREAD DIRT AT <b>Ex. 6 (Personal Privacy)</b> BACKHOE BLW OUT SEAL BEFORE WE COULD FINISH JOB CHANGED BUCKET ON RIG	
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PICK BOX, CALVIN BLVD <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job K.M.	CYCLED BLOWERS & <b>Ex. 7f (Water Infra.)</b> CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BY-PASS PUMP AT 75TH <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 15		
<b>Meter Readers</b>		
Employees on Job T.C.	FINISHED 17 & 18	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		



Date 4-11-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		GRADED ROCK, SET VALVE BOX FOR CONCRETE POUR, POURED & FINISHED CONCRETE IN PATCH WHERE MAIN BREAK
Employees on Job F.P. - B.S. - K.M. - G.G. 4HR		WAS REPAIRED AT CHURCH RD. & <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 14 - BOTH BACKHOES - 11		INSTALLED RE-SITTER & 18" x 30" P.V.C. METER BOX AT <b>Ex. 6 (Personal Privacy)</b> FOR CONT. THAT BROKE CLAY BOX
<b>Sewer Department</b>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed		CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT
Employees on Job K.M. 4HR		
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job T.C.		FINISHED 14-15
Areas - Read		STARTED 17
Vehicles Used 8		
General Foreman <u>Franky. Pace</u>		



Date 4-10-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	EXPOSED 6" C.I. MAIN / CORP STOP - LEAKING AT CORP STOP - REMOVED CORP STOP & INSTALLED 6" C.I. S.S. CLAMP - BACKFILLED WITH CLEAN	
Employees on Job F.P. - B.S. - G.F. - T.C. - K.M. 4 HR	ROCK & C-M-6 ROCK AT CHANGED IN METER AT	
Vehicles or Equip. Used 11-14 - BACKHOLE - 6	GRADED C-M-6 ROCK AROUND CULVERT AT Ex. 6 (Personal Privacy)	
Sewer Department		
Address	WORKED WITH VILLAGE OF CAHOKIA AT Ex. 6 (Personal Privacy) ONE MAN UNIT & 2 HR	
Job Completed	CYCLED BLOWERS AT OAKLAND CYCLED BY-PASS PUMP AT 75TH	
Employees on Job K.M. T.C. 4 HR 2 HR	BY-PASS PUMPED AT PITTSBURG	
Vehicles or Equip. Used 9-15		
Meter Readers		
Employees on Job T.C. 2 HR	FINISHED 13	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 4-9-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O. LOCATES	
Jobs Completed	BACKFILLED WHERE MAIN BREAK WAS REPAIRED, PUT CULVERT BACK IN PLACE & BACKFILLED WITH ROCK AT	
Employees on Job	F.P. - B.S. - G.F. 3 HR	
Vehicles or Equip. Used	11-14 - BACKHOLE	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 75TH Ex. 7f (Water Infra.) RILL BOX	
Job Completed	CYCLED PUMP AT CYCLED BLOWERS AT CYCLED BY PASS PUMP AT 75TH Ex. 7f (Water Infra.)	
Employees on Job	G.F. 5 HR	
Vehicles or Equip. Used	15	
Meter Readers		
Employees on Job	T.C. FINISHED 11-12	
Areas - Read	STARTED 13	
Vehicles Used	8	
General Foreman <u>Frank J. Pace</u>		

Date 4-6-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>	Comments
Address	O. T.
Jobs Completed	SHUT OFF METER AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy)
Employees on Job G. F.	
Vehicles or Equip. Used 11	
<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	



Date 4-6-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES- Re-READS
Jobs Completed	
Employees on Job BS GF	
Vehicles or Equip. Used 14 11	

Sewer Department

Address	By PASSED 71ST + PII BOX LYCLED Blowers AT 73rd - ALSO
Job Completed	HOLMES. JETTED BEHIND LAKE DR.
Employees on Job TC BS Km	CHECKED STATIONS PH 1
Vehicles or Equip. Used 15 VAC TRUCK	

Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job TC	
Areas - Read FINISHED 9 STARTED 11	
Vehicles Used 8	
General Foreman	B. Smith

Date 4-5-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	EXPOSED MAIN, TREE, VALVE, SOI FITTINGS & FOUND LEAK ON REDUCER BETWEEN VALVE & TREE TIGHTENED DOWN FLANGE BOLTS TO STOP LEAK AT	
Employees on Job F.P. - B.S., K.M. - G.F. 5 HR 1 HR	MOUSSETTE <b>Ex. 6 (Personal Privacy)</b> - GRADED ROAD WITH ROCK & SAW CUT FOR PATCH	
Vehicles or Equip. Used 14-15-11 - BACKHOLE		
<u>Sewer Department</u>		
Address	CHECKED E. ST. LOUIS MANHOLES AT 73RD ST <b>Ex. 7f (Water Infra.)</b> FULL & HOLDING	
Job Completed	PULLED BACK OFF PUMP #2 AND CLEANED OUT RAGS/MOP HEAD. AT <b>Ex. 7f (Water Infra.)</b>	
Employees on Job F.P. - B.S. 3 HR		
Vehicles or Equip. Used 14		
Meter Readers		
Employees on Job T.C. - G.F. 7 HR	FINISHED 7 & 8 - T.C. 9, 3, 4, 5, 6, 7, 8 - G.F.	
Areas - Read	STARTED	
Vehicles Used 8-15		
General Foreman	Franky Pace	

Date 4-4-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT BACKSIDE AT <b>Ex. 6 (Personal Privacy)</b> USED NEW METER SHUT OFF & RESETER	
Employees on Job G.F. - F.P. - B.S.	HOOKED UP BACKSIDE AT <b>Ex. 6 (Personal Privacy)</b> USED ONE METER COUPLING, 6' OF 3/4" COPPER TUBING & ONE 3/4" X 3/4" UNIVERSAL COMP. FITTING	
Vehicles or Equip. Used 11-14 - BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPS AT <b>Ex. 7f (Water Infra.)</b>	
Job Completed	ADJUSTED FLOATVALVES AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S. K.M. 1.5 HR 4 HR	CHECKED SOME STATIONS (SOUTH END)	
Vehicles or Equip. Used 14- 15	SETTLED LINE FOR VILLAGE OF CAHOKIA AT <b>Ex. 6 (Personal Privacy)</b> UNIT 9 & T.C. 4 HR	
Meter Readers		
Employees on Job T.C. - K.M. 4 HR	FINISHED 6 T.C.	
Areas - Read	STARTED 9 K.M.	
Vehicles Used 8-15		
General Foreman	Frank J. Pace	



Date 4-3-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W/O.
Jobs Completed	
Employees on Job C.F.	
Vehicles or Equip. Used	

Sewer Department

Address	CHECKED STATIONS - PUMPED OUT CANS AT OAKLAND, BELLEVUE, & BLUFF
Job Completed	WORKED ON NEW PUMP INSTALLATION AT SUPERIOR - HOOKED UP & READY TO WELD/GRIND
Employees on Job K.M. - F.P. - B.S. 4 HR	CYCLD CROCKETS FOR 6 HR.
Vehicles or Equip. Used 14-15	

Meter Readers

Employees on Job T.C.	FINISHED 5
Areas - Read	
Vehicles Used 8	

General Foreman

Frank J. Pace

Date 4-2-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		BY-PASS PUMPED AT <b>Ex. 7f (Water Infra.)</b> PUMPED OUT CANS AT BELLEVUE, BLUFF OAKLAND
Job Completed		CHANGED OIL IN BLOWERS AT AMES, CROCKETT, PERSHING INSTALLED SUMP PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job K.M. - F.P. - B.S.		CHECKED STATIONS
Vehicles or Equip. Used 14-15		CHECKED FOR BACKUP AT <b>Ex. 6 (Personal Privacy)</b> CUST. PROBLEM
<u>Meter Readers</u>		
Employees on Job T.C.		FINISHED 344
Areas - Read		STARTED 5
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 5-31-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service TRUCK work orders
Jobs Completed	SPREAD 1 Bucket of dirt & Seeded AT
Employees on Job GF BS-KM	
Vehicles or Equip. Used 11 14- BACK HOE	

Ex. 6 (Personal Privacy)

Sewer Department

Address	By PASSED BOTH SPOTS AT 71ST cycled Blowers AT 73rd ST
Job Completed	RAN Ex. 6 (Personal Privacy) Repaired sewer LATERAL AT
Employees on Job KM BS-FP	TURNED BOTH PUMPS ON AT violet - PUMPS Seamed line -
Vehicles or Equip. Used 15 14 BACK HOE	NEED TO Re-check STATUS FRIDAY OR MONDAY

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Meter Readers

Employees on Job TC	
Areas - Read FINISHED 3	STARTED 4
Vehicles Used 8	
General Foreman	B. Smith



Date 5-30-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.  LOCATES	
Jobs Completed	REBUILT SERVICE AT <b>Ex. 6 (Personal Privacy)</b> USED 12' OF 3/4" COPPER TUBING - ONE USED METER COUPLING, ONE USED METER SHUTOFF ONE 3/4" I.P. X 3/4" COMP. - ONE 3/4" FLARE X 3/4" COMP. - ONE 18" X 30" P.V.C. METER BOX - INSTALLED R.R. METER & LID FROM SHOP BACKFILLED WITH SPOIL	
Employees on Job G.F. F.P. - B.S. - T.C. 4 HR 2 HR		
Vehicles or Equip. Used 8-14-BACKHOE		
<u>Sewer Department</u>		
Address	PULLED PUMPS & CLEANED OUT RAGS AT <b>Ex. 7f (Water Infra.)</b> LATING WELL FILL TO CHECK PUMPS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> 63RD	
Employees on Job K.M. - F.P. - T.C. - B.S. 4 HR 2 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Vehicles or Equip. Used 7-14-15	BLUFF IS ON & CYCLING	
Meter Readers		
Employees on Job T.C. 2 HR	FINISHED AREA 1	
Areas - Read		
Vehicles Used 8		
General Foreman	Frank J. Pace	

Date 5-29-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATED	
Jobs Completed		
Employees on Job F.P. G.F. 1 HR		
Vehicles or Equip. Used 14 - 11		
<u>Sewer Department</u>		
Address	CHECKED SOME STATIONS - BLUFF ON CHECKED FOR BACKUP AT COST. PROBLEM	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX Ex. 7f (Water Infra.)	
Employees on Job F.P. - K.M. 2 HR	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS A	
Vehicles or Equip. Used 14 - 15		
<u>Meter Readers</u>		
Employees on Job F.P. - T.C. 5 HR	FINISHED 29 - F.P., T.C. 2 - T.C.	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pae</u>		

Date 5-25-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	INSTALLED R.R. METERS ON MILDRED
Employees on Job C.G.F. - T.C. 4 HR	
Vehicles or Equip. Used 8-11	

Sewer Department

## Address

CHECKED STATIONS  
SUPERIOR ON PUMP #2

## Job Completed

BY-PASS PUMPED WITH 3" GAS DUMP AT  
71ST Ex. 7f (Water Infra.) PULL BOX

## Employees on Job

K.M. - F.P. - G.F.  
4 HR

CYCLED PUMP AT  
CYCLED BLOWERS

Ex. 7f (Water Infra.)  
Ex. 7f (Water Infra.)

## Vehicles or Equip. Used

14-15

## Meter Readers

## Employees on Job

T.C.  
4 HR

FINISHED  
22 - T.C.

## Areas - Read

## Vehicles Used

8

## General Foreman



Date 5-28-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

H  
O  
L  
I  
D  
A  
YSewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

M  
E  
M  
O  
R  
I  
A  
L

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

D  
A  
YGeneral Foreman Frank J. Pace

Date 5-24-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed		
Employees on Job G.F. - F.P. - B.S. 2 HR		
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	PULLED BY-PASS PUMP & CLEANED OUT RAGS AT BELLEVIEW ~ BLUFF IS OFF	
Job Completed	JACKET LINES ON 73RD TO RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b> ST. - THINK IT IS CUSTOMER PROBLEM	
Employees on Job F.P. - B.S. T.C. 6 HR 2 HR	CHECKED STATIONS	
Vehicles or Equip. Used 7-14-9		
<u>Meter Readers</u>		
Employees on Job T.C. - K.M. 6 HR	FINISHED 21-T.C. 23-24-26-K.M.	
Areas - Read	STARTED 22-T.C.	
Vehicles Used 8-15		
General Foreman <u>Frank J. Pace</u>		

Date 5-23-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SEAVICK TRUCK W.O. LOCATING	
Jobs Completed	SHUT OFF SERVICE AT CORP STOP/MAIN AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job <u>F.P. - B.S.</u> 6 HRS		
Vehicles or Equip. Used 14 - BACKHOE		
<u>Sewer Department</u>		
Address	PULLED PUMP #1 & CLEANED OUT RAGS CLEANED TRANSDUCER AT CRISTON	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILEY BOX	
Employees on Job <u>F.P. - B.S. - K.M.</u> 2 HRS 5 HRS	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Vehicles or Equip. Used 14-15-7		
<u>Meter Readers</u>		
Employees on Job T.C. - K.M. 3 HRS	FINISHED 19 - T.C. & K.M. 20 - T.C.	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		



Date 5-22-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICER TRUCK W.O. LOCATES	
Jobs Completed		
Employees on Job T.C. S.M.R.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT BRIDGEDALE STATION	
Job Completed	JACKETED LINE TO RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S. - K.M. - T.C. 3 P.M.	REPLACED 4" CHECK VALVE WITH NEW CHECK VALVE AT BRIDGEDALE	
Vehicles or Equip. Used 9-14-15-7		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 5-21-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	REPAIRED 14" MAIN BREAK AT ACNES & <div style="background-color: black; color: red; padding: 2px;">Ex. 6 (Personal Privacy)</div> USED TWO 1" P.V.C. BARB FITTINGS, & 60" OF 1" P.V.C. TUBING.
Employees on Job F.P. - B.S. - T.C.	
Vehicles or Equip. Used G-14 - BACKHOL - 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <div style="background-color: black; color: red; padding: 2px;">Ex. 7f (Water Infra.)</div> <div style="background-color: black; color: red; padding: 2px;">Ex. 7f (Water Infra.)</div> <div style="background-color: black; color: red; padding: 2px;">Ex. 7f (Water Infra.)</div>
Job Completed	CYCLED PUMP AT <div style="background-color: black; color: red; padding: 2px;">Ex. 7f (Water Infra.)</div> CYCLED BLOWERS
Employees on Job K.M.	
Vehicles or Equip. Used 15	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 5-21-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

1 HR. CALL OUT  
O.T.

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

CHECKED FOR BACKUP AT  
HAZEL - FOUND OUR LINE WAS  
BLOCKED & HOLDING

Ex. 6 (Personal Privacy)

Employees on Job

F.P.

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 5-18-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPLACED CHLORINATING LINE, INTERCEPTOR, & CORP. STOP AT <b>Ex. 7f (Water Infra.)</b>	
Employees on Job <u>F.P. - B.S. - G.P.</u> <u>4 HR</u>		
Vehicles or Equip. Used <u>11-14</u>		
<b>Sewer Department</b>		
Address	CHECKED STATIONS - ALL GOOD	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job <u>F.P. - B.S. - K.M.</u> <u>4 HR</u>	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Vehicles or Equip. Used <u>14-15</u>		
<b>Meter Readers</b>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-17-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. HEREADS	
Jobs Completed		
Employees on Job G.F. - T.C. CNR		
Vehicles or Equip. Used 8-11		
<u>Sewer Department</u>		
Address	PULLED PUMP & CLEANED OUTRAGE, LOWERED PUMP & ADJUSTED FLOAT BALLS AT BELLVIEW BLUFF ON & PUMPING & CYCLING	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT GDNSE <b>Ex. 7f (Water Infra.)</b> CHECKED FOR BACKUP AT <b>Ex. 6 (Personal Privacy)</b> HOUSE CUST. PROS.	
Employees on Job F.P. - B.S. - T.C. - K.M. 2HR 6HR	CYCLED STATIONS AT <b>Ex. 6 (Personal Privacy)</b> OAKLAND, CROCKETS - CHECKED FOR BACKUP AT <b>Ex. 6 (Personal Privacy)</b> 23RD - CUST. WAS GOOD AFTER SYSTEM PUMPED DOWN	
Vehicles or Equip. Used 14-15-8	RAW PUMP #1 AT SUPERIOR - #2 PUMPING (OLD) (NEW) NOW	
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-16-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

WORK orders

Jobs Completed

REPAIRED SERVICE LEAK ON  
ST. SPLICED 2' PIECE OF COPPER  
2- PACK JOINT FITTINGS

Ex. 6 (Personal Privacy)

Employees on Job

GF  
BS-TC-VM

1 LOAD CMB

Vehicles or Equip. Used

14 " 11  
DUMP- BACKHOE

Sewer Department

Address

BY PASSED 71ST BOTH LOCATIONS  
CYCLED BLOWERS ON 73rd - RAN  
STATION

Ex. 7f (Water Infra.)

Job Completed

CHECKED PH 2 SEWERS  
CHECKED #1 PUMP AT SUPERIOR

Employees on Job

VM  
TC-BS

TURNED ON BRIEFLY

Vehicles or Equip. Used

14-15


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman





Date 5-15-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	HAULED IN TWO BUCKETS OF DIRT & GRADED, RAISED BOX WITH 2" CLAY RISER, AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job F.P. - B.S. - K.M. G.F. QHR	
Vehicles or Equip. Used 11-14-15 - BACKHOL	

Sewer DepartmentAddress

REMOVED BACK OF PUMP, CLEANED OUT RAGS, &amp; HAIR FROM PUMP, TOOK OFF FILL PLATE &amp; PRIMED PUMP - DISCHARGE LINE

Job CompletedIS BLOCKED - PUMP WON'T PUMP - NEED TO REPLACE CHECK VALVE & GATE VALVE ON DISCHARGE LINE & CLEAN AT **Ex. 7f (Water Infra.)**Employees on JobF.P. - B.S. - K.M.  
GHR

STATION FRONT,

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)** OUR LINES DOWN & FLOWING - CUST. PROB.Vehicles or Equip. Used

14-15 - BACKHOL

**Ex. 6 (Personal Privacy)**

CHECKED ON SEWER ODOR IN HOUSE AT OUR LINES ARE DOWN - CUST. PROB.

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman

Frank J. Pore

Date 5-14-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT & MOVED SERVICE AT <b>Ex. 6 (Personal Privacy)</b> USED 15' OF 3/4" COPPER TUBING, ONE METER SHOT OFF, ONE METER COUPLING, ONE	
Employees on Job F.P. - B.S. - G.F. - T.C. 6 HR	3/4" P.V.C. BARB X 3/4" COMP. FITTING, ONE 3/4" X 3/4" COMP. FITTING, INSTALLED R.R. RING, LOCK LID, & METER, RE-USED 18" X 30"	
Vehicles or Equip. Used 8-11-14 - BACKHOLE	P.V.C. METER BOX - BACKFILLED WITH SPOIL GRADED DIRT IN YARD WHERE MAIN WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b>	
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> <b>Ex. 7f (Water Infra.)</b>	
Job Completed	PULLED BACK OFF PUMP & CLEANED OUT RAGS AT BRIDGDALE TWICE	
Employees on Job F.P. - B.S. K.M. 2 HR		
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		



Date 5-11-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED YARD WITH DIRT & SIDEWALK WITH ROCK WHERE MAIN BREAK WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S. - T.C. 4 HR		
Vehicles or Equip. Used 14-11- BACKHOE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715' <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A CHECKED SOME STATIONS ON NORTH END	
Employees on Job F.P. - B.S. - K.M. 4 HR 4 HR	CLEANED DEBRIS OUT OF MANHOLE & REPLACED RING & CID ON MANHOLE AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 14-15- BACKHOE	CYCLED PUMP #2 AT SUPERIOR - ONLY WORKING OFF OF ONE FLOATBALL	
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 5-10-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	RAISED BOX WITH 5 1/2" CLAY RISER WHERE CUST PUT ROCK OVER BOX AT	
Employees on Job	G.F. - B.S. - F.P. - T.C. 2 HR	
Vehicles or Equip. Used	11 - 14 - 8	
<u>Sewer Department</u>		
Address	WIKED UP PUMP, PUT COVER ON MOTOR, TIGHTENED BOLTS ON MOTOR TO FRAME CHECKED ALL BOLTS, PRIMED PUMP &	
Job Completed	GOT PUMPING - STATION WENT ALTERNATE RUNNING CROWN PUMP FOR NOW.	
Employees on Job	F.P. - B.S. - T.C. - K.M. 6 HR 2 HR	
Vehicles or Equip. Used	9-14	
<u>Meter Readers</u>		
Employees on Job	FINISHED T.C. - K.M. 4 HR 6 HR 14-K.M. - 17-T.C. - 18-T.C. & K.M.	
Areas - Read		
Vehicles Used	8-15	
General Foreman	Frank J. Boer	

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

EDWA

Date 5-9-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	DUG OUT RING + LID AT <b>Ex. 6 (Personal Privacy)</b> REPLACED METER WITH NEW NEPTUNE RADIO READ METER - CUT 5" CLAY RISER AT SHOP, REPLACED RING + LID + BACK FILLED	
Employees on Job F.P. - B.S. - G.F.	GRADED DIRT, SET RIP RAP AROUND CULVERT, GRADED ROCK AROUND RIP RAP + DRIVEWAY ENTRANCE AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 11-14 - BACKHOE	GRADED ROCK IN DRIVE AT <b>Ex. 6 (Personal Privacy)</b>	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, CALVIN BLVD <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job K.M.		
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 13	
Areas - Read	STARTED 14	
Vehicles Used 11		
General Foreman <u>Frank J. Pace</u>		



Date 5-8-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATLS	
Jobs Completed	TOOK MAIL TO E. ST. LOUIS POST OFFICE	
Employees on Job C.P. F.P. 2 HR		
Vehicles or Equip. Used 11-14		
<b>Sewer Department</b>		
Address	CHECKED STATIONS - ALL GOOD NEED TO VACUUM OFF SOLIDS FROM TOP AT <b>Ex. 6 (Personal Privacy)</b>	
Job Completed	PUT PUMP BACK ON A SPOOL IN SUCTION LINE, PRIMED PUMP, & GOT PUMP PUMPING AT <b>Ex. 6 (Personal Privacy)</b> SYSTEM DOWN	
Employees on Job F.P. - B.S. T.C. 6 HR 1 HR	CYCLED OAKLAND & CROCKETTS BLOWERS	
Vehicles or Equip. Used 14-7-9		
<b>Meter Readers</b>		
Employees on Job K.M. - T.C. 7 HR	FINISHED 15-K.M. 11 & 12 - T.C.	
Areas - Read	STARTED 17-K.M.	
Vehicles Used 8-15		
General Foreman <u>Frank J. Pace</u>		



Date 5-7-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O,	
Jobs Completed	CHANGED METER TO NEW NEPTUNE RADIO READ METER AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	G.F. - <u>F.P. - B.S.</u> T.C. 2HR 2HR	
Vehicles or Equip. Used	11-14-8-BACKHOLE	

Sewer Department		Comments
Address	JETTED LINE TO RELIEVE BACKUP IN THE <b>Ex. 6 (Personal Privacy)</b> OF LAKE DR.	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 715' <b>Ex. 7f (Water Infra.)</b> PILL BOX, PITTSBURG <b>Ex. 7f (Water Infra.)</b>	
Employees on Job	CYCLAD BLOWERS AT OAKLAND & CROCKETS K.M. - <u>F.P. - B.S.</u> - T.C. 6HR 4HR	
Vehicles or Equip. Used	15-14-9 - REMOVED BACK OF PUMP & BOUL IN <del>GROUND</del> SUCTION LINE TO REMOVE ROOT BALL FROM PUMP/LINE AT <b>Ex. 6 (Personal Privacy)</b> USED TO PRIME PUMP & GET PUMPING	

Meter Readers		
Employees on Job	T.C. 2HR	FINISHED METER THAT WERE LEFT OUT OF PASSPORT
Areas - Read		
Vehicles Used	8	
General Foreman	<u>Frank J. Pace</u>	

Date 5-4-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES
Jobs Completed	BACK FILLED ROAD WITH CLEAN ROCK & C-M-G ROCK WHERE MAIN BREAK WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b> HAULLED OFF
Employees on Job F.P. B.S. T.C. G.F. 4HR 2HR 2HR	SPOIL THRU & ON HOWELL
Vehicles or Equip. Used 6-14-BACKHOL-11	

Sewer Department

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
Employees on Job B.S. 6HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS
Vehicles or Equip. Used 15	NEED TO JET ON <b>Ex. 6 (Personal Privacy)</b> MAKE <b>Ex. 6 (Personal Privacy)</b> NOT PUMPING

Meter Readers

Employees on Job F.P. T.C. GHR 4HR 6HR	FINISHED MANUALS 9-T.C. & F.P. - 10-F.P.
Areas - Read	
Vehicles Used 14-9	
General Foreman	Frank J. Pace



Date 5-3-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.D.	
Jobs Completed	REPAIRED MAIN BREAK ON BELL AT Ex. 6 (Personal Privacy) USED TWO 4" SOLID SLEEVES 2 4 GLAND PACKS, 24" OF 4" C-900 P.V.C. NEED TO BACK FILL - RIBBONS OFF	
Employees on Job	G.F. - F.P. - B.S.	
Vehicles or Equip. Used	11-14-15-BACKHOLE	
<b>Sewer Department</b>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<b>Meter Readers</b>		
Employees on Job	FINISHED 8	
Areas - Read	STARTED 9	
Vehicles Used	8	
General Foreman	Frank J. Pace	



Date 5-2-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SECTION TRUCK W.O.

Jobs Completed

Ex. 6 (Personal Privacy)

POURED NEW COPPER LINE UNDER ROAD AT  
USED ONE 3/4" FLAREX COMP. FITTING,  
40' OF 3/4" COPPER TUBING, ONE METER SHUT OFF,  
ONE METER COUPLING, ONE 18" X 30" P.V.C.

Employees on Job

F.P. - B.S. - G.F.  
3 HR

METER BOX. BACKFILLED WITH SPOLIC.

Vehicles or Equip. Used

11-14- BACKHOE

**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST Ex. 7f (Water Infra.) PILL BOX

Job Completed

CYCLED PUMP AT  
CYCLED BLOWERS A

Ex. 7f (Water Infra.)

Employees on Job

G.F.  
5 HR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C.

FINISHED

5 MANUALS

Areas - Read

Vehicles Used

7

General Foreman

James J. Pace

Date 5-1-18

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	JETTED LINE AT <b>Ex. 6 (Personal Privacy)</b> FOR VILLAGE OF CAHOKIA - ONE MAN & UNIT #9 2 HR.
Job Completed	JETTED LINE TO RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job F.P. - T.C. 4 HR	PULLED PUMP BEHIND <b>Ex. 6 (Personal Privacy)</b> CLEANED OUT RAGS - RAISED PUMP ABOUT 8" TO 12"
Vehicles or Equip. Used 9-14 - BACKHOE	CHECKED STATIONS - NEED TO VAC OFF SOLIDS AT <b>Ex. 6 (Personal Privacy)</b> OAT BALLS HANGING UP ON SOLIDS - WELL WAS FULL - PUMPING NOW

**Meter Readers**

Employees on Job F.P. - T.C. 4 HR	FINISHED MANUALS 7-F.P. - 4-T.C.
Areas - Read	
Vehicles Used 14-15	

General Foreman

Frank J. Paul



Date 6-29-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F. DHR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	CHECKED STATIONS Ex. 7f (Water Infra.) FRONT RUNNING ON PUMP #1 ONLY	
Job Completed	REMOVED BLOWER AT Ex. 7f (Water Infra.) PULLED BACK & CLEANED OUT RAGS AT BRIDGE DALE	
Employees on Job F.P. - T.O. - K.M. - G.F. ONE	REPAIRED AIR LINE AT 63A Ex. 7f (Water Infra.) USED ONE 2" C.I. SS. REPAIR CLAMP	
Vehicles or Equip. Used 11-14-15 - BACKHOE	TREE LIMB ON WIRES AT SNOWS	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Price	



Date 6-28-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address	<u>SERVICE TRUCK W.D.</u> <u>LOCATES</u>	
Jobs Completed	REPAIRED 6" C.I. MAIN BREAK WITH ONE 6" S.S. REPAIR CLAMP - BACK FILLED WITH ONE LOAD 1" CLEAN ROCK & 1/2 LOAD C-M-G AT	
Employees on Job <u>G.F. - F.P. - T.C. - K.M.</u> <u>5 HR</u>	<b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used <u>11-14-6-BACKHOE</u>		
<b>Sewer Department</b>		
Address	<u>CHECKED STATIONS ON SOUTH END</u>	
Job Completed	<u>PULLED PUMP &amp; CLEANED OUT RAGS</u> <u>BEHIND</u> <b>Ex. 6 (Personal Privacy)</b> <u>PUMPING NOW</u>	
Employees on Job <u>F.P. - T.C. - K.M.</u> <u>3 HR</u>		
Vehicles or Equip. Used <u>14-BACKHOE-8</u>		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 6-27-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE WORK TRUCK W.O.	
Jobs Completed		
Employees on Job G.F. 4 HR		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 82ND ST.	
Job Completed	CHECKED STATIONS - HOLE IN AIR LINE AT 63RD <b>Ex. 6 (Personal Privacy)</b> REPAIR NEED TO PULL PUMP BEHIND <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - G.F. - K.M. 4 HR	<b>Ex. 7f (Water Infra.)</b> STARTER WAS KICKED OUT - RE-SET & PUMPED SYSTEM DOWN	
Vehicles or Equip. Used 14 - 15	<b>Ex. 6 (Personal Privacy)</b> OFF CYCLED STATIONS - HOLMES - OAKLAND - CROCKETTS	
Meter Readers		
Employees on Job T.C.	FINISHED 26, 142	
Areas - Read		
Vehicles Used 8		
General Foreman	Frank P. Pace	

Date \_\_\_\_\_

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	SWEPT GARAGE FLOOR & CAGE WORK orders
Jobs Completed	
Employees on Job GF BS TC	
Vehicles or Equip. Used 11	

Sewer Department

Address

 JETTED LINE **Ex. 6 (Personal Privacy)**  
 CHANGED OIL IN BOTH 3" PUMPS

Job Completed

Employees on Job

BS  
TC GF

Vehicles or Equip. Used

VAC TRUCK  
14

Meter Readers

Employees on Job

TC

Areas - Read

FINISHED 24

Vehicles Used

8

General Foreman

B. Smith



Date 6-25-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O.  LOCATES	
Jobs Completed		
Employees on Job G.F. - F.P. 2 HR		
Vehicles or Equip. Used  11-14		
<b>Sewer Department</b>		
Address	JACKETED LINE AT <b>Ex. 6 (Personal Privacy)</b> RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b>	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 <b>Ex. 7f (Water Infra.)</b> ALL BOX	
Employees on Job F.P. - B.S. - T.C. 6 HR 2 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Vehicles or Equip. Used  9-14-15	CHECKED STATIONS	
<b>Meter Readers</b>		
Employees on Job T.C. 6 HR	FINISHED 22	
Areas - Read	STARTED 24	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 6-22-18

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address		WORK orders
Jobs Completed		
Employees on Job BS		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		By PASSED 71ST BOTH SPOTS
Job Completed		RAN HOLMES PUMP CYCLED BLOWERS AT 73 <sup>00</sup>
Employees on Job BS KM		checked PH. 1 sewers
Vehicles or Equip. Used 11 15		By PASSED 82ND ST
Meter Readers		
Employees on Job TC		
Areas - Read 21 STARTED 22		
Vehicles Used 8		
General Foreman	B. L. L. L.	

Ex. 7f (Water Infra.)

Date 6-21-18

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address	Service TRUCK WORK orders	
Jobs Completed		
Employees on Job GF		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<b>Meter Readers</b>		
Employees on Job BS TC		
Areas - Read 19-20 23	STARTED 24-20	
Vehicles Used 7-8		
General Foreman	B. Smith	



Date 6-20-18

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

WORK orders

Jobs Completed

RAKED OUT DIRT AROUND  
METER BOXES AT APTS. AT  
END OF COOPER.

Employees on Job

GF  
BS TCBROUGHT IN 7 LOADS OF DIRT  
FROM 88TH ST.

Vehicles or Equip. Used

11  
14 Dump & Hoe**Sewer Department**

Address

BY PASSED 71ST BOTH SPOTS  
CYCLED BLOWERS AT 73rd & RAN

Job Completed

Ex. 7f (Water Infra.) ALSO PUMPED  
DOWN 82nd ST

Employees on Job

KM

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Date 6-19-18

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments****Address**

Service TRUCK work orders

**Jobs Completed**

filled in AROUND BOX

Ex. 6 (Personal Privacy)

Used 3 Buckets of DIRT A

Ex. 6 (Personal Privacy)

**Employees on Job**GF  
BS TCDOWN IN the DITCH - checked on  
VILLAGE meter AT GOLF COURSE**Vehicles or Equip. Used**

11 - 15 BACKHOE

REPAIRED 88TH ST WITH ROCK

**Sewer Department****Address**

BY PASSED CALVIN

CHANGED OIL IN BLOWERS

**Job Completed**

CROCKETS, OAKLAND &amp; PERSHING

**Employees on Job**KM  
BS TC

checked ON STANDING WATER

AT Ex. 6 (Personal Privacy) WATER CO

**Vehicles or Equip. Used**15  
14

HAS A LEAK IN ALLEY

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

D. Drivil

Date 6-18-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

work orders  
&  
LOCATES

Jobs Completed

Employees on Job

GF  
BS-TC

Vehicles or Equip. Used

8  
11Sewer Department

Address

By PASSED 71ST BOTH SPOTS  
CYCLED Blowers AT 73rd ST  
By PASSED PITTSBURGH

Job Completed

Employees on Job

Km  
BS TC

checked STATIONS

Vehicles or Equip. Used

15  
8

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

B. Smith



Date 6-15-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	WRECKED OFF FORMS WHERE CONCRETE WAS POURED FOR SIDEWALKS + GRADED DIRT + SPREAD SELDS AT <b>Ex. 6 (Personal Privacy)</b> JEROME	
Employees on Job F.P. - B.S. - T.C. 5 HR	<b>Ex. 6 (Personal Privacy)</b> BLOCK OF JEROME	
Vehicles or Equip. Used 11-14-BACKHOLE	GRADED DIRT + SPREAD SELDS AT <b>Ex. 6 (Personal Privacy)</b>	
<b>Sewer Department</b>		
Address	CHECKED STATIONS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, 82ND ST	
Employees on Job R.M. - F.P. - B.S. 3 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS.	
Vehicles or Equip. Used 15-8		
<b>Meter Readers</b>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 6-14-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.D.
Jobs Completed	POURED CONCRETE FOR SIDEWALKS AROUND DISTRICT
Employees on Job F.P. - B.S. - G.F. - T.C. 4 HR 1 HR	
Vehicles or Equip. Used 11-14 - BACKHOE - 8	

Sewer Department

Address	W7 WIRED IN & SET PUMP BEHIND Ex. 7f (Water Infra.)
Job Completed	CHECKED SOME STATIONS (SOUTH END) LOCATES
Employees on Job F.P. - B.S. - T.C. 4 HR	
Vehicles or Equip. Used 14-7-8	

Meter Readers

Employees on Job T.C. 3 HR	FINISHED 18
Areas - Read	
Vehicles Used 8	
General Foreman	Frank J. Pace

Date 6-13-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	REPLACED CRUSHED BOX, R.R. METER REMOVED OLD CRUSHED BOX & REPLACED WITH 18"X30" P.V.C. METER BOX - REPLACED R.R.
Employees on Job F.P. - B.S. - G.P.	METER WITH 1" R.R. METER FROM SHOP RE-SET POLE ON SIDE OF BOX AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 11-14- BACKHOE	EXPOSED 15-20' OF 6" MAIN, BUT COULDN'T FIND TAP FOR <b>Ex. 6 (Personal Privacy)</b> BACKFILLED WITH SPOIL & TWO BUCKETS OF C-M-G ROCK

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 63RD <b>Ex. 7f (Water Infra.)</b>
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS
Employees on Job K.M. GHR	
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job T.C.	FINISHED 17
Areas - Read	STARTED 18
Vehicles Used 8	

General Foreman Frank J. Pace



Date 6-12-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W/O,	
Jobs Completed	GRADED, REMOVED CONCRETE, SET FORMS FOR CONCRETE AT <b>Ex. 6 (Personal Privacy)</b> THEROME, RANGELANE <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	F.P. - B.S. - G.F. - K.M. 4 HR	
Vehicles or Equip. Used	11-14-15- BACKHOL	
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND ST.	
Employees on Job	K.M. 4 HR	
Vehicles or Equip. Used	15	
<b>Meter Readers</b>		
Employees on Job	T.C.	FINISHED 15
Areas - Read		STARTED 17
Vehicles Used	7-8	
General Foreman <u>Frank J. Pace</u>		

Date 6-11-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	FILLED IN AROUND BOXES WITH DIRT, GRADED & SEEDED AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	G.F. - F.P. - B.S. <b>Ex. 6 (Personal Privacy)</b> JULIAN	
REPAIRED YARD & REMOVED CONCRETE PIECE OF SIDEWALK WHERE MAIN BREAK WAS REPAIRED AT	<b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used	REMOVED SIDEWALK, GRADED & SET FORMS FOR CONCRETE AT <b>Ex. 6 (Personal Privacy)</b>	
11-14- BACKHOE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CALVIN BLVD	
Employees on Job	K.M.	
Vehicles or Equip. Used	15	
<u>Meter Readers</u>		
Employees on Job	T.C. FINISHED 13414	
Areas - Read		
Vehicles Used	8-7	
General Foreman	Frank J. Pace	

Date 6-8-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.D. LOCATES RE-READS	
Jobs Completed		
Employees on Job		
F.P. - G.F. 3HR		
Vehicles or Equip. Used		
11-14		
<u>Sewer Department</u>		
Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job	WORKED ON 51ST <b>Ex. 7f (Water Infra.)</b> READY TO BE GROUND DOWN	
F.P. - B.S. - K.M. 5HR 4HR		
Vehicles or Equip. Used	CHECKED STATIONS - PULLED BACK OFF PUMP & CLEANED RAGS OUT AT BRIDGEDALE	
14-15		
<u>Meter Readers</u>		
Employees on Job	T.C. FINISHED 11 & 12	
Areas - Read		
Vehicles Used		

General Foreman

Frank J. Pace



Date 6-7-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	PULLED PUMP, CLEANED OUT RAGS AT 82ND <b>Ex. 7f (Water Infra.)</b> TURNED BLUFF ON AT 3:30 P.M.
Job Completed	INSTALLED CHECK VALVE ON PUMP #1 AT <b>Ex. 7f (Water Infra.)</b> FRONT BOTH PUMPS PUMPING + ALTERNATING
Employees on Job B.S. - F.P.	
Vehicles or Equip. Used 7-14	

Meter Readers

Employees on Job K.M.	STARTED - ALMOST FINISHED - 8 PASSPORT DIED
Areas - Read	
Vehicles Used 8	

General Foreman Frank J. Pace

Date 6-6-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job F.P. - B.S. - K.M.	REMOVED OLD GATE VALVE & CHECK VALVE INSTALLED NEW GATE VALVE ON PUMP #1 AT <b>Ex. 7f (Water Infra.)</b>	
Vehicles or Equip. Used 14-15- BACKHOLE		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 7 & 8	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 6-5-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		PULLED PUMP AT BELLEVUE & TOOK TO IL MO PUMP FOR REPAIR - INSTALLED NEW PUMP FROM IL MO PUMPING NOW
Job Completed		PULLED PUMP AT 75TH CLEANED OUT RAGS/ROOT BALL - PUMPING NOW
Employees on Job F.P. - B.S.		
Vehicles or Equip. Used 7-14		
<u>Meter Readers</u>		
Employees on Job T.C.		FINISHED 6 & 10
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Ex. 7f (Water Infra.)



Date 6-4-12

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	RESET VALVE BOX AT CHURCH RD & Ex. 6 (Personal Privacy) LEAKED VALVE TO STOP LEAK
Employees on Job G.F. - F.P. - B.S. 4 HR	TO REPLACE VALVE AT CHURCH NEED ONE 4" M.I. VALVE, ON 4" X 4" TEE & THREE 4" C.I. SOLID SLAVES Ex. 6 (Personal Privacy)
Vehicles or Equip. Used HYDRO HAMMER 11-14 - BOTH BACKHOES	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) FILL BOX, CALVIN BLVD.
Job Completed	CHECKED STATIONS NEED TO PULL & CLEAN PUMP AT 82ND Ex. 7f (Water Infra.)
Employees on Job K.M. - F.P. - B.S. 4 HR	CYCLED PUMP AT CYCLED BLOWERS Ex. 7f (Water Infra.)
Vehicles or Equip. Used 14-15	CHECKED FOR BACKUP AT AFTER PUMPING & CUST. LATERAL WAS DOWN Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job T.C.	FINISHED 5
Areas - Read	STARTED 10
Vehicles Used 8	

General Foreman Frank J. Pace

Date 6-1-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O, WORKED ON GETTING STEAMER NOZZLE OFF HYDRANT IN YARD - COULDN'T GET NOZZLE OFF	
Jobs Completed	REPLACED METER SHUT OFF AT <b>Ex. 6 (Personal Privacy)</b> EXPOSED SERVICE LINE OUTSIDE BOX & CRIMPED OFF & REPLACED	
Employees on Job F.P. - B.S. - G.F. - K.M. 6 HR 4 HR	SHUT OFF WITH USED SHUT OFF FROM SHOP EXPOSED MAIN & TRIED TO MOVE VALVE BOX AT CHURCH RD <b>Ex. 7f (Water Infra.)</b> NEED TO	
Vehicles or Equip. Used 15-11-14 - BACKHOLE	REMOVE CURB AROUND BOX - CUT CURB	
<u>Sewer Department</u>		
Address	BY-PASS PUMPER WITH 3" GAS PUMP AT 715 <b>Ex. 7f (Water Infra.)</b> RILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job F.P. - B.S. K.M. 2 HR 4 HR	CHECKED STATIONS ON SOUTH SIDE <b>Ex. 7f (Water Infra.)</b> PUMPING & CYCLING	
Vehicles or Equip. Used 14-15	SUPERIOR ALTERNATIVE NOW ?	
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 4	
Areas - Read	STARTED 5	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		



Date 7-31-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICER TRUCK W.O.
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		VACUUMED OFF SOLIDS AT BEHIND <b>Ex. 6 (Personal Privacy)</b> <b>Ex. 7f (Water Infra.)</b> PULLED OUT S.S. RAILS FROM BEHIND <b>Ex. 7f (Water Infra.)</b>
Job Completed		TIGHTENED BELT ON PUMP & FRONT P.S. BY-PASS PUMPS WITH 3" GAS PUMP AT VIOLET SO WE COULD PULL PUMPS
Employees on Job F.P. - B.S. - T.C. - K.M.		PULLED PUMPS & CLEANED OUT RAGS AT VIOLET - PUMPING ON HAND - WELL TO LOW FOR AUTO
Vehicles or Equip. Used 14-15-9-7		CHECKED STATIONS
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	



Date 1-30-18Daily Job Sheet 1Sheet 1 of 1Water Department

## Comments

Address	Service TRUCK Work orders
Jobs Completed	Turned off <b>Ex. 6 (Personal Privacy)</b> AT MAIN
Employees on Job GF BS - TC	
Vehicles or Equip. Used 11 14 BACKHOE	

Sewer Department

Address	BY PASSED 71ST - RAN Blowers BY PASSED <b>Ex. 7f (Water Infra.)</b>
Job Completed	TURNED OFF PUMP #2 AT <b>Ex. 7f (Water Infra.)</b> NOT PUMPING
Employees on Job KM BS TC	Checked STATIONS
Vehicles or Equip. Used 15 14	

## Meter Readers

## Employees on Job

## Areas - Read

## Vehicles Used

## General Foreman

Date 7-26-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address		JETTED MAIN LINE & COST. LATERAL AT <b>Ex. 7f (Water Infra.)</b> DIDN'T GET THROUGH TALKED WITH COST. THINK IT'S COST PROB.
Job Completed		DUG OFF LID OF WELL, PUMPED DOWN WELL & VACUMED OUT DEBRIS - INSTALLED EDUCTOR BUT CAP IS TOO TALL TO LET
Employees on Job F.P. - B.S. - T.C. - K.M.		LID BACK ON WELL - NEEDED DIFFERENT TEE ON EDUCTOR. RE-SET ELECTRIC BY-PASS PUMP & PUT LID BACK ON PUMPING NOW
Vehicles or Equip. Used 7-9-14-15-BACKHOE		WITH ELECTRIC BY-PASS PUMP AT <u>BECKVIEW</u> CYCLED OAKLAND & CROCKETTS
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Ponce</u>		

Date 7-27-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A	
Employees on Job B.S. - F.P. - T.C. 4 HR	MOVED FLOATBALLS TO CENTER OF WELL BEHIND <b>Ex. 7f (Water Infra.)</b>	
Vehicles or Equip. Used 14 - 15	LOWERED FLOAT BALLS AT BELLEVUE	
<b>Meter Readers</b>		
Employees on Job F.P. - T.C. 4 HR	FINISHED CYCLE 2 RADIO READ METERS	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pore</u>		



Date 1-25-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O, LOCATES
Jobs Completed	
Employees on Job F.P. - B.S. - T.C. C.G.F. 2 HR 2 HR 6 HR	
Vehicles or Equip. Used 8-11-14	

Sewer Department

Address	CHECKED STATIONS
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> FILL BOX
Employees on Job K.M. - T.C. - B.S. 6 HR 4 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b>
Vehicles or Equip. Used 15-14	NEED TO JET LINE TO RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b>

Meter Readers

Employees on Job T.C. - K.A. - F.P. - B.S. - G.F. 2 HR	TRAINING FOR RADIO READ METERS
Areas - Read F.P. 4 HR	'FINISHED 29 R.R. - F.P. & BOB
Vehicles Used	

General Foreman

Frank J. Pace

Date 7-24-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATIONS	
Jobs Completed	REPAIRED SERVICE LEAK AT Ex. 6 (Personal Privacy) USED ONE 3/4" x 3/4" COMP., ONE 3/4" x 1/2" COMP., ONE METER SHUT OFF, ONE METER COUPLING,	
Employees on Job G.P. - F.P. - B.S. - T.C. 6 HR 5 HR	ONE 18" x 30" P.I.C., METER BOX, 10' OF 3/4" COPPER TUBING - INSTALLED RADIO READ METER, BACKFILLED WITH CLEAN ROCK & C-M-G ROCK FROM SHOP - HAULED OFF SOIL	
Vehicles or Equip. Used	11-14-6 - BACKHOLE	
<b>Sewer Department</b>		
Address	REPAIRED DISCHARGE LINE AT SNOWS CHECKED PUMPS IN PARKFIELD & BEHIND Ex. 7f (Water Infra.) ALL GOOD	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)	
Employees on Job F.P. - B.S. K.M. 2 HR 3 HR		
Vehicles or Equip. Used	14 - 15	
<b>Meter Readers</b>		
Employees on Job T.C. & K.M. 5 HR	FINISHED AREA 29	
Areas - Read		
Vehicles Used	8	
General Foreman	Frank J. Pace	

Date 7-24-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	2 HOUR CALL OUT - O.T.
Jobs Completed	CHECKED FOR LEAK AT ST. BONIFACE - DID NOT FIND ANY LEAK - TALKED TO CUSTOMER WHO
Employees on Job F.P.	SAID FRONT YARD WAS FLOODED EARLIER - CHECKED METER BUT NOT SPINNING & BOX WAS DRY
Vehicles or Equip. Used 14	

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Ex. 6 (Personal Privacy)



Date 7-23-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	BY-PASS PUMPED 71ST ST & 82ND ST CYCLED STATIONS <b>Ex. 6 (Personal Privacy)</b> OAKLAND & CROCKETTS

Sewer DepartmentAddress

FRANK PACE CALLED VILLAGE  
of CAHOQUIA TO JCT LINE  
None of local 100 Employees had CDL license on 7-23-18

JETTED MAIN LINE TO RELIEVE  
BACKUP ON **Ex. 6 (Personal Privacy)** CALLED IN

Job Completed

PULLED PUMP AT LAURALEE **Ex. 7f (Water Infra.)**  
FOUND WIRE AT STATION BURNED -  
RE-WIRED PUMP - PUMPING NOW.

Employees on Job

K.M., F.P. - B.S.,  
4 HR

FLOAT BALLS BEHIND **Ex. 7f (Water Infra.)**  
HUNG UP - MOVED BALLS & PUMPING  
NOW

Vehicles or Equip. Used

14

DISCHARGE LINE AT SNOWS WAS HIT  
BY CAR & NERAS REPAIRED -  
PUMP OFF

Meter ReadersEmployees on Job

F.P. - B.S.,  
4 HR

FINISHED 1 &amp; 2

Areas - ReadVehicles Used

14

General Foreman

Frank J. Pace

Date 7-20-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	HEAVIER TRUCK W.O. REMOVES & RE-ROADS	
Jobs Completed		
Employees on Job F.P.-B.S. 6HR		
Vehicles or Equip. Used 14-11		
<u>Sewer Department</u>		
Address	CHECKED STATIONS ON SOUTH END	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILE BOX	
Employees on Job F.P.-B.S. 2HR	K.M. 4HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b>
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job T.C.	FINISHED 22 & 26	
Areas - Read		
Vehicles Used 8		
General Foreman	Franky. Pace	

Date

7-19-18

Daily Job Sheet

Sheet 1 of 1

Water Department

## Comments

Address

Service TRUCK WOODS

Jobs Completed

Employees on Job

BS  
Km

Vehicles or Equip. Used

11  
15Sewer Department

Address

BY PASSED 82ND ST

Job Completed

Employees on Job

Km

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

BS-GF  
TC

Areas - Read

19  
23-24

STARTED 26

Vehicles Used

14- 11

General Foreman

B. Smith



Date 7-18-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	CRIMPED OFF SERVICE LINES IN BOXES & REPLACED SHUT OFFS AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	<b>Ex. 6 (Personal Privacy)</b>	
F.P. - B.S. - G.F.	PICKED OUT COLD PATCH, REPLACED BROKEN METER, RING, & LID. FILLED IN AROUND RING WITH SAME COLD PATCH / EASY STREET	
Vehicles or Equip. Used	AT <b>Ex. 6 (Personal Privacy)</b>	
11-14		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS METER AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWER AT <b>Ex. 7f (Water Infra.)</b>	
Employees on Job	CHECKED <b>Ex. 7f (Water Infra.)</b> FRONT- ALL GOOD	
K.M.		
Vehicles or Equip. Used		
15		
<b>Meter Readers</b>		
Employees on Job	FINISHED 18 & 21	
T.C.		
Areas - Read	STARTED 02	
Vehicles Used	8	
General Foreman	Frank J. Pace	

Date 7-17-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES
Jobs Completed	REPAIRED DRIVEWAY WHERE LEAK WAS REPAIRED WITH ONE BUCKET OF C-M-G ROCK AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job F.P.-B.S. G.F. 2 HR	
Vehicles or Equip. Used 14- 11-BACKHOE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> 3RD. - CYCLED BLOWERS AT OAKLAND + CROCKETS
Job Completed	PULLED PUMP AT BELLVIEW DUE TO DISCHARGE LINE BACKING OUT OF DISCHARGE LINE - CRANED PUMP + RE-INSERTED DISCHARGE TIED OFF DISCHARGE + PUMPING NOW
Employees on Job F.P.-B.S. - K.M. 6 HR 4 HR	TURNED ON BLUFF AT END OF SHIFT INSTALLED BELT ON PUMP #1 AT <b>Ex. 7f (Water Infra.)</b> STATION FRONT
Vehicles or Equip. Used 14-15	VIOLET STATION WAS KICKED OUT - RESET STARTER - NEED TO CHECK TOMORROW

Meter Readers

Employees on Job T.C.	FINISHED 17
Areas - Read	STARTED 18
Vehicles Used 8	

General Foreman Frank J. Pace



Date 7-16-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	LOCATED SERVICE ON EMPTY LOT ON DORA FOR BORING CREW - TALKED TO CREW ON SITE	
Employees on Job F.P. GMR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - BELTS OFF OF PUMPS AT <b>Ex. 7f (Water Infra.)</b> RUNNING ON #2 NOW	
Job Completed	BELLEVUE KICKED OUT - RESET STARTER PUMPING NOW	
Employees on Job G.F. - F.P. GMR	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, CALVIN BLVD.	
Vehicles or Equip. Used 11-15	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 13	
Areas - Read	STARTED 17	
Vehicles Used 8		
General Foreman <u>Frank J. Rice</u>		



Date 7-13-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		<u>Comments</u>	
Address		SERVICE TRUCK W.O.	
Jobs Completed			
Employees on Job G.F. 7HR			
Vehicles or Equip. Used 11			
<u>Sewer Department</u>			
Address		BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed		CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job K.M. - E.P. - Conf. 4HR 1HR		PULLED BACK OFF PUMP & CLEANED OUT RAGS/MOP AT BRIDGE DALE	
Vehicles or Equip. Used 11-14-15			
<u>Meter Readers</u>			
Employees on Job F.P. - T.C. 7HR		FINISHED 11+12 - F.P. 15 - T.C.	
Areas - Read		STARTED 13 - F.P. 17 - T.C.	
Vehicles Used 8-14			
General Foreman <u>Frank J. Pace</u>			

Date 7-12-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	LOCATES
Employees on Job F.P. - G.F. - T.C. 6HR 2HR	CLEANED UP DEBRIS & SPOIL WHERE MAIN BREAK WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 11-14	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD.
Job Completed	PULLED BACK OFF OF PUMP #1 - ALL CLEAN - CHECKED AMPS 10-13 - PUMPING CYCLING & ALTERNATING NOW - <b>Ex. 7f (Water Infra.)</b>
Employees on Job F.P. - T.C. K.M. 2HR 4HR	FRONT
Vehicles or Equip. Used 14-15	

Meter Readers

Employees on Job T.C. - K.M. 4HR	FINISHED 14-K.M.
Areas - Read	STARTED 15-K.M. 11-T.C.
Vehicles Used 8-15	

General Foreman Frank J. Pace

Date 7-11-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	REBUILT SERVICE & PULLED NEW COPPER LINE UNDER ROAD AT <b>Ex. 6 (Personal Privacy)</b> USED 45' OF 3/4" COPPER TUBING, ONE 3/4" FLARE & COMP.	
Employees on Job C.F. <u>F.P. - T.C.</u> 6 HR	FITTING, ONE 3/4" x 3/4" COMP. FITTING, ONE METER SHUT OFF, ONE METER COUPLING, INSTALLED NEW R.R. METER, RE-USED CLAY BOX, RING & LID	
Vehicles or Equip. Used 11-14-BACKHOLE	BACKFILLED WITH SPOIL	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job <u>F.P. - T.C.</u> K.M. 8 HR	JETTED LINE IN <b>Ex. 6 (Personal Privacy)</b> BATHS TO RELIEVE BACKUP	
Vehicles or Equip. Used 9-14-15	WORKED WITH CENTREVILLE TO JET LINES BUT ALL M.H. WERE FULL DUE TO WET WALL AT STATION WAS FULL - 2 MEN + UNIT 91MR	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 7-10-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		PULLED NEW COPPER LINE UNDER ROAD FOR <b>Ex. 6 (Personal Privacy)</b> 40' OF $\frac{3}{4}$ " COPPER TUBING, ONE $\frac{3}{4}$ " FLAREX COMP., ONE $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP.
Employees on Job F.P. - K.M. 7 HR G.F. 4 HR		BACK FILLED WITH SPOIL
Vehicles or Equip. Used 11-14 - Backhoe		
<b>Sewer Department</b>		
Address		RE-SRT STARTER #2 AT FRONT - PUMPING NOW - <b>Ex. 7f (Water Infra.)</b>
Job Completed		CHECKED SOME STATIONS ON SOUTH END
Employees on Job F.P. - K.M. 1 HR		
Vehicles or Equip. Used 14		
<b>Meter Readers</b>		
Employees on Job T.C. - G.F. 4 HR		FINISHED 6 - G.F. 9 - T.C.
Areas - Read		
Vehicles Used 11-8		
General Foreman <u>Frank J. Pace</u>		

Date 7-9-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED 4" C.I. MAIN BREAK AT <b>Ex. 6 (Personal Privacy)</b> - USED ONE 16"X4" C.I. S.S. REPAIR CLAMP - 3 BUCKETS OF	
Employees on Job F.P. - G.F. - K.M. 2MRC	CLEAN ROCK FROM SHOP & TWO BUCKETS OF C.M.-G ROCK - NEEDED TO CLEAN UP DEBRIS & DRIVE	
Vehicles or Equip. Used  11-14-15- BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILEY BOX G.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job K.M. 6MRC		
Vehicles or Equip. Used  15		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 5	
Areas - Read	STARTED 6	
Vehicles Used 8		
General Foreman <u>Franky. Pace</u>		

Date 7-6-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O., LOCATES	
Jobs Completed		
Employees on Job F.P. - K.M. 2 HR		
Vehicles or Equip. Used 14-11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job F.P. - K.M. GHR GHR	PULLED PUMP AT 75TH <b>Ex. 7f (Water Infra.)</b> CLEANED RAGS & SECURED DISCHARGE LINE	
Vehicles or Equip. Used 14-15- BACKHOC	CHECKED STATIONS - ALL GOOD	
<u>Meter Readers</u>		
Employees on Job G.F. - T.C. 4 HR	FINISHED 8-G.F. 4-T.C.	
Areas - Read	STARTED 5-T.C.	
Vehicles Used 8-11		
General Foreman <u>Franky Pace</u>		



Date 7-5-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed		
Employees on Job F.P. - G.F. 4HR 2HR		
Vehicles or Equip. Used 11-14		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX, 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job K.M. - F.P. 4HR	CHECKED STATIONS - ALL GOOD	
Vehicles or Equip. Used 14-15	LOCATES	
<b>Meter Readers</b>		
Employees on Job T.C. - G.F. 6HR	FINISHED 7-10 G.F. 3-T.C.	
Areas - Read	STARTED 8-G.F. 4-T.C.	
Vehicles Used 8-11		
General Foreman <u>Franky. Pace</u>		

Date 7-4-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky PaceH  
O  
L  
I  
D  
A  
Y4  
T  
HO  
FJ  
U  
L  
Y

Date 7-3-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	SHUT OFF CORP. STOP AT MAIN FOR <b>Ex. 6 (Personal Privacy)</b> WALK TO REBUILD SERVICE WHEN CUST. PAYS BILL.	
Employees on Job G.F. - <u>F.P. - T.C.</u> 2 HR		
Vehicles or Equip. Used 11-14-BACKHOLE		
<u>Sewer Department</u>		
Address	LOOKED FOR M.H. ON BO CLAIR TO CHECK BACKUP AT <b>Ex. 6 (Personal Privacy)</b> CUST. PROBLEM	
Job Completed	BY-PASS PUMPED WITH 2" GAS PUMP AT CALVIN BLVD, 63RD <b>Ex. 7f (Water Infra.)</b> 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job <u>F.P. - T.C.</u> - K.M. 1 HR	CYCLED BLOWERS AT OAKLAND & CROCKETT CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 14-15		
<u>Meter Readers</u>		
Employees on Job <u>F.P. - T.C.</u> 5 HR	FINISHED 29	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Franky Pace</u>		



Date 7-2-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	MOVED BLOWER FROM 1 TO 2 AT Ex. 7f (Water Infra.) CHANGED OIL - PUMPS GOOD CHECKED STATIONS - LIMB ON WIRE DROP AT SNOWS	
Job Completed	JETTED LINE FOR S.C. HOUSING AT Ex. 6 (Personal Privacy) PULLED BACK OFF PUMPS CLEANED RAGS OUT AT Ex. 7f (Water Infra.)	
Employees on Job F.P. - T.C. - K.M.	BY-PASS PUMPED WITH 39 GAS PUMP AT 71ST Ex. 7f (Water Infra.) MILL BOX, & 82ND ST.	
Vehicles or Equip. Used 9-14-15	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS A	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Date 8-31-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job T.C.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, 63RD <b>Ex. 7f (Water Infra.)</b> ALVIN BLVD.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b> CHECKED STATIONS - ALL GOOD	
Employees on Job K.M. - F.P. - B.S. 4 HR	PULLED BACK OFF PUMP #1 & CLEANED OUT RAGS AT <b>Ex. 7f (Water Infra.)</b> - PUMPING CYCLING NOW	
Vehicles or Equip. Used 14-15	CHANGED OIL IN BLOWERS AT BERCHLAND & AT 63RD <b>Ex. 7f (Water Infra.)</b>	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Date 9-3-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 8-30-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	DISCONNECTED SERVICE FROM MAIN AT <b>Ex. 6 (Personal Privacy)</b> REMOVED BOX BACKFILLED WITH SPOIL	
Employees on Job F.P. - B.S. - K.M. - T.C.		
Vehicles or Equip. Used 11-14-15 - BACKHOC		
<u>Sewer Department</u>		
Address	PULLED BACK OFF PUMP #1 & CLEANED OUT MOPHEAD - PUMP CYCLED ONCE BUT STARTER WAS KICKED OUT LATE-	
Job Completed	RUNNING PUMP #2 NOW AT <b>Ex. 7f (Water Infra.)</b> STATION-FRONT	
Employees on Job F.P. - B.S. - K.M. 3 HRS	COULDN'T WORK ON BELLEVUE AVE TO HIGH WATER LEVEL IN WET WELL	
Vehicles or Equip. Used 14-7 - BACKHOC		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Franky Pace	

Date 8-29-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. CLEANED OUT UNIT 14	
Jobs Completed	INSTALLED ANTENNAS AT <b>Ex. 6 (Personal Privacy)</b> <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S. - T.C. 4 HR		
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - PUMP #1 PICKED UP RABS WE THINK - IT WAS KICKED OUT AT END OF DAY - PUMPING WITH #2 PUMP AT <b>Ex. 7f (Water Infra.)</b> NEED TO PULL BACK	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job F.P. - B.S. K.M. 4 HR 6 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A	
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 8-28-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	EXPOSED MAIN FOR CONTRACTOR AT <b>Ex. 6 (Personal Privacy)</b> 10" A.C. MAIN - O.D. 12.00 - DEPTH 54"	
Employees on Job F.P. - B.S. - T.C. - K.M.	REBUILT SERVICE & CHANGED METER TO R.R. USED ONE 3/4" FLARE X COMP., TWO 3/4" X 3/4" COMP. FITTINGS, 12' OF 3/4" P.V.C. TUBING, 6' OF 3/4" COPPER TUBING, ONE METER COUPLING,	
Vehicles or Equip. Used 11-14-15- BACKHOE	ONE METER SHUT OFF, ONE 8" X 30" METER BOX, BACKFILLED WITH SPOIL	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	



Date 8-27-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job B.S. - T.C. 6 HR 2 HR		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - ALL GOOD LOCATES	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST. <b>Ex. 7f (Water Infra.)</b> PILL BOX, 82ND	
Employees on Job K.M. F.P. - T.C. 4 HR 2 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A	
Vehicles or Equip. Used 7-14-11	PULLED BACK OFF OF PUMP #2 AND CLEANED OUT RAGS/MOP - CYCLING & ALTERNATING BOTH PUMPS NOW	
Meter Readers		
Employees on Job F.P. T.C. 4 HR 4 HR	FINISHED 2 & 29 MANUALS - T.C. CYCLE 2 RANIOS - F.P.	
Areas - Read		
Vehicles Used 11-14		
General Foreman	<u>Frank J. Pace</u>	

Date 8-26-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

2 HR CALL OUT  
D.T.

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

CALL OUT - SUPERIOR PUMP #2  
STARTER KICKED OUT - RESET STARTER  
& PUMP KICKED OUT AGAIN AFTER.

Job Completed

RUNNING 10-15 MINUTES - TURNED  
ALTERNATOR TO PUMP #1 & CHECKED  
CYCLES - PUMPING & CYCLING ON PUMP NOW

Employees on Job

F.P.

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 8-24-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A
Employees on Job K.M.	CHECKED STATIONS - BLUFF OFF DUE TO SURCHARGING ON 82ND
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job F.P.-B.S. 4 HR	FINISHED 29 - EXCEPT FOR F.O.W.
Areas - Read	
Vehicles Used 14	

General Foreman Franky. Ace



Sheet of

### Comments

LOOKED FOR VAULTS AT

REMOVES METER, INSTALLED PLUG IN SHOT  
OFFSIDE OF SET & INSTALLED SPREADER  
BETWEEN FRONT & BACKSIDE

OILED & CLEANED TAP MACHINE FOR 1 1/2" TAP

G.R. - F.P. - B.S.

Vehicles or Equip. Used	
-------------------------	--

11-14

## Sewer Department

BY-PASS PUMPED WITH 3" GAS PUMP AT  
CALVIN BLVD, 63RD **Ex. 7f (Water Infra.)** 72ND ST.

Ex. 7f (Water Infra.) 7208 ST

INSTALLED BELT AT PERSHING

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**  
 OUR LINKS DOWN COST. PROBLEM

K.M. F.P-B.S.  
2000

Vehicles or Equip. Used

7-14

## Meter Readers

FINISHED

2691

STARTED

22

### Vehicles Used

8

## General Foreman

Date 8-22-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>	<u>Comments</u>
Address	SERVICE TRUCK W.O.
Jobs Completed	FILLED IN YARD WITH DIRT & STREET WITH C-M-Q ROCK AT <b>Ex. 6 (Personal Privacy)</b> RAKED & SEEDS DIRT AROUND BOX
Employees on Job (F.P.-B.S.) G.F. S.M.R.	FILLED IN YARD WITH DIRT AROUND HYDRANT AT <b>Ex. 6 (Personal Privacy)</b> RAKED & GRADED & SEEDS YARD AROUND HYDRANT
Vehicles or Equip. Used 11-14- BACKHOLE	CUT BUSHES & WEEDS AROUND HYDRANT AT <b>Ex. 6 (Personal Privacy)</b>

<u>Sewer Department</u>	
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, 82ND ST.
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT
Employees on Job K.M.	
Vehicles or Equip. Used 15	

Meter Readers	
Employees on Job (F.P.-B.S.) T.C. S.M.R.	FINISHED 19-F.P. & B.S. 24-T.C.
Areas - Read	STARTED 26-T.C.
Vehicles Used 8-	

General Foreman	<u>Frank J. Pace</u>
-----------------	----------------------

Date 8-21-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	<p>80' OF EACH ROLL</p> <p>PULLED TWO 3/4" P.V.C. LINES UNDER ROAD FOR <b>Ex. 6 (Personal Privacy)</b> - USED TWO 3/4" FLARE X COMP. FITTINGS, ONE 3/4" P.V.C. BARBX COMP. FITTING, ONE 3/4" METER SET, ONE 18" X 30" P.V.C. METER BOX, BACKFILLED SPOIL</p>
Employees on Job F.P. - B.S. - K.M.	
Vehicles or Equip. Used 14-15- BACKHOE	<p>HOOKED UP NEW LINE AT <b>Ex. 6 (Personal Privacy)</b></p> <p>USED ONE 3/4" COMP. X 1/2" COMP FITTING - RAISED BOX WITH 4" CLAY RISER CUT AT SHOP. INSTALLED NEW R.R. METER WITH LIA FROM SHOP</p>

Sewer Department

Address	VIOLET ON & CYCLING ON AUTO
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job T.C.	FINISHED 22 MANUALS
Areas - Read	STARTED 24 MANUALS
Vehicles Used 8	
General Foreman <u>Franky Pace</u>	



Date 8-20-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - ALL GOOD PULLED BOTH PUMPS & CLEANED OUT RAGS AT <b>Ex. 7f (Water Infra.)</b> TO SECURE RAILS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> FILL BOX 80ND ST.	
Employees on Job F.P. - B.S. - K.M.	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A	
Vehicles or Equip. Used 7-14-15		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED AREA 20 & 21	
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 8-17-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		CHECKED STATIONS N.E.D TO PULL PUMP AT VIOLET & CLAN - KICKING OUT STARTER
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
Employees on Job F.P. - T.C. 4HR		CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT
Vehicles or Equip. Used 14-15		
<u>Meter Readers</u>		
Employees on Job F.P. 4HR		FINISHED CYCL 5 RADIO READS - AREA 23
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 8-16-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	EXPOSED MAIN, S.S. REPAIR CLAMP VALVE TO CHECK FOR LEAK AT <b>Ex. 6 (Personal Privacy)</b> & LEAK - INSTALLED 38" PIECE OF S&K 21" LINCOLN HAT FOR VALVE BOX	
Employees on Job	G.F. - J.C. - F.P. - B.S. 4 HR 4 HR	
Vehicles or Equip. Used	11-14 - BACKHOLE - 8	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWER	
Employees on Job	K.M. - F.P. - B.S. 4 HR	
Vehicles or Equip. Used	BELLVIEW WELL UP - PUMP IS PUMPING BLUFF OFF 14-15	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Franky Pace</u>	



Date 8-15-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
	CLEANED UP SHOP/ TRUCKS	
Jobs Completed	PUT HOSE ON UNIT #9	
	WIRED MOTORS + INSTALLED PULLEYS	
Employees on Job F.P. - B.S. - G.F. - T.C. G.W.	RE-READS	
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX CALVIN BLVD.	
Job Completed	TURNED ON BLUFF	
Employees on Job K.M.	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job F.P.	FINISHED CYCLE 4 RADIO READS	
Areas - Read		
Vehicles Used 14		
General Foreman	Frank J. Pace	

Date 8-14-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	VACUMED OUT WELL, BALLED OFF LINES, INSTALLED EDUCTOR AT BELLVIEW - STILL USING BY-PASS PUMP
Job Completed	RETRIEVED HOSE & JET NOZZLE FROM LINE AT <b>Ex. 6 (Personal Privacy)</b> STATION
Employees on Job F.P. - B.S. - T.C. - K.M.	
Vehicles or Equip. Used 7-9-14-15 BACKHOLE	

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Franky. Pace

Date 8-13-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	DATA LOGGED METER AT FALLING SPRINGS RD. Ex. 6 (Personal Privacy)	
Employees on Job G.P. F.P. - B.S. DHR		
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX, 63RD Ex. 7f (Water Infra.) ALVIN BLVD.	
Job Completed	CYCLED PUMP AT CYCLER BLOWERS A Ex. 7f (Water Infra.)	
Employees on Job K.M. - F.P. - B.S.	CHECKED STATIONS - VIOLET STARTERS KICKED OUT - MAY NEED TO PULL PUMP #1 & CLEAN	
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job T.C.	FINISHED 18	
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 8-10-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	SHUT OFF CORP. STOP AT MAIN FOR Ex. 6 (Personal Privacy) EMPTY) TO STOP LEAK IN STREET	
Employees on Job G.P. - F.P. - B.S. 4 HR	TAPED OFF HOLE AT SRT UP BARRICADES Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 11-14 - BACKHOE		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - ALL GOOD BUT VIOLE. Ex. 7f (Water Infra.) VIRKS TO PUMP BURNED - RE-WIRED PUMP - PUMPING NOW	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 715. Ex. 7f (Water Infra.) PILL BOX, 82ND ST.	
Employees on Job F.P. - B.S., K.M., 4 HR 6 HR	CYCLED BLOWERS AT OAKLAND + CROCKETTS CYCLED PUMP AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 14-15		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 17	
Areas - Read	STARTED 18	
Vehicles Used 7		
General Foreman <u>Franky. Pace</u>		

Date 8-9-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

SERVICE TRUCK W/O.  
 DATA LOGGED METERS AT **Ex. 6 (Personal Privacy)**  
**Ex. 6 (Personal Privacy)**

Jobs Completed

EXPOSED MAIN, TWO TAPS, LINES GOING  
 INTO BOXES TO PREP FOR TWO PULCS AT  
**Ex. 6 (Personal Privacy)** MAKE PULL TOMORROW

Employees on Job

G.F. - F.P. - B.S. - K.M.

Vehicles or Equip. Used

14-15 - BACKHOLE

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHES MANUAL  
 13-14 & 15 - T.C.

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Price

Date 8-8-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O, LOCATES	
Jobs Completed		
Employees on Job G.F. F.P. 2HR		
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	VACUMED OUT M.H. AT AMES BLOCK BETWEEN M.H. <span style="color: red;">Ex. 6 (Personal Privacy)</span>	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT AMES. <span style="color: red;">Ex. 7f (Water Infra.)</span> PILL BOX	
Employees on Job B.S. - T.C. - K.M. 4HR	CYCLED PUMP AT CYCLED BLOWERS <span style="color: red;">Ex. 7f (Water Infra.)</span>	
Vehicles or Equip. Used 9-15		
<u>Meter Readers</u>		
Employees on Job K.M. F.P. - T.C. 4HR 6HR 4HR	STARTED 15 - T.C. 13 - K.M. & F.P.	
Areas - Read	FINISHED CYCLE 3 RADIO READS 12 - K.M. F.P.	
Vehicles Used 8-14		
General Foreman <u>Frank J. Pace</u>		



Date 8-7-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job <u>G.F. - K.M.</u> 2 HR		
Vehicles or Equip. Used <u>11-8</u>		
<u>Sewer Department</u>		
Address	CHANGED OIL & GREASED BLOWER, WIRED IN MOTOR & CONNECTED AIR LINE AT PERSHING - PUMPING NOW	
Job Completed	VACUMED OUT M.H. AT AMES STILL HAVE BLOCK IN LINE - NEED TO BY-PASS PUMP DOWN SYSTEM	
Employees on Job <u>F.P. - B.S. - T.C.</u>	CYCLED PUMP AT CYCLED BLOWERS	
Vehicles or Equip. Used <u>7-9-14</u>		
Meter Readers		
Employees on Job <u>G.F. - K.M.</u> G.F.R.	FINISHED <u>9-G.F. - 11-K.M.</u>	
Areas - Read		
Vehicles Used <u>8-11</u>		
General Foreman	<u>Frank J. Pace</u>	

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Date 8-6-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.D.	
Jobs Completed		
Employees on Job	G.F. 1.5 HR	
Vehicles or Equip. Used	11	
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job	K.M. - F.P. - B.S. REMOVED BLOWER & MOTOR FROM PERSHING + INSTALLED MOTOR #2 ON BLOWER #1 - NEED TO CHANGE OIL IN BLOWER	
Vehicles or Equip. Used	14-15 CHECKED STATIONS - ALL GOOD BUT PERSHING - FOUND HOLE AROUND M.H. AT ELM <b>Ex. 7f (Water Infra.)</b>	
Meter Readers		
Employees on Job	FINISHED G.F. T.C. 6.5 HR 8-G.F. 5-T.C.	
Areas - Read	STARTED 9-G.F.	
Vehicles Used	8-11	
General Foreman	Frank J. Pace	

Date 8-3-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job B.S. - G.F. 2 HR 2 HR	
Vehicles or Equip. Used 11	

Sewer Department

Address	PULLED PUMP BEHIND <b>Ex. 6 (Personal Privacy)</b> CLEANED OUT RAGS - PUMPING NOW.
Job Completed	BY-PASS PUMPER WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> - EDNA 82ND ST.
Employees on Job F.P. - B.S. - K.M. 2 HR	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b>
Vehicles or Equip. Used 14 - BACKHOC	

Meter Readers

Employees on Job F.P. G.F. 2 HR	FINISHED 7-F.P. 10-G.F. 4-F.P. & G.F.
Areas - Read	STARTED 8-F.P.
Vehicles Used 8-14	DIPPED OUT BOXES & READ METERS IN AREA 6 - F.P.

General Foreman Frank J. Pace



Date 8-2-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. <u>LOCATES</u>	
Jobs Completed		
Employees on Job C.F. <u>F.P.-B.S.</u> 2 HR		
Vehicles or Equip. Used 11- 14		
<u>Sewer Department</u>		
Address	DUG OFF LID, BALLED OFF LINES & TRIED TO INSTALL EDUCATOR AT BELLEVUE - NEED DIFFERENT TOP/CAP ON EDUCATOR	
Job Completed	TURNED BLUFF ON - NEED TO PULL PUMP BEHIND <b>Ex. 6 (Personal Privacy)</b> RUNNING BUT NOT PUMPING.	
Employees on Job <u>F.P.-B.S.-T.C.-K.M.</u> 6 HR 3 HR	<u>WIRED MOTOR FOR PUMP #1 AT 51ST</u>	
Vehicles or Equip. Used 7-9-14-15-BACKHOLE		
Meter Readers		
Employees on Job T.C.-K.M. 5 HR	FINISHED 6-K.M. 3-T.C.	
Areas - Read	STARTED 7-K.M.	
Vehicles Used 8-15		
General Foreman <u>Frank J. Pace</u>		

Date 8-1-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		DIPPED OUT WATER FROM CANS AT OAKLAND 73RD, BLUFF, BELLEVUE INSTALLED BELT PUMP 1 P.S. FRONT
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, CALVIN BLVD, PITTSBURG <b>Ex. 7f (Water Infra.)</b>
Employees on Job F.P. - B.S. - T.C. - K.M.		CYCLEPUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLEPUMP BLOWERS RAN BLUFF FOR 4 HRS. - OFF NOW
Vehicles or Equip. Used 8-14-15		CHANGED OIL, GREASED BLOWER & CHANGED HOSE AT BELLEVUE - BLOWER WORKS GOOD - CHECKED VOLT - GOOD
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 9-28-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	Truck 11 Work orders
Jobs Completed	
Employees on Job G.F - 8HR	
Vehicles or Equip. Used 11	


Sewer Department

Address	Pumped 71 <sup>st</sup> street, camera manhole Ex. 6 (Personal Privacy) put belt on @ Ames
Job Completed	Cycled Oakland + Crockett station is down
Employees on Job K.M - 8HR	
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job N/A	N/A
Areas - Read	
Vehicles Used	

General Foreman





Date 9-27-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department		Comments
Address	<u>Truck 3 W.O. (G.F.) (truck 11)</u>	
Jobs Completed		
Employees on Job G.F. - 6 HR		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address	Worked on station <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> on Ames; got station running	
Job Completed	Cycled Oakland & <del>60</del> 75 <sup>th</sup> stations	
Employees on Job G.F. - 2 hr L.M. - 4 hr		
Vehicles or Equip. Used 14, 15		
Meter Readers		
Employees on Job KM	Radio Readings	
Areas - Read		
Vehicles Used 15		
General Foreman <u>K.M.</u>		

Date 9-26-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

WORK orders

Jobs Completed

INSTALLED NEW 3/4" WATER  
SERVICE AT **Ex. 6 (Personal Privacy)**

Employees on Job

GF

BS-KM

REBUILT SERVICE AT

**Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

11

14 BACKHOE

Sewer Department

Address

BY PASSED PILL BOX AT 71ST

Job Completed

CYCLED BLOWERS AT 73rd

**Ex. 6 (Personal Privacy)**

RUNS -

Employees on Job

GF

BS-KM

BUT DOESN'T PUMP -

Vehicles or Equip. Used

15

14

PULLED RAGS FROM BRIDGEDALE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 9-25-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service TRUCK WORK orders
Jobs Completed	
Employees on Job GF BS-TC	BUSTED OUT concrete for Village
Vehicles or Equip. Used 11 BREAKER + 8	

Sewer Department

Address 76 LLEE 82 LLEE	INSTALLED New Pump + wired Pumped DOWN well
Job Completed 100 LLEE	Pulled Pump & ReATTACHED FLANGE TO Pump - BACK ON
Employees on Job Km TC BS PITTSBURGH	BY PASSED
Vehicles or Equip. Used 15 8 BACKHOE	CYCLED Blowers AT 73rd <b>Ex. 7f (Water Infra.)</b>

Meter ReadersEmployees on Job

TC	
Areas - Read FINISHED #	
Vehicles Used 8	

General Foreman

B. J. Smith



Date 9-24-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service TRUCK work orders
Jobs Completed	
Employees on Job GF BS	
Vehicles or Equip. Used 11 14	

Sewer Department

Address	BY PASSED 71ST - PIN BOX RAN <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> ycled BLOWERS AT 73RD
Job Completed	Pulled PUMP OUT OF well AT <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span>
Employees on Job Km BS-TC- GF	Checked PH 1 STATIONS
Vehicles or Equip. Used 15 14 8	


Meter Readers

Employees on Job GF TC	
Areas - Read 29 1 STARTED 2	
Vehicles Used 8	

General Foreman

B. Smith

Date 9-21-18 Daily Job Sheet Sheet 1 of 1

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed		
Employees on Job	GF BS	
Vehicles or Equip. Used	11 14	
<b>Sewer Department</b>		
Address		By PASSED 71st ST. RAW BLOWERS AT 73rd - OAKLAND <b>Ex. 7f (Water Infra.)</b>
Job Completed		STARTER AT BLUFF WON'T PULL IN. "REBUILT" PUMP AT 82
Employees on Job	KM BS	LLEE NOT WORKING -
Vehicles or Equip. Used	15 14	
<b>Meter Readers</b>		
Employees on Job	TC	
Areas - Read		FINISHED #26
Vehicles Used	8	
General Foreman		

Date 9-20-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

SERVIE TRUCK  
LOCATES

Jobs Completed

Employees on Job

GF  
BS

Vehicles or Equip. Used

11  
14Sewer Department

Address

PULLED #2 PUMP AT 53rd -  
REMOVED VOLUTE + CLEANED DEBRIS

Job Completed

RE INSTALLED - BACK ON

Employees on Job

BS  
Km  
GF

BY PASSED 71ST - CYCLED 73rd

**Ex. 7f (Water Infra.)** - HOLMES

Vehicles or Equip. Used

14  
7  
BACK HOE

Meter Readers

Employees on Job

GF  
TCFINISHED 22  
FINISHED 23 + 24  
+ STARTED 26

Areas - Read

Vehicles Used

11/8

General Foreman





Date 9-19-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service TRUCK work orders
Jobs Completed	
Employees on Job GF	
Vehicles or Equip. Used 11	

Sewer Department

Address	Pulled Pump AT <b>Ex. 7f (Water Infra.)</b> By PASSED <b>Ex. 7f (Water Infra.)</b> jet well
Job Completed	Removed 100 AMP BREAKER from BOX AT LAUREE <b>Ex. 7f (Water Infra.)</b> RAW BLOWERS AT 73' <b>Ex. 7f (Water Infra.)</b>
Employees on Job Km BS	
Vehicles or Equip. Used 15 14 BACKHOE	


Meter Readers

Employees on Job GF TC	
Areas - Read 19 STARTED 22	
Vehicles Used 8	
General Foreman B. Smith	

Date \_\_\_\_\_

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	Worked on work orders	
Jobs Completed		
Employees on Job		
GF		
Vehicles or Equip. Used		
11		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job	Installed pump on laurallee; cycled pumps on crockett *	
B.S. KM.		
Vehicles or Equip. Used		
15, backhoe, 14		
<u>Meter Readers</u>		
Employees on Job		
T.C		
Areas - Read		
20, 21 started 22		
Vehicles Used		
8		
General Foreman		

Date 9-17-18

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address		WORK orders LOCATES
Jobs Completed		
Employees on Job	GF BS	
Vehicles or Equip. Used	" 14	
<b>Sewer Department</b>		
Address	76 LEE	Pulled BY PASS OUT - Pump BURST UP
Job Completed		BY PASSED 71ST CYCLED BLOWERS AT 73rd RAN <b>Ex. 7f (Water Infra.)</b> PUMP
Employees on Job	KM BS-TC-	ALSO PITTSBURGH
Vehicles or Equip. Used	# 11 #8 BACKHOE 15	
Meter Readers		
Employees on Job	TC RS	
Areas - Read	STARTED 20 CYCLE 5 RADIA-	
Vehicles Used	8 14	
General Foreman	B. Smith	



Date 9-14-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATLS	
Jobs Completed		
Employees on Job C.F. F.P.-B.S. - T.C. 6HR 2HR 2HR		
Vehicles or Equip. Used 11-14		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 63RD Ex. 7f (Water Infra.) ALVIN BLVD.	
Job Completed	INSTALLED TARPS AT BERCHLAND & 63RD Ex. 7f (Water Infra.)	
Employees on Job F.P.-B.S. - K.M. 4HR	CHECKED STATIONS - E. ST. LOUIS STILL NOT TAKING AT 80NA & 73RD. NEED TO PULL PUMP BEHIND Ex. 7f (Water Infra.)	
Vehicles or Equip. Used	SPLIT IN DISCHARGE LINE NEEDS REPAIR STILL PUMPING & CYCLING. NEED TO PULL PUMP AT Ex. 7f (Water Infra.) KICKING ON & OFF	
<b>Meter Readers</b>		
Employees on Job B.S.-F.P. T.C. 2HR 4HR	FINISHED 1 CYCLE 4 18 RADIO READS	
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 9-13-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 8-11	

Sewer Department

Address	CHECKED STATIONS - HEADER BLOCKED ON PUMP #1 AT <b>Ex. 7f (Water Infra.)</b> FRONT - <b>Ex. 7f (Water Infra.)</b> OFF
Job Completed	51ST & 53RD ON & PUMPING
Employees on Job F.P. - B.S.	E. ST. LOUIS STILL NOT TAKING AT 73RD & 82ND - LAURA <b>Ex. 7f (Water Infra.)</b> ON & PUMPING
Vehicles or Equip. Used 14	PULLED BACK OFF PUMP #1 AT <b>Ex. 7f (Water Infra.)</b> STATION - NO RAGS - HEADER BLOCKED

Meter Readers

Employees on Job T.C. - K.M.	FINISHED 13 & 14 - K.M. 17 - T.C.
Areas - Read	STARTED 18 - T.C.
Vehicles Used 8-15	

General Foreman Frank J. Pace

Date 9-12-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job F.P. - G.F. 5 HR	
Vehicles or Equip. Used 7-8-14	

Sewer Department

Address	CHECKED STATIONS RAN SIST FOR 3 HR, RAN 53RD FOR 4 HR <b>Ex. 7f (Water Infra.)</b> OR 1 HR THEN SHUT OFF DUE TO SURCHARGE AT 54TH
Job Completed	EAST ST. LOUIS NOT TAKING AT 13RD OR 82ND
Employees on Job F.P. 3 HR	
Vehicles or Equip. Used 14	

Meter Readers

Employees on Job T.C. - K.M.	FINISHED 12-K.M. 15-T.C.
Areas - Read	STARTED 13-K.M. 17-T.C.
Vehicles Used 8-15	

General Foreman Frank J. Pace



Date 9-11-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED SERVICE LINE LEAK AT <div style="background-color: black; color: red; padding: 2px;">Ex. 6 (Personal Privacy)</div> 3RD ONE 3/4" FLARE X COMP. FITTING, ONE 3/4" X 3/4" COMP. FITTING, 6' OF	
Employees on Job F.P. - B.S. - T.C. - G.F. 3 HR 2 HR	3/4" COPPER TUBING, ONE TROCK LOAD CLEAN ROCK, TWO BUCKETS OF C-M-6 ROCK, DIRT FROM SHOP IN YARD,	
Vehicles or Equip. Used  7-14-6-BACKHOLE		
<b>Sewer Department</b>		
Address	WORKED WITH VILLAGE OF CAHOKIA ON FLORENCE SETTING LINES - 1 MAN & UNIT 9 2 HR	
Job Completed	CHECKED STATIONS - E. ST. LOUIS NOT TAKING BELLEVUE & BLUFF OFF - <div style="background-color: black; color: red; padding: 2px;">Ex. 6 (Personal Privacy)</div> 53RD OFF DUE TO SURCHARGE ON: 54TH	
Employees on Job T.C. - F.P. - B.S. 2 HR 3 HR	RAN 53RD & 51ST FOR 4 TO 5 HRS THEN SHUT OFF	
Vehicles or Equip. Used  9-14	THROTTLE CONTROL ON UNIT 9 DIDN'T WORK TODAY	
<b>Meter Readers</b>		
Employees on Job K.M. - T.C. 4 HR	FINISHED 11 T.C. & K.M.	
Areas - Read	STARTED 12 T.C.	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 9-10-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 7		
<b>Sewer Department</b>		
Address	DIPPED/PUMPED OUT SEWER STATION CANS AT BLUFF (OVER MOTORS) BELLEVIEW OAKLAND (1/2 WAY UP MOTORS), CROCKETTS, 63RD	
Job Completed	CHECKED STATIONS - BLUFF, BELLEVIEW, 51ST, <b>Ex. 6 (Personal Privacy)</b> FR. SNOWS IS PUMPING BUT FLOODED OVER WELL	
Employees on Job F.P. - B.S. - K.M. GAR	E. ST. LOUIS NOT TAKING AT 82ND OR 73RD - COULDN'T BY-PASS PUMP TODAY	
Vehicles or Equip. Used 14-15		
<b>Meter Readers</b>		
Employees on Job F.P. - B.S. T.C. GAR	FINISHED AREA 9 - T.C. CYCLE 3 RADIO READS F.P. B.S.	
Areas - Read		
Vehicles Used 8-14		
General Foreman <u>Frank J. Pace</u>		

Date 4-7-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F. 5 HR		
Vehicles or Equip. Used 7		
<u>Sewer Department</u>		
Address		CHECKED STATIONS
Job Completed		PULLED BACK OFF OF PUMP & CLEANED OUT RAGS AT BRIDGE DARE
Employees on Job F.P. - G.F. - K.M. 3 HR 4 HR		PULLED PUMP AT VIOLET CLEANED OUT RAGS, REPLACED LEAD INTO STARTER, TOOK PUMP TO 12-MO
Vehicles or Equip. Used 7-14-15-BACKHOE		
Meter Readers		
Employees on Job T.C.		FINISHED 5 & 8
Areas - Read		
Vehicles Used 8		
General Foreman	Frank J. Pace	

Ex. 7f (Water Infra.)



Date 9-6-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPLACED CRUSHED BOX AT <b>Ex. 6 (Personal Privacy)</b> USED ONE 18"X30" P.V.C. METER BOX	
Employees on Job G.F. - <u>F.P. - B.S.</u> 4 HR	REPLACED SHUT OFF & INSTALLED RE-SETTER AT <b>Ex. 6 (Personal Privacy)</b> USED ONE I.P. THREADED PLIER SHUT OFF & ONE RE-SETTER FROM SHOP	
Vehicles or Equip. Used  11-14-BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX 82ND ST.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS	
Employees on Job K.M. - <u>B.S. - F.P.</u> 4 HR	CLEANED TRANSDUCERS AT 53RD ST & <b>Ex. 7f (Water Infra.)</b>	
Vehicles or Equip. Used  14-15-BACKHOLE	CHECKED STATIONS	
<u>Meter Readers</u>		
Employees on Job	T.C.	FINISHED 4
Areas - Read		STARTED 5
Vehicles Used	8	
General Foreman <u>Frank J. Pock</u>		

Date 9-5-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. <hr/> LOCATES	
Jobs Completed	CONNECTED SERVICE LINE AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> USED 8' OF 3/4" COPPER TUBING, ONE METER SHUT OFF, ONE 3/4" X 3/4" COMP. FITTING & INSTALLED RADIO READ METER	
Employees on Job G.F. - F.P. - B.S.	CONNECTED NEW SERVICE LINE AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> GOLDEN - USED ONE 3/4" X 3/4" COMP. FITTING & INSTALLED RADIO READ METER	
Vehicles or Equip. Used 14 - 11 - BACKHOLE		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job T.C. - K.M.	FINISHED 7-K.M. 3-T.C.	
Areas - Read	STARTED 8-K.M. 4-T.C.	
Vehicles Used 8-15		
General Foreman	Frank J. Pace	

Date

9-4-18

Daily Job Sheet

Sheet

of

1

Water DepartmentComments

Address

WORK orders + LOCATES

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

Sewer Department

Address

Job Completed

By PASSED 71ST - RAN  
+ 73rd Blowers - Pittsburgh +  
TURNED ON BLUFF

Ex. 6 (Personal Privacy)

Employees on Job

KM  
BS

Vehicles or Equip. Used

7-11

CHECKED STATIONS

Meter Readers

Employees on Job

TC  
GF

Areas - Read

6 - STARTED 7  
10 - STARTED 3

Vehicles Used

8  
15

General Foreman

B. Smith



Date 10-31-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. REMOVED METERS RE-READS	
Jobs Completed		
Employees on Job C.F. - T.C.		
Vehicles or Equip. Used 8-11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> WELL BOX, 75TH & <b>Ex. 7f (Water Infra.)</b> ALVIN BLVD.	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT BLUFF	
Employees on Job F.P. - B.S. - K.M	CHECKED STATIONS - CLEANED FLOAT BALLS AT <b>Ex. 7f (Water Infra.)</b> ERSHING, PUT BUCKET OVER ELECTRIC RECEPTACLE IN FIELD FROM RENNOIS ADJUSTED FERNCO AT SNOWS DISCHARGE	
Vehicles or Equip. Used 14-15	CLEANED OUT SUMP AT BRIDGE DALE	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 10-30-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	DISCONNECTED SERVICES TO UPPER CAHOKIA RD. - CUT P.V.C. SERVICE LINES TO HOUSES ON OUTSIDE OF BOX ON THE HOUSE SIDE OF BOX
Employees on Job F.P. - B.S. - C.F. - T.C. 2 hrs	
Vehicles or Equip. Used 14-11-8	

Sewer Department

Address	CHECKED FOR BACKUP AT COST. PROBLEM - NO ONE ANSWERED DOOR CHECKED STATIONS
Job Completed	WORKED ON Ex. 6 (Personal Privacy) CHECKED AMPS & VOLTS ON PUMP, BREAKERS & STARTER - ALL O.K. - STARTER WENT PULL IN - BY-PASSED STARTER & PUMPED DOWN SYSTEM OFF BY BREAKER
Employees on Job F.P. - B.S. - K.M. 6 hrs 4 hrs	BY-PASS PUMPS WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) 2ND ST.
Vehicles or Equip. Used	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS BLUFF

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 10-29-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service Truck work orders LOCATES
Jobs Completed	Removed 2" meter from I.C.S.
Employees on Job GF BS-TC	filled IN shoulder with ROCK ON MC. AVE
Vehicles or Equip. Used 11 14- Dump BACK HOE	

Sewer Department

Address	checked PH. 2 STATIONS TURNER ON BLUFF FOR 1 HR.
Job Completed	By PASSED 71ST - PITTSBURGH RAN BLOWERS AT 73rd
Employees on Job	HOLMES STARTER IS KICKING OUT NOT ABLE TO RUN TODAY
Vehicles or Equip. Used 15 14	

Ex. 7f (Water Infra.)

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman

B. Linn



Date 10-26-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. RA-READS LOCATES	
Jobs Completed		
Employees on Job		
G.F. - F.P. - T.C. 2 HR		
Vehicles or Equip. Used		
11-14-8		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX 75TH <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS <b>Ex. 7f (Water Infra.)</b> BLUFF <b>Ex. 7f (Water Infra.)</b>	
Employees on Job		
K.M.		
Vehicles or Equip. Used		
15		
Meter Readers		
Employees on Job	F.P. - T.C. FINISHED 29 CYCLE 2 RADIO READS	
Areas - Read		
Vehicles Used	8-14	
General Foreman	Franky Ace	

Date 10-24-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	MADE PUSH UNDER ROAD AT USED 20' OF 3/4" COPPER, ONE 3/4" FLARE X COMP TWO 3/4" X 3/4" COMP, ONE METER COUPLING, ONE Ex. 6 (Personal Privacy)
Employees on Job G.F. - F.P. - B.S. - K.M.T.G. 4 HR	METER SHUT OFF, ONE 3/4" I.P. X 3/4" COMP 10' OF 3/4" P.V.C. TUBING. - NEEDED TO SET BOX & GRADE DIRT AROUND BOX
Vehicles or Equip. Used 11-14-15 - BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST Ex. 7f (Water Infra.) FILL BOX
Job Completed	CYCLED PUMP AT CYCLED BLOWERS AT Ex. 7f (Water Infra.)
Employees on Job K.M. 4 HR	
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job T.C. 4 HR	FINISHED 126 CYCLE 5 RADIO READS
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace



Date 10-25-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. RE-READS LOCATES
Jobs Completed	SET BOX, GRADED DIRT, HAULING OFF ASPHALT AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job G.F. - T.C. - F.P. - B.S. 3HR 4HR	
Vehicles or Equip. Used 11-8-14 - BACKHOE	

Sewer Department

Address	PULLED PUMP & CLEANED RACS OUT BEHIND <b>Ex. 6 (Personal Privacy)</b> INSTALLED PUMP IN FIELD FROM RENOIS
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT FIELD FROM RENOIS, PITTSBURG, CALVIN, BEHIND <b>Ex. 6 (Personal Privacy)</b>
Employees on Job F.P. - B.S. - K.M. 4HR	BY-PASSED STARTER AT BLUFF TO CYCLE BLOWER & RELIEVE SYSTEM & STARTERS ARE BOTH BAD - ONE WON'T PULL IN &
Vehicles or Equip. Used 14-15 - BACKHOE	OTHER IS LOW VOLTAGE AT BOTTOM OF STARTER

Meter Readers

Employees on Job T.C. 5HR	FINISHED 102
Areas - Read	
Vehicles Used 8	
General Foreman <u>Frank J. Pace</u>	



Date 10-23-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	WORKED AT <b>Ex. 6 (Personal Privacy)</b> FOUND TAP FOUND SERVICE LINE AT MAIN - DUG PUSH HOLE - HOOKED UP <b>Ex. 6 (Personal Privacy)</b> SERVICE	
Employees on Job F.P. - B.S. - G.F. - T.C. K.M. 4HR 2HR	TEMPORARILY TO GIVE SERVICE OVERNIGHT	
Vehicles or Equip. Used	14-15-11 - BACKHOLE	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job T.C.	FINISHED 24	
Areas - Read	STARTED 26	
Vehicles Used		
General Foreman	Frank Pace	

Date 10-22-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOOKED FOR LEAK AT **Ex. 6 (Personal Privacy)**  
DUG FROM BOX TO ROAD FOLLOWED SERVICE  
LINE - NO LEAK FROM BOX TO SHOULDER

Employees on Job

F.P. - B.S. - G.F.  
6 HR

Vehicles or Equip. Used

11-14 - BACKHOLE

Sewer Department

Address

PULLED PUMP BEHIND **Ex. 6 (Personal Privacy)**  
CLEANED OUT RAGS & ADJUSTED FLOAT BALL  
TALKED TO CUST. AT **Ex. 6 (Personal Privacy)** IT BACKUP

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** PILL BOX, BEHIND  
100 L.L. & FIELD FROM RENDIS

Employees on Job

F.P. - B.S. - K.M.  
2 HR

Vehicles or Equip. Used

14-15 - BACKHOLE

CYCLED PUMP AT **Ex. 7f (Water Infra.)**  
CYCLED BLOWERS ATMeter Readers

Employees on Job

T.C.

FINISHED  
22 & 23

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 10-19-18 Daily Job Sheet Sheet 1 of 1Water Department

## Comments

Address	Service Truck WORK orders - LOCATES
Jobs Completed	
Employees on Job GF BS	
Vehicles or Equip. Used 11 14	

Sewer Department

## Address

BY PASSED 71ST & CYCLED  
BLOWERS AT 73rd - Pumped

## Job Completed

REPAIRS DOWN - TURNED

Ex. 6 (Personal Privacy)

Re-Set BREAKER CONTINUES TO TRIP

## Employees on Job

DRAWING 50+ AMPS - LEFT OFF  
CHECKED PH 1 STATIONS

## Vehicles or Equip. Used

15  
14

## Meter Readers

## Employees on Job

TL

## Areas - Read

20 - 21

## Vehicles Used

8

## General Foreman

B. Smith



Date 10-18-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICER TRUCK W.O.
Jobs Completed	PULLED NEW LINE UNDER ROAD AT GENAVERE - USED 45' OF 3/4" P.V.C. TUBING, ONE 3/4" FLAREX COMP. ONE 15" METER SET INSTALLED RADIO READ METER - REUSED OLD
Employees on Job G.F. - K.M. - F.P. - B.S. 4 HR 4 HR 6.5 HR	P.V.C. BOX, RING & LID FROM SHOP BACKFILLED WITH SPOIL - TOPPED DRIVS WITH TWO BUCKETS OF C-M-Q ROCK
Vehicles or Equip. Used 11-14 - BACKHOLE	CHECKED LEAK AT <b>Ex. 6 (Personal Privacy)</b>

Sewer Department

Address	BUTT CRIMPED & HEAT SHRINK TUBE ON FLOAT BALLS AT VIOLET <b>Ex. 7f (Water Infra.)</b>
Job Completed	CHECKED FOR BACKUP AT <b>Ex. 7f (Water Infra.)</b> M.H. ON BOTH SIDES OF HOUSE DOWN IN CHANNEL - PUMPS WORKING - NO ONE HOME CUST. PROB.
Employees on Job F.P. - B.S. 1.5 HR	
Vehicles or Equip. Used 14	

Meter Readers

Employees on Job T.C. - G.F. - K.M. 4 HR	FINISHED 17-G.F. & K.M. 18-T.C. 19-T.C. & K.M.
Areas - Read	
Vehicles Used	

General Foreman

Franky - Pace

Date 10-17-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
VIOLET **Ex. 7f (Water Infra.)** 1ST WELL - 71ST **Ex. 7f (Water Infra.)**  
71ST **Ex. 7f (Water Infra.)** + PITTSBURG

Job Completed

CYCLAD PUMP AT **Ex. 7f (Water Infra.)**  
CYCLAD BLOWERS #

Employees on Job

F.P. - B.S. - K.M.

INSTALLED PUMP AT VIOLET **Ex. 7f (Water Infra.)**  
WELL - SPICED IN NEW FLOATBALLS - PUMPING  
NOW

Vehicles or Equip. Used

14-15 - BACKHOLE

CHECKED STATIONS  
LOCATES

Meter Readers

Employees on Job

T.C.

FINISHED  
13-14-15

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pore



Date 10-16-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.D.	
Jobs Completed	REBUILT SERVICE LEAKING ON FITTING TO HOUSE LINE AT <b>Ex. 6 (Personal Privacy)</b> USA ONE 3/4" FLARE X COMP., ONE 3/4" X 3/4" COMP., ONE 3/4" BARB X COMP., 10' OF 3/4" P.V.C. TUBING	
Employees on Job G.F. - F.P. - B.S.	6' OF 3/4" COPPER TUBING, ONE METER SPOT OFF, ONE METER COUPLING, ONE 18" X 30" P.V.C. METER BOX, BACKFILLED WITH SPOIL	
Vehicles or Equip. Used 11-14	LOCATED TAP FOR PULL AT <b>Ex. 6 (Personal Privacy)</b> IT IS UNDER DRIVE	
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT VIOLET <b>Ex. 7f (Water Infra.)</b> VRT WELL 75TH <b>Ex. 7f (Water Infra.)</b>	
Employees on Job K.M. G.H.C.	CYCLED BLOWERS AT OAKLAND & CROCKETTS	
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job T.C.	STARTED 13 (PASSPORT DIED) & 15	
Areas - Read		
Vehicles Used 8		
General Foreman	Frank J. Pace	



Date 10-15-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O. LOCATES	
Jobs Completed		
Employees on Job F.P. 4 HR		
Vehicles or Equip. Used 14		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST <b>Ex. 7f (Water Infra.)</b> PILL BOX, FIELD FROM RANBIS, VIOLET <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CYCLAD PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLAD BLOWERS A	
Employees on Job F.P. - B.S. - K.M. 2 HR	PULLED PUMP & REPAIRED SPLIT DISCHARGE LINE BEHIND <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 14-15- BACKHOLE	REPLACED WIRES INTO BREAKER AT <b>Ex. 6 (Personal Privacy)</b> DON'T KNOW HOW THEY PULLED OUT	
<b>Meter Readers</b>		
Employees on Job F.P. T.C. 2 HR	FINISHED 11 & 12 MANUALS T.C. / CYCLAD 4 RADIOS F.P.	
Areas - Read		
Vehicles Used 8-14		
General Foreman <u>Frank J. Pace</u>		

Date 10-12-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

K.M.  
3 HR

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** PILL BOX

Job Completed

CYCLED PUMP AT **Ex. 7f (Water Infra.)**  
CYCLED BLOWERS AT

Employees on Job

K.M. - F.P.-B.S.  
5 HR 3 HRPULLED BACK OFF PUMP 1 & CLEANED OUT  
MOP - WIRED PUMP 1 INTO STARTER 1 AT  
**Ex. 6 (Personal Privacy)** STARTER 2 LOOKS  
LIKE IT IS DEFERRED ON SIDE

Vehicles or Equip. Used

14-15

CHECKED BACKUP AT **Ex. 6 (Personal Privacy)**  
CUST. PROBLEM - TALKED TO CUST.Meter Readers

Employees on Job

F.P.-B.S.  
5 HRFINISHED  
9

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace



Date 10-11-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. CHANGED BROKEN METER SHUT OFF A Ex. 6 (Personal Privacy) USED ONE NEW METER SHUT OFF	
Jobs Completed	HOOKED UP BACKSIDES AT USED THREE 3/4" P.V.C. INSERTS, THREE 1/2" X 3/4" COMP. FITTINGS - BACKFILLED WITH SPOIL Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - G.F. - T.C. 6 HR 4 HR 3 HR	SHUT OFF BRANCH VALVE FOR HYDRANT AT COODWYN Ex. 6 (Personal Privacy) BY CAR - BROUGHT HYDRANT TO SHOP	
Vehicles or Equip. Used 11-14-BACKHOLE	MET WITH CLEAR WATER COMMUNICATIONS ABOUT BORING JOB	

Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT VIOLET Ex. 7f (Water Infra.) YET WELL	
Job Completed	PULLED BACK OFF PUMP #1 & CLEANED OUT MOP AT Ex. 7f (Water Infra.) FRONT	
Employees on Job K.M. - F.P. - B.S. 3 HR		
Vehicles or Equip. Used 15		

Meter Readers		
Employees on Job T.C. 5 HR	FINISHED 8	
Areas - Read		
Vehicles Used		

General Foreman

Frank J. Pace



Date 10-10-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	Service TRUCK WORK orders LOCATES
Jobs Completed	
Employees on Job GF BS	
Vehicles or Equip. Used 11 14	

Sewer Department

Address	BY PASSED 71 <sup>ST</sup> BOTH SPOTS CYCLED BLOWERS AT 73 <sup>rd</sup>
Job Completed	BY PASSED PITTSBURGH
Employees on Job Km BS	checked PH 1 TURNED #2 PUMP OFF <sup>AT</sup>
Vehicles or Equip. Used 15 14	RUNNING BUT NOT PUMPING

Ex. 7f (Water Infra.)

Meter ReadersEmployees on Job

TC

Areas - Read

6 &amp; 7

Vehicles Used

8

General Foreman

D. Amiel

Date 10-9-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT FIELD FROM RENOIS	
Job Completed	DUG OFF LID TO WET WELL, OPENED QUICK COUPLING ON HEADER, JRTIED HEADER, JRTIED TOWARDS PUMP, TOOK BACK OFF	
Employees on Job F.P. - B.S. - T.C.	PUMP TO MAKE SURE WE HAVE FLOW FROM WELL - PUMPING NOW AT FRONT - ALL PUMPS ON & CYCLING ALTERNATING	
Vehicles or Equip. Used 14-15-7- BACKHOLE - 9		
Meter Readers		
Employees on Job K.M.	FINISHED 10	
Areas - Read	STARTED 6	
Vehicles Used 8		
General Foreman	Frank J. Pace	

Ex. 7f (Water Infra.)

Date 10-8-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PICK BOX, CALVIN BLVD
Job Completed		CYCLED BLOWERS AT OAKLAND & CROCKETTS CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job F.P. - K.M. GOS		PULLED BACK OFF PUMP #1 & CLEANED OUT RAGS/MOP AT <b>Ex. 7f (Water Infra.)</b> RENT TWICE CHECKED <b>Ex. 6 (Personal Privacy)</b> FOR TIED PLUMBING AT
Vehicles or Equip. Used 14-15		CHECKED STATIONS
<u>Meter Readers</u>		
Employees on Job F.P. 1.5 T.C.		FINISHED AREA 5 T.C.
Areas - Read		FINISHED R.R. METERS AREAS 3,4,5,6,7,8,9 F.P.
Vehicles Used 8		
General Foreman <u>Frank P. Pae</u>		



Date 10-6-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<b>Sewer Department</b>		
Address		
Job Completed		RESRT BREAKERS AT <b>Ex. 7f (Water Infra.)</b> STATION FRONT- MONITERED PUMPS TILL THEY CAUGHT UP- TURNED ON
Employees on Job F.P. - K.M.		RILAY, 51ST, & 53RD. PUMPS
Vehicles or Equip. Used 14		
<b>Meter Readers</b>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 10-5-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	DUG OUT ROAD & PATCHED WITH COLD PATCH WHERE LEAK WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	F.P. - G.F. - T.C. - K.M. 5 HR                      2 HR    3 HR	
Vehicles or Equip. Used	11-14-15-BACKHOE	
<b>Sewer Department</b>		
Address	PULLED PUMP AT 75TH. <b>Ex. 7f (Water Infra.)</b> BROUGHT TO SHOP	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX	
Employees on Job	F.P. - G.F. - K.M. 3 HR                      5 HR	
Vehicles or Equip. Used	CHECKED BRIDGEDALE <b>Ex. 7f (Water Infra.)</b> 515 <b>Ex. 7f (Water Infra.)</b> ALL GOOD.	
14-11-15-BACKHOE		
Meter Readers		
Employees on Job	T.C. 6 HR                      FINISHED 4	
Areas - Read		
Vehicles Used	8	
General Foreman	Frank J. Pace	

Date 10-4-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed		
Employees on Job F.P.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715 <b>Ex. 7f (Water Infra.)</b> ALL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job K.M. 4HR	TALKED TO COST AT <b>Ex. 6 (Personal Privacy)</b> BOUT BACKUP- RELIEVED BACKUP WHEN WE BY-PASS PUMPED	
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 3	
Areas - Read	STARTED 6	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		



Date 10-3-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	CONNECTED BACKSIDE TO NEW LINE AT Ex. 6 (Personal Privacy) USED ONE 3/4" X 3/4" COMP. ONE METRIC COUPLING & 6' OF 3/4" COPPER TUBING
Employees on Job G.F. - F.P. - T.C. 5 HR	CONNECTED BACKSIDE TO NEW LINE AT Ex. 6 (Personal Privacy) USED ONE 3/4" X 3/4" COMP. ONE METRIC COUPLING & 6' OF 3/4" COPPER TUBING
Vehicles or Equip. Used 11-14-BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 Ex. 7f (Water Infra.) PILL BOX.
Job Completed	CYCLED PUMP AT Ex. 7f (Water Infra.) CYCLED BLOWERS AT BLUFF
Employees on Job K.M. - F.P. - T.C. 3 HR	WORKED ON BLUFF FLOAT BALLS - CANT SOLVE PROBLEM - RUNNING OFF ONE BALL & NOT KICKING MOTOR ON
Vehicles or Equip. Used 14-15	NEED TO PULL PUMP & CHECK FOR RAGS AT 75TH Ex. 7f (Water Infra.)

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 10-2-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	CRIMPED OFF LINE IN BOX & REPLACED BROKEN SHUT OFF AT <b>Ex. 6 (Personal Privacy)</b> USED ONE METER SHUT OFF
Employees on Job G.F. - F.P. - K.M. 2 HR	
Vehicles or Equip. Used 11	

Sewer DepartmentAddress

PULLED PUMP IN FIELD FROM RENOIS  
BY-PASS PUMPED IN FIELD FROM RENOIS  
TOOK PUMP TO SHOP

Job Completed

SWITCHED BLOWER #1 TO STARTER #1  
FROM STARTER #2 AT BLUFF - STILL  
PROBLEM WITH FLOATBALL - RUNNING ON  
TOP BALL - ON & OFF - OFF AT POLE NOW

Employees on Job

F.P. - K.M.  
6 HR 4 HR

REINSERTED DISCHARGE LINE INTO DISCHARGE  
AT 75TH **Ex. 7f (Water Infra.)** PUMPING NOW -  
CYCLED OAKLAND & CROCKETS

Vehicles or Equip. Used

14 - BACKHOLE

LOCATES

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 10-1-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT BACKSIDE & INSTALLED METER AT <b>Ex. 6 (Personal Privacy)</b> USED ONE METER COUPLING, ONE $\frac{1}{4}$ " X $\frac{3}{4}$ " COMP. FITTING &	
Employees on Job F.P. - G.B. 4 HR	10' OF $\frac{3}{4}$ " COPPER	
Vehicles or Equip. Used  11-14		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX	
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS AT	
Employees on Job F.P. - K.M. 4 HR	<b>Ex. 7f (Water Infra.)</b> CHECKED SECTIONS - STARTER AT PONA PULLING IN & HOLDING IN	
Vehicles or Equip. Used  14-15		
<b>Meter Readers</b>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 11-30-18

Daily Job Sheet

Sheet      of     Water Department

## Comments

Address	SERVICE TRUCK W/O. LOCATES
Jobs Completed	
Employees on Job F.P. - B.S. - G.R. D.H.R.	
Vehicles or Equip. Used 11-14	

Sewer Department

Address	BY-PASS PUMPED WITH 3rd GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RAIL BOX, FIELD FROM RENOIS
Job Completed	CYCLID BLOWERS AT OAKLAND, CROCKETTS BLUFF.
Employees on Job F.P. - B.S. - K.M. G.W.R.	PULLED PUMP & CLEANED OUT RAGS FROM PUMP IN FIELD FROM RENOIS
Vehicles or Equip. Used 14-15 - BACKHOLE	CHECKED STATIONS

## Meter Readers

## Employees on Job

## Areas - Read

## Vehicles Used

General Foreman

Frank J. Pace

Date 11-29-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT BACKSIDE AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> ED ONE METER SHUT OFF, ONE 3/4" X 3/4" CORR. FITTING, 12" OF 3/4" COPPER TUBING, ONE 18" X 30" P.VIC. METER BOX	
Employees on Job F.P. - B.S. - G.F. - K.M.	REPLACED SADDLE FOR <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> USED ONE 6" A.C. SADDLE ONE CORR. STOP. 24" OF 3/4" COPPER TUBING, BACK FILLED DRIVE WITH DUMP TRUCK LOAD OF CLEAN ROCK + C-MC ON TOP	
Vehicles or Equip. Used 11-14-15- BACKHOLE	REPLACED BROKEN SHUT OFF AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> WILLIAMS - CRIMPED IN BOX, REPLACED SHUT OFF	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 11-28-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	USED BACK HOP TO FIND MATERS FOR RE-ROADS <b>Ex. 6 (Personal Privacy)</b> CALVIN SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job B.S. - G.F.		
Vehicles or Equip. Used 11-14 - BACKHOP		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX,	
Job Completed	CYCLED BLOWERS AT OAKLAND, BLUFF CROCKETS	
Employees on Job K.M.		
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job F.P.	FINISHED 142 CYCLE 1 RADIO READS	
Areas - Read		
Vehicles Used 11		
General Foreman <u>Franky-Pace</u>		



Date 11-27-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		<u>Comments</u>	
Address		<u>SERVICE TRUCK W.O.</u> <u>RR-READS</u>	
Jobs Completed			
Employees on Job F.P. - G.P. GMR			
Vehicles or Equip. Used 11-14			
<u>Sewer Department</u>			
Address			
Job Completed			
Employees on Job			
Vehicles or Equip. Used			
Meter Readers			
Employees on Job F.P. - T.C. - K.M. GMR		FINISHED 19 & 29 - T.C. & K.M. CYCLE 5 RADIO READS F.P.	
Areas - Read			
Vehicles Used 14-8			
General Foreman <u>Franky-Pace</u>			

Date 10-26-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O. RE-READS
Jobs Completed		
Employees on Job F.P. - K.M. 2HR		
Vehicles or Equip. Used 11-15		
<u>Sewer Department</u>		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 7137 <b>Ex. 7f (Water Infra.)</b> PILL BOX
Employees on Job K.M.		CYCLAD BLOWERS AT OAKLAND & CROCKETTS
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job T.C.		FINISHED 24 & 26
Areas - Read		STARTED 19
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 11-21-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. REMOVED METERS LOCATES
Jobs Completed	
Employees on Job F.P.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX PITTSBURG, CALVIN BLVD.
Job Completed	CYCLER BLOWERS AT OAKLAND, & CROCKETT
Employees on Job K.M.	
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job T.C.	FINISHED 22-23
Areas - Read	STARTED
Vehicles Used 8	

General Foreman

Frank J. Pace



Date 11-22-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

THANKS

GIVING

HOLIDAY

Date 11-23-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

THANKS

GIVING

FRIDAY

HOL

1 DAY

Date 11-20-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. REMOVED METERS	
Jobs Completed		
Employees on Job F.P. - K.M. C.H.R.		
Vehicles or Equip. Used 11-15		
<u>Sewer Department</u>		
Address	REMOVED BACK OF PUMP & CHECKED FOR RAGS - PUMPING & CYCLING NOW AT Ex. 6 (Personal Privacy)	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS E. ST. LOUIS UP & NOT TAKING	
Employees on Job F.P. - K.M.		
Vehicles or Equip. Used 11-15		
Meter Readers		
Employees on Job T.C.	FINISHED 20+22	
Areas - Read	STARTED 21	
Vehicles Used 8		
General Foreman	Frank J. Pace	



Date 11-19-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. REMOVED METERS
Jobs Completed	REPAIRED 2" C.I. MAIN BREAK AT CAROL - USED ONE 2" S.S. REPAIR CLAMP BACKFILLED WITH ROCK SPOIL & ONE BUCKET C-M-G ROCK FROM SHOP
Employees on Job F.P. - T.C. - K.M. 6HR 4HR	CRIMPED LINE IN BOX TO STOP LEAK FROM TAMPERING - NEED TO RE BUILD SERVICE
Vehicles or Equip. Used  11-8-15-BACKHOE	

Sewer Department

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> RILL BOX
Employees on Job K.M. 4HR	CYCLED BLOWERS AT ADAMS, OAKLAND, CROCKETTS
Vehicles or Equip. Used  15	

Meter Readers

Employees on Job T.C.	FINISHED 14
Areas - Read	
Vehicles Used 8	

General Foreman

Franky Pace

Date 11-16-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
REMOVED METERS

Jobs Completed

Employees on Job

F.P. - B.S.

Vehicles or Equip. Used

7-11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
71ST **Ex. 7f (Water Infra.)** PILL BOX, CALVIN BLVD.

Job Completed

**Ex. 6 (Personal Privacy)** CYCLED PUMP AT  
AFTER 10-15 MIN. OF PUMPING,  
CYCLED BLOWERS AT AMES, OAKLAND, CROCKETTS

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C.

FINISHED  
13 & 18

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 11-15-18

Daily Job Sheet

Sheet      of     Water Department

## Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	CLEANED CAGE, SHOP, BREAK & METER ROOMS
Employees on Job F.P. - G.F. - B.S. - T.C. - K.M. 4 HR	SEPERATED BRASS & COPPER
Vehicles or Equip. Used  7-11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS
Employees on Job K.M.	
Vehicles or Equip. Used  15	

## Meter Readers

## Employees on Job

## Areas - Read

## Vehicles Used

General Foreman

Franky Pace



Date 11-14-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES REMOVED MATERS	
Jobs Completed		
Employees on Job		
G.F. - K.M. - B.S. 2 HR 1.5		
Vehicles or Equip. Used		
11-14-15		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT PITTSBURG	
Job Completed	INSTALLED PUMP & FLOATBALL AT Ex. 6 (Personal Privacy)	
Employees on Job		
F.P. - B.S. K.M. G.S. 2 HR	INSTALLED NEW CONDUIT & FLOATBALLS AT AMES	
Vehicles or Equip. Used		
14-15-BACKHOE		
Meter Readers		
Employees on Job	FINISHED CYCLE 4 RADIO READS 12-T.C. - F.P.	
T.C. - K.M. - F.P. 4 HR 1.5		
Areas - Read	STARTED 13-K.M. 18-T.C.	
Vehicles Used		
8-15		
General Foreman	<u>Frank J. Pace</u>	

Date 11-13-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. CLEANED TOOLS & SUCTION HOSE FROM NIGHT JOB AT <b>Ex. 6 (Personal Privacy)</b>
Jobs Completed	BACKFILLED WITH TWO TRUCK LOADS OF CLAN ROCK A <b>Ex. 6 (Personal Privacy)</b> HALLED OFF SPOIL TO SNOWS
Employees on Job F.P. - B.S. - T.C. - G.F. 4 HR 3 HR	
Vehicles or Equip. Used G-14-11-BACKHOE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST <b>Ex. 7f (Water Infra.)</b> PILL BOX, CLINTON
Job Completed	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT AMES, OAKLAND, & CROCKETTS
Employees on Job K.M. - F.P. - B.S. 4 HR	TURNED ON BELLEVUE, SUPERIOR IS RUNNING BOTH PUMPS - ALTERNATING & CYCLING.
Vehicles or Equip. Used 14-15	CHECKED SOUTH END STATIONS - PULLED PUMP BEHIND <b>Ex. 6 (Personal Privacy)</b> LOOK TO SHOP.

Meter Readers

Employees on Job T.C. 5 HR	FINISHED 12411
Areas - Read	STARTED
Vehicles Used 8	

General Foreman

Franky Pace

Date 11-12-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>	<u>Comments</u>
Address	DOUBLE TIME
Jobs Completed	REPAIRED MAIN BREAK AT BOND - CUT OUT 49" OF 6" C.I. MAIN & REPLACED WITH 49" OF C-900 P.V.C. ~
Employees on Job F.P. - G.F. - T.C. - K.M.	TWO 6" 501 EXTREME DRASSERS NEEDED TO BACKFILL WITH ROCK & HAUL OFF SPOIL
Vehicles or Equip. Used	

Ex. 6 (Personal Privacy)

<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace



Date 11-12-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

HOLIDAY

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

VETERANS

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

DAY

General Foreman

Frank J. Pace

Date 11-9-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS RE-READS REMOVED METERS
Jobs Completed	
Employees on Job C.F. K.M. 2 HR	
Vehicles or Equip. Used 11-15	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT AMRS, OAKLAND, & CROCKETTS - ALL OFF NOW - E. ST. LOUIS FULL
Employees on Job F.P. - B.S. - K.M. 4 HR	PULLED & WIRED IN FLOATBALLS AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 14-15	PRIMED PUMP #1 AT SUPERIOR & CLEANED SUMP PUMP & SUMP WELL

Meter Readers

Employees on Job T.C. - K.M. 2 HR	FINISHED 15 - T.C.
Areas - Read	STARTED 11 - T.C. & K.M. - PASSPORT DIED
Vehicles Used 8-15	

General Foreman Frank J. Pace

Date 11-8-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES
Jobs Completed	
Employees on Job G.F. - F.P. 5HR 2HR	
Vehicles or Equip. Used 11-14	

Sewer DepartmentAddress

CYCLER BLOWER AT CROCKETTS  
CHECKED STATIONS

Job Completed

INSTALLED STARTER AT  
WORKED ON FLOATBALLS AT AMES -  
NEED TO REPLACE CONDUIT UNDER GROUND

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.  
4HR

Vehicles or Equip. Used

7-14

Meter ReadersEmployees on Job

T.C. G.F. F.P.  
3HR 2HR

FINISHED

9-T.C.

8+10-G.F.

RADIO  
READS F.P.

Areas - ReadVehicles Used

8-11-14

General Foreman



Date 11-7-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.P.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT AMES, OAKLAND & CROCKFITS
Employees on Job F.P.-B.S.-K.M.	WORKED ON SUPERIOR - PULLED BACK OFF PUMP #2 & CLEANED OUT RAGS - PULLED & WIRED IN TWO NEW FLOAT BALLS - NEED TO PRIME PUMP 1 & CHECK BALL ADJUSTMENT
Vehicles or Equip. Used 14-15	

Meter Readers

Employees on Job T.C.	FINISHED 6
Areas - Read	STARTED 8
Vehicles Used 8	

General Foreman

Frank P. Pace

Date 11-6-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

SERVICE TRUCK  
WORK orders

Jobs Completed

Employees on Job

BS

6F

Vehicles or Equip. Used

11

14

Sewer Department

Address

PRIMED #1 PUMP A.M. LOST PRIME  
IN P.M. TURNED OFF- RUNNING #2  
PUMP. CHECKED PH 1 SEWERS

Job Completed

BY PASSED PITTSBURGH  
TURNED OFF BELLEVUE-

Employees on Job

BS

KM

ESL IS FULL. COULD NOT  
PUMP 73RD OR OAKLAND EITHER

Vehicles or Equip. Used

14  
15Meter Readers

Employees on Job

TC

Areas - Read

5

Vehicles Used

8

General Foreman



Date 11-5-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W/O. RH-READS - PUMPED OUT VAULTS WITH 2" PUMP
Jobs Completed	
Employees on Job G.F. - F.P. - B.S. GMR 2HR	
Vehicles or Equip. Used 11-14	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX CALVIN
Job Completed	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS A
Employees on Job K.M. - F.P. - B.S. 2HR	AMES ONLY WORKING ON TOP/SHORT FLOATBALL
Vehicles or Equip. Used 14-15	REMOVED STARTER FROM <b>Ex. 6 (Personal Privacy)</b>

Meter Readers

Employees on Job T.C.	FINISHED 4
Areas - Read	STARTED 5
Vehicles Used 8	
General Foreman <u>Franky. Pice</u>	



Date 11-2-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	PULLED NEW P.V.C. SERVICE LINE UNDER ROAD AT <b>Ex. 6 (Personal Privacy)</b> USED 30' OF 3/4" P.V.C. TUBING, 18' OF 1/2" COPPER TUBING.
Employees on Job F.P.-B.S.-G.F.-T.C. 1HR	ONE 3/4" COMP. NUT, ONE 3/4" X 3/4" COMP. FITTING, ONE 15" METAL SET, THREE 3/4" INSERTS, ONE 18" X 30" P.V.C. METAL BOX,
Vehicles or Equip. Used 8-11-14-BACKHOC	BACK FILLED WITH SPOIL & TWO BUCKETS OF C-M-6 ROCK FROM SHOP INSTALLED RADIO READ METER

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Sewer Could Not Pump  
E. ST. Louis System FullMeter Readers

Employees on Job

TC - K.M.  
7HR 6HR

FINISHED

3-T.C. 7-K.M.

Areas - Read

STARTED

4-T.C. 8-K.M.

Vehicles Used

8-15

General Foreman

Frank J. Pace

Date 11-1-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job C.F.	
Vehicles or Equip. Used 11	

Sewer DepartmentAddress

BY-PASS PUMPED AT 75T **Ex. 7f (Water Infra.)** BUT  
E. ST. LOUIS WAS BACKED UP & NOT TAKING  
DID NOT VAC WELL OR SET PUMP DUE TO THAT

Job Completed

CHECKED STATIONS - ALL GOOD BUT  
E. ST. LOUIS NOT TAKING AT 82ND & 73RD  
E. ST LOUIS TAKING AT 63RD

Employees on Job

F.P. - B.S. - K.M. - T.C.

CUT OUT BAD SPOT IN DISCHARGE LINE &  
RE STABBED QUICK COUPLING AT SHOP  
ORGANIZED UNIT 14

Vehicles or Equip. Used

14-15-9-7

SECURED SUMP PUMP DISCHARGE & CHECK  
VALVE AT BRIDGE DALE - CLEANED UP  
DEBRIS IN CAN AT **Ex. 7f (Water Infra.)**

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman

Frank J. Pace

Date 12-31-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job F.P. - T.C. 4 HR	
Vehicles or Equip. Used	
8-11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS
Employees on Job F.P. - T.C., K.M. 4 HR	PULLED PUMP #1 & CLEANED OUT RAGS AT CRISTON
Vehicles or Equip. Used	
BACKHOE - 14-15	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace



Date 12-28-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. RE-READS
Jobs Completed	
Employees on Job F.P. - T.C. 4HR 2HR	
Vehicles or Equip. Used 11-8	

Sewer Department

Address	WORKED WITH CENTREVILLE TOWNSHIP ON SIGNAL HILL JATTING CULVERTS
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX CALVIN BLVD.
Employees on Job K.M. F.P. - T.C. 2HR	CYCLED BLOWERS AT OAKLAND & CROCKETTS
Vehicles or Equip. Used 9-14-15	

Meter Readers

Employees on Job F.P. T.C. 2HR 4HR	FINISHED AREA 29 MANUALS
Areas - Read	
Vehicles Used 11-8	

General Foreman Frank J. Rice

Date 12-27-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. RE-READS	
Jobs Completed	PUMPED OUT DITCHES & LOOKED FOR LEAK AT <b>Ex. 6 (Personal Privacy)</b> WAITING ON LOCATE	
Employees on Job	F.P. - J.C. - K.M. 4 HR 6 HR	
Vehicles or Equip. Used	14-15-11	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job	FINISHED CYCLE 2 RADIO F.P. - J.C. - K.M. - READS - F.P. 4 HR 2 HR 1 & 2 - T.C. & K.M. -	
Areas - Read		
Vehicles Used	8-11	
General Foreman	Frank J. Pace	

Date 12-26-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job F.P. 7 HR	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7th St. <b>Ex. 7f (Water Infra.)</b> PILL BOX
Job Completed	CYCLAD BLOWERS AT OAKLAND & CROCKETTS E. ST. LOUIS NOT TAKING
Employees on Job K.M. 6 HR	
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job F.P. - K.M. - T.C. 1 HR 2 HR	FINISHED 19-T.C. & K.M. 24 & 26-T.C. CYCLER 5 RADIO READS F.P.
Areas - Read	
Vehicles Used 8-11	

General Foreman Franky Pace



Date 12-25-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Franky Pace

HOLIDAY  
MERRY  
CHRISTMAS

Date 12-24-18

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. 2 MC		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 715' <b>Ex. 7f (Water Infra.)</b> VILL BOX
Job Completed		CYCLRD BLOWERS AT OAKLAND & CROCKETTS TURNED ON BELLEVUE <b>Ex. 7f (Water Infra.)</b>
Employees on Job F.P. - K.M.		DIPPED OUT CAN AT BLUFF <b>Ex. 7f (Water Infra.)</b>
Vehicles or Equip. Used 14-15		CHECKED STATIONS ON SOUTH END
<u>Meter Readers</u>		
Employees on Job T.C.		FINISHED 23
Areas - Read		
Vehicles Used 8		
General Foreman _____		

Date 12-21-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.D.
Jobs Completed	REBUILT SERVICE & HOOKED UP NEW LINK AT Ex. 6 (Personal Privacy) USED TWO $\frac{3}{4}$ "X $\frac{3}{4}$ " COMP. FITTINGS ONE METER SHUT OFF, ONE METER COUPLING,
Employees on Job F.P. - G.F. - K.M.	12' OF $\frac{3}{4}$ " COPPER TUBING, ONE 12"X30" METER BOX, BACKFILLED WITH ONE BUCKET SAND FROM SHOP & SPOIL
Vehicles or Equip. Used 11-14-BACKHOLE	REPLACED SHUT OFF AT Ex. 6 (Personal Privacy) CRIMPED LINK IN BOX & REPLACED SHUT OFF

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHED  
22 + 21 - T.C.

Areas - Read

Vehicles Used

8

General Foreman

Franky Pace



Date 12-20-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	GRADED ROAD WITH $\frac{1}{2}$ BUCKET OF C-M-G ROCK WHERE MAIN BREAK WAS REPAIRED IN THE <b>Ex. 6 (Personal Privacy)</b> MILDRED
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	CHECKED STATIONS - PULLED BACK OFF PUMP AT BRIDGE DALE BUT PROBLEM WAS WITH FLOATBALLS - PUMPING NOW
Job Completed	E. ST. LOUIS NOT TAKING - M.H. FULL AT 3RD LOCATED FOR BORE JOB
Employees on Job F.P. - T.C. - K.M. 2HR 6HR	INSTALLED CLEANOUT IN LATERAL AT <b>Ex. 6 (Personal Privacy)</b> - USED ONE 4" SWAMP, 6' OF 4" P.V.C. PIPE, CLEAN ROCK + C-M-G ROCK TO BACKFILL.
Vehicles or Equip. Used 14-15-6 - BACKHOLE	

Meter Readers

Employees on Job T.C. - K.M. 6HR 2HR	FINISHED 20 - K.M. & T.C.
Areas - Read	STARTED 23 - T.C.
Vehicles Used 8	

General Foreman

Frank J. Pace

Date 12-19-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED AT 71ST & 71ST Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS	
Employees on Job F.P. - T.C. - K.M.	CUT & HAMMERED OUT ROAD, EXPOSED 6" CONCRETE LATERAL TO VERTICAL PIPE, CUT LATERAL, BLOCK IS 4' DOWN FROM TOP	
Vehicles or Equip. Used G-14-15 - BOTH BACKHOCKS	OF VERTICAL PIPE TO MAIN. BACKFILLED WITH TWO TRUCK CLEAN ROCK & THREE BUCKETS C-M-G ROCK AT Ex. 6 (Personal Privacy)	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Date 12-18-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		PULLED BACK OFF OF PUMP & CRANKED OUT RAGS AT BRIDGE DALE LOCATED ALONG 157 FOR BORING
Job Completed		BY-PASS PUMPS WITH 3" GAS PUMP AT CALVIN 75TH Ex. 7f (Water Infra.) CYCLED BLOWERS AT OAKLAND & CROCKETTS
Employees on Job F.P. - T.C. - K.M.		WORKED WITH VILLAGE CAMERA + H+H SENER AT Ex. 6 (Personal Privacy) COULD NOT OPEN LATERAL PULLED BACK MUD ON CUTTER
Vehicles or Equip. Used 9-14-15		BACKUPS AT Ex. 6 (Personal Privacy) HANOVER DUE TO PUMP KICKING OUT & SYSTEM BACKUP
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 12-17-18

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715 <b>Ex. 7f (Water Infra.)</b> PILL BOX, 63RD & PITTSBURG
Job Completed	CYCLES BLOWERS AT OAKLAND & CROCKETTS DIPPED OUT CANS AT OAKLAND & CROCKETTS
Employees on Job F.P. - T.C. - K.M.	EXPOSED LATERAL, CUT OUT 30" OF LATERAL & JETTED TOWARDS MAIN, COULDN'T GET THROUGH BLOCK - HAULED OFF SPOIL & WAITING TO CAMERA LINE
Vehicles or Equip. Used 9-14-15 - BACKHOLE	LOCATED ALONG 157 FOR BORING

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 12-14-18

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	REPLACED BRAKE LIGHT ON UNIT 14	
Employees on Job F.P. - G.F. - B.S. 4 HR 2 HR		
Vehicles or Equip. Used 11-14		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> EDNA, 63RD <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CHECKED STATIONS - E. ST. LOUIS NOT TAKING AT 82ND - M. AN HOLES ARE FULL E. ST. LOUIS NOT TAKING FULLY AT 73RD	
Employees on Job F.P. - K.M. 4 HR	CYCLED BLOWERS AT OAKLAND & CROCKETTS	
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Price</u>		

Date 12-13-18

Daily Job Sheet

Sheet      of     Water Department

## Comments

Address	SERVICE TRUCK W.O. LOCATES PUSHED DEBRIS OFF ROAD AT SNOWS
Jobs Completed	INSTALLED RESETER, RING, LID, & R.R. METER AT <b>Ex. 6 (Personal Privacy)</b> ALSO RAISED BOX WITH ROW OF BRICKS
Employees on Job F.P. - B.S. - G.F. 6 HR	WORKED ON PUMPS IN SHOP - NITHER RUN WELL - NEW ONE RUNS WITH CHOKER ON ONLY OLD ONE WON'T START
Vehicles or Equip. Used 11-14	HADZED BUCKET OF C-M-G ROCK & GRADED SHOULDER ACROSS FROM <b>Ex. 6 (Personal Privacy)</b> WHERE PUSH WAS MADE

Sewer Department

Address	WORKED WITH CENTREVILLE AT <b>Ex. 7f (Water Infra.)</b> WITH UNIT 9
Job Completed	FOUND LINES AT <b>Ex. 7f (Water Infra.)</b> <b>Ex. 7f (Water Infra.)</b>
Employees on Job K.M. - F.P. - B.S. - T.C. 2 HR 4 HR	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST <b>Ex. 7f (Water Infra.)</b> PILL BOX, <b>Ex. 7f (Water Infra.)</b> 3RD - PUMPED OUT PILL BOX
Vehicles or Equip. Used 9-14-15	CYCLED PUMP AT <b>Ex. 7f (Water Infra.)</b> CYCLED BLOWERS

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace



Date 12-12-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

SERVICE TRUCK

LOCATES

Jobs Completed

Fixed LEAK AT  
with 4" CLAMP

Ex. 6 (Personal Privacy)

Employees on Job

FP GP  
TC BS Km

Vehicles or Equip. Used

11 15  
BACK HOE 14LOCATED 157 FOR BORING  
comp.Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 12-11-18

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O. RE-READS LOCATED 157 FOR BORING	
Jobs Completed	FOUND VALVE AT <b>Ex. 6 (Personal Privacy)</b> IT HAD NO VALVE BOX - INSTALLED USED VALVE BOX FROM SHOP.	
Employees on Job	G.F. - F.P. - B.S. - K.M. - T.C. 6HR 6HR 2HR	
Vehicles or Equip. Used	11-14-15-18-BACKHOE	
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 75TH <b>Ex. 7f (Water Infra.)</b>	
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS E. ST. LOUIS NOT TAKING FULLY	
Employees on Job	PULLED PUMP # 1 AT <b>Ex. 6 (Personal Privacy)</b> CLEANED RAGS.	
Vehicles or Equip. Used	CHECKED FOR BACKUP AT RENITASON WEST CUST PROB.	
<b>Meter Readers</b>		
Employees on Job	FINISHED 18-G.F. 13414-T.C.	
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 12-10-18

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

Ex. 6 (Personal Privacy)

Dug UP BOX AND TURNED SERVICE  
OFF AT SHUT OFF.SERVICE TRUCK WORK ADDRESS  
LOCATES

Jobs Completed

Employees on Job

BS  
TC

Vehicles or Equip. Used

14  
18  
BACKHOESewer Department

Address

By PASSED Ex. 7f (Water Infra.)  
71ST - RAN BLOWERS AT 73rd

Job Completed

Employees on Job

KM

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

GF  
TC

Areas - Read

11 12 13

FINISHED 11 12 STARTED 13

17 18

FINISHED 17 STARTED 18

Vehicles Used

14  
8

General Foreman

B. Smith



Date 12-7-18

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job	GF BS	
Vehicles or Equip. Used	11 14	
<u>Sewer Department</u>		
Address		BY PASSED 71ST - CYCLED BLOWERS AT 73rd - OAKLAND
Job Completed		BY PASSED PITTSBURGH
Employees on Job	KM	
Vehicles or Equip. Used	15	
<u>Meter Readers</u>		
Employees on Job	GF TC	START 11 FINISH 15      START 17
Areas - Read		
Vehicles Used	118	
General Foreman	B. [Signature]	

Date 12-4-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

SERVICE TRUCK  
WORK ORDERS

Jobs Completed

Employees on Job

BS  
GF

Vehicles or Equip. Used

14  
11Sewer Department

Address

Job Completed

CHECKED STATIONS  
#1 PUMP OUT AT  
SWITCHED ALT. TO #2

Ex. 6 (Personal Privacy)

Employees on Job

KM-BS

BY PASSED CALVIN  
ESTL. STILL NOT TAKING

Vehicles or Equip. Used

15-14

Meter Readers

Employees on Job

GF

Areas - Read

FINISHED 4  
FINISHED 9

START + FINISHED 5

Vehicles Used

11  
8

General Foreman

B. Smith

Water Department		Comments	
Address		Service TRUCK work orders	
Jobs Completed			
Employees on Job BS GF			
Vehicles or Equip. Used 14 11			
Sewer Department			
Address		By PASSED 71ST - RAN BLOWERS ON 73rd By PASSED PITTSBURGH	
Job Completed			
Employees on Job Km			
Vehicles or Equip. Used 15			
Meter Readers			
Employees on Job GF TC			
Areas - Read		FiniSHed 3      completed 8 START 4      STARTED 9	
Vehicles Used 11/8			
General Foreman		B. Daniel	



Date 12-4-18

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address	SERVICE TRUCK
Jobs Completed	
Employees on Job GF BS KM	
Vehicles or Equip. Used 8 11 15	

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job KM GF	
Areas - Read STARTED 3	FINISHED 6 COMPLETED 7 START 8
Vehicles Used 158	

General Foreman B. Smith

Date 12-3-18

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

Service TRUCK

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

14

Sewer Department

Address

BY PASSED 71ST &  
CYCLED BLOWERS AT 73<sup>rd</sup>

Job Completed

BY PASSED 75TH ST

Employees on Job

KM

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

GF

Areas - Read

10  
STARTED 3  
STARTED 6

Vehicles Used

15

General Foreman

B. Smith