

Date 1-1-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Water Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Meters - Read

Vehicles Used

General Foreman Frank J. Pace

How
2
1
Day
New
Year
Day

Date 1-4-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPS WITH BOTH 3" GAS PUMPS AT 71ST & Ex. 6 (Personal Privacy) VIOLET, RENOIS
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, - CYCLED PUMP AT CLINTON
Employees on Job F.P. - B.S. - K.M. Ex. 6 (Personal Privacy)	PULLED PUMP & CLEANED OUT RACS BEHIND LAURALER - PUMPING NOW.
Vehicles or Equip. Used 2-14- BACKHOE	BY-PASSED M.H. DOWN & INSTALLED NEW PUMP Ex. 6 (Personal Privacy) LAURALER - PUMPING NOW

Meter Readers

Employees on Job T.C.	FINISHED 6+9
Areas - Read	
Vehicles Used DROP OFF	

General Foreman

Frank J. Pace

Date 1-5-21

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

RE-READS

Employees on Job

K.M. G.F. - F.P. B.S.
6 HR

REPAIRED MAIN BREAK [REDACTED] T. CROME
USED ONE 6" A.C. OVERSIDE S.S. REPAIR CLAMP
BACK FILLED WITH 1/2 LOAD OF CLEAN ROCK & SPOL

Vehicles or Equip. Used

1-3-14 - BACKHOE

HOOKE UP BACKSIDE [REDACTED] CALVIN
USED ONE 3/4" X 3/4" COMP. FITTING + ONE 3/4"
P.V.C. INSERT - BACK FILLED WITH SPOL

Sewer Department

Address

[REDACTED]

PUT LID & RING BACK ON MANHOLE AT
OLD MO

Jobs Completed

Employees on Job

F.P. - B.S.
1 HR

Vehicles or Equip. Used

14 - BACKHOE

Meter Readers

Employees on Job

T.C.

FINISHED
10, 11, 12

Areas - Read

STARTED

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace

Date 1-6-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	W.O / Locates
Jobs Completed	re-reads
Employees on Job G.F	
Vehicles or Equip. Used 3	

Water Department

Address	Bypass pumped - 71 st , oakland, crockett, pershing, clinton, and arnes
Jobs Completed	
Employees on Job KM	
Vehicles or Equip. Used 2	

Meter Readers

Employees on Job T.C, B.S	Finished 13, 15, 17	Started 14, 18
Areas - Read 15, 17, 18 13, 14		
Vehicles Used 1		

General Foreman Kent McCall

Date 1-7-21

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>W.O. / Locates</u> <u>Rereads</u>
Jobs Completed	
Employees on Job	
<u>BS, GF</u>	
Vehicles or Equip. Used	
<u>2, 3</u>	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Readers

Employees on Job	<u>Finished</u> <u>14, 18</u>
<u>KN, TC</u>	
Areas - Read	
<u>4, 18</u>	
Vehicles Used	
<u>1</u>	

General Foreman K. M. Ball

Date 1-8-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	<u>N.O. , Locates</u> <u>Rereads</u>
Jobs Completed	replaced shut off on 11/5/8 1/5/8 shutoff Ex. 6 (Personal Privacy) Hanover Broken shutoff replaced
Employees on Job	
GF, BS, KM	
Vehicles or Equip. Used	
1, 2, Backhoe	

Water Department

Address	Bypass pumped 71 st , crockett, oakland, pershing, & clinton cycled.
Jobs Completed	
Employees on Job	
KM	
Vehicles or Equip. Used	
1	

Water Readers

Employees on Job	<u>Finished</u> 19	<u>Started</u> 20, 23
Areas - Read	19, 20, 23	
Vehicles Used	1, 2	

General Foreman John McCall

Date 1-12-21

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WAT WELL DOWN,
PULLED & CLEANED PUMP #2 AT
Ex. 7f (Water Infra.) REAR.

Jobs Completed

CYCLED AMES STATION FOR 3 HOURS.

Employees on Job

F.P. - B.S. - K.M.
J.M.

Vehicles or Equip. Used

2-14-BACKHOE

Meter Readers

Employees on Job

K.M.
G.M.

FINISHED

22 & UNREAD METERS IN PASSPORT

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 1-13-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATED
Jobs Completed	FILLED IN ROADS WITH ONE BUCKETT C-M WHERE BREAKS WERE REPAIRED AT BLOCK OF PHILADELPHIA
Employees on Job F.P. - K.M. G.F. B.S. 1 HR 4 HR 1 HR	LEAK AT JEROME Ex. 6 (Personal Privacy) AGAIN
Vehicles or Equip. Used	1-3 - BACKHOE

Water Department

Address	BY-PASS PUMPED DOWN WET WALL, VACUUMED + CLEANED OUT WALL - SET PUMP BY BACK ON SHOE - ADJUSTED FLOAT BALLS AT THE
Jobs Completed	CENTREVILLE Ex. 7f (Water Infra.) REAR
Employees on Job F.P. - B.S. - K.M. 7 HR	CHECKED FOR BACKUP AT Ex. 6 (Personal Privacy) CALLED IN BY Ex. 6 (Personal Privacy) IS SURCHARGING OUT OF LATERAL + FLOODING YARD -
Vehicles or Equip. Used -14- BACKHOE VILAGE VACTOR	OUR LINES ARE DOWN & FLOODING TALKED TO COST AT Ex. 6 (Personal Privacy)

Water Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-14-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

REPAIRED 8" C.I. MAIN BREAK IN
BLOCK OF N. 55TH - USED TWO 3" 501 DRESSERS
4' OF 2" P.V.C. PIPE - BACK FILLED OVER

Ex. 6 (Personal Privacy)

Employees on Job

F.P.-B.S. - G.P.
G.P.MAIN WITH SPOKE - NEEDED TO FILL IN MORE
AFTER IT DRIES OUT.

Vehicles or Equip. Used

3-14-BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" CAS DUMP AT
VIOLAT

Ex. 6 (Personal Privacy)

Jobs Completed

J&T JOB FOR CENTREVILLE

Employees on Job

K.M. T.C.
D.M.C. D.M.C.

Vehicles or Equip. Used

1

Meter Readers

Employees on Job

F.P.-B.S. - K.M.-T.C.
D.M.C. G.M.C.

FINISHED

142-T.C.

29-F.P.-B.S. - K.M.-T.C.

Areas - Read

Vehicles Used

DROPOFF 102

General Foreman

Frank J. Pace

Date 1-15-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

RA-READS

Jobs Completed

CLEANED OUT UNIT 14

Ex. 6 (Personal Privacy)

Employees on Job

G.F. - T.C. - F.P.
6 HR 4 HRREPAIRED GARAGE DOOR ON NORTH WEST
SIDE OF SHOP - CAME OUT OF TRACK AT
TOP PANEL

Vehicles or Equip. Used

2-3 - SHOP

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
Ex. 6 (Personal Privacy) PILL BOX - RENOIS -

Jobs Completed

CYCLED BLOWERS AT CROCKFORD,
OAKLAND & AERSHING - CYCLED PUMP AT
CLINTON

Employees on Job

K.M. - F.P. (G.F.)
4 HR 2 HR

LOCATED MANHOLES ALONG LAUREL

Vehicles or Equip. Used

1 - BACKHOE - 3

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-18-21

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Water Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

H
O
L
I
D
A
Y

M
L
K
D
A
Y

Date 1-19-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPS WITH BOTH 2" PUMPS AT 71ST & Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy) LAURA CREE
Jobs Completed	CYCLAD BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLAD PUMP AT CLINTON
Employees on Job F.P. - B.S. - K.M.	EXPOSED SEWER MAIN & FOUND ROOTS GROWING INTO MAIN AT BELT BEHIND Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1-14-BACKHOE	WORKED ON LOWERING PUMP AT Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job T.C.	FINISHED 344
Meters - Read	STARTED 5
Vehicles Used DROP OFF	

General Foreman Frank J. Pace

Date 1-20-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

REPAIRED 4" C.I. MAIN BREAK AT
ROSE LN. - USED ONE 4" C.I. S.S. REPAIR
CLAMP - BACKFILLED ROAD WITH ROCK

Ex. 6 (Personal Privacy)

Employees on Job

C.I. - F.P. - B.S.
4 HRFILLED IN ROAD WITH ROCK WHERE MAIN
BREAK WAS REPAIRED ON N. 50TH

Vehicles or Equip. Used

2-3-14 - BACKHOLE

Sewer Department

Address

PUMPED DOWN M.H. WITH 3" GAS PUMP &
36T PUMP WITH LONGER DISCHARGE & CHAIN
TO LOWER PUMP AT

Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

F.P. - B.S.
4 HR

Vehicles or Equip. Used

14 - BACKHOLE

Meter Readers

Employees on Job

K.M.

FINISHED
5 & 6

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 11-21-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

REPAIRED 1" GALV. MAIN BRAAK AT
S. 55TH ST - USED ONE 1" SS. REPAIR CLAMP
NEAR ROCK FOR BACKFILL IN ROAD

Ex. 6 (Personal Privacy)

Employees on Job

G.P. - F.P. - B.S. - K.M.
4HR 2HR 2HR

Vehicles or Equip. Used

2-3-14-BACKHOLE

Sewer Department

Address

BY-PASS PUMPS WITH BOTH 3" GAS PUMPS
AT 71ST Ex. 6 (Personal Privacy) VIOLET, ILLINOIS

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND, &
PERSHING - CYCLED PUMP AT CLINTON
CHECKED STATIONS

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - K.M.
5HR 6HR

Vehicles or Equip. Used

1-2-14-BACKHOLE

PULLED & CLEANED PUMP #1 BEHIND
STATION - DUE TO BACKUP AT CLARITA - NEEDED
TO RE-SET PUMP WHEN WELL GETS DOWN

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

T.C.

FINISHED

21-23-24-25-26

Areas - Read

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace

Date 1-21-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPAIRED 8" A.C. MAIN BREAK AT JEROME LN. - USED ONE 8" A.C. OVERSIZE S.S. REPAIR CLAMP - BACK FILLED WITH ROCK
Employees on Job G.F. <u>F.P. - B.S.</u> 4 HR	SPOIL & 4 BUCKETS CLEAN ROCK & TWO BUCKETS C-M-4 ROCK
Vehicles or Equip. Used	
2-3-14 - BACKHOLE	

Ex. 6 (Personal Privacy)

Sewer Department

Address	LOWERED FLOATBALLS THAT WERE RIDING ON SOLIDS CAUSING BACKUP AT SUPERIOR STATION
Jobs Completed	REPLACED BAN BREAKER FOR PUMP BEHIND
Employees on Job <u>F.P. - B.S.</u> 4 HR	NEED TO PULL PUMP BEHIND LAUREL - WELL IS FULL - SHUT OFF PUMP FOR TONIGHT
Vehicles or Equip. Used 14-2	NO BREAKER AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job K.M	FINISHED 7 & 8
Meters - Read	STARTED 9
Vehicles Used 1	

General Foreman

Frank J. Pace

Date 1-22-21

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATIONS	
Jobs Completed	REPAIRED A 6" C.I. MAIN BREAK AT BOND Ex. 6 (Personal Privacy) USED ONE 6" C.I. S.S. REPAIR CLAMP - BACKFILLED WITH SPOIL	
Employees on Job	C.F. - F.P. - B.S. - K.M. 6 HR 4 HR	
Vehicles or Equip. Used	-14- BACKHOE - 3	

Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 6 (Personal Privacy)	
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND & PARSHINE - CYCLED PUMP AT CLINTON	
Employees on Job	B.S. 4 HR	
Vehicles or Equip. Used	2	

Water Readers		
Employees on Job	K.M. 4 HR	FINISHED AREA 9 & 10
Meas - Read		
Vehicles Used	1	
General Foreman <u>Frank J. Pace</u>		

Date 1-25-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	w.o. / Locates
Jobs Completed	
Employees on Job	
G.F.	
Vehicles or Equip. Used	
3	

Water Department

Address	Bypass pumped 71 st pillbox
Jobs Completed	Cycled oakland, clinton, crockett & pershing
Employees on Job	
K.M.	
Vehicles or Equip. Used	
1	

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman R. McFall

Date 1-26-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	W.O. / Locates
Jobs Completed	
Employees on Job	
GF, T.C., B.S.	
Vehicles or Equip. Used	
2, 3	

Sewer Department

Address	Bypass pumped "the field" with 3" pump
Jobs Completed	checked stations Dipped out oakland + crockett stations w/ can.
Employees on Job	
K.M., B.S., T.C.	
Vehicles or Equip. Used	
1, 2, Backhoe	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman 

Date 1-27-21

Daily Job Sheet

Sheet of

Water Department

Comments	
Address	W.O. / Locates
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used G.F., B.S., T.C. 2, 3	

Water Department

Address	<div>Ex. 6 (Personal Privacy)</div> Pulled bypass pump and replaced pump
Jobs Completed	<div>Ex. 6 (Personal Privacy)</div> Pulled and cleaned rags from bypass pump and replaced
Employees on Job	Cycled oakland, crockett, pershing & clinton stations
Vehicles or Equip. Used B.S., T.C., R.M. BACKHOE, 1	Checked stations Reset pump @ <div>Ex. 7f (Water Infra.)</div>

Water Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman K. D. McCall

Date 1-28-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	HAULED IN 4 LOADS OF C-M & ROCK & GRADED TO RAISE ROAD INTO SNOWS
Jobs Completed	PUMPED WATER FROM AROUND STATION/ ROAD INTO SNOWS
Employees on Job F.P. - K.M.	
Vehicles or Equip. Used 1-14- BACKHOE	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-29-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

G.B. - F.P.
2HR 4HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

REPLACED RUBBER SHOCK ABSORBERS ON
3" WHACKER TRASH PUMP

Jobs Completed

PULLED BACK OFF OF PUMP & CLEANED OUT
RAGSI MOP FROM PUMP #1 AT
STATION FRONT

Ex. 7f (Water Infra.)

Employees on Job

K.M. - G.F. - F.P.
2HR 4HR

Vehicles or Equip. Used

1-5-14 - BACKHOE

CYCLED BLOWERS AT CROCKETS, OAKLAND,
PERSHING - CYCLED PUMP AT CLINTON

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Rose

Date 2-1-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATED MOUSSETTE LN. - POTHOLES MAIN OVER CANAL ON MOUSSETTE - MAIN IS ONLY ABOUT 12" 16" DEEP THERE
Jobs Completed	REPAIRED 4" C.I. MAIN BREAK AT COOPER - USED ONE 4" C.I. S.S. RING CLAMP - BACKFILLED ROAD WITH ROCK
Employees on Job F.P. - B.S. - G.F. GHR 7HR	
Vehicles or Equip. Used 1-3-2-BACKHOLE	

Ex. 6 (Personal Privacy)

Sewer Department

Address	PULLED BACK REE PUMP & CLEANED OUT RAGS AT Ex. 7f (Water Infra.) FRONT - PUMPING NOW & ALL STATIONS BACK ON
Jobs Completed	BY-PASS PUMPED WITH 2" GAS PUMP AT 71ST & Ex. 6 (Personal Privacy) VIOLET
Employees on Job K.M. - F.P. - G.F. JHR 1HR	CYCLED BLOWERS AT CROCKFITS, OAKLAND, PERSHING - CYCLED PUMP AT CLINTON
Vehicles or Equip. Used 5-1-3	DIPPED OUT STATION CANS AT OAKLAND & 82ND Ex. 7f (Water Infra.)

Meter Readers

Employees on Job	T.C.	FINISHED 11 @ 12
------------------	------	---------------------

Areas - Read

STARTED
13 - ONLY F.O.W.'S LEFT.

Vehicles Used

DROP OFF

General Foreman

Frank J. Rose

Date 7-2-21

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 442	
Vehicles or Equip. Used 3	

Water Department

Address	WORKED AT SNOWS STATION BUILDING ROAD, PUMPING DOWN LAKE, & SETTING PUMP IN WELL - 2 LOAD 2" CLEAN ROCK
Jobs Completed	ON ROAD
Employees on Job F.A. - B.S. - K.M.	
Vehicles or Equip. Used 9 T-14 - BOTH BACKHOES	

Water Readers

Employees on Job T.C.	FINISHED 15 & 17
--------------------------	---------------------

reas - Read

Vehicles Used DROP OFF	
---------------------------	--

General Foreman

Frank J. Pace

Date 2-2-21

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address

OVER TIME

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

JETTIED LINE IN Ex. 6 (Personal Privacy) OF
BATES - COULDN'T GET THROUGH
BLOCK

Jobs Completed

Employees on Job

D.T. - K.M.

Vehicles or Equip. Used

9-5

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 2-3-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REBUILT SERVICE Ex. 6 (Personal Privacy) PARK LANE USED ONE 3/4" P.V.C. BARB X 3/4" COMP.; ONE 3/4" X 3/4" COMP. ONE METER SHUT OFF, ONE METER COUPLING, 8" O.D. 3/4" COPPER, ONE 18" X 30" P.V.C. METER BOX
Employees on Job G.F. - F.P. - B.S. - K.M. GAR	REBUILT BACKSIDE Ex. 6 (Personal Privacy) BLUE WATER - USED ONE METER COUPLING, 8" O.D. 3/4" COPPER TUBING ONE 3/4" P.V.C. BARB X 3/4" COMP.
Vehicles or Equip. Used	
5-14-3-BACKHOE	

Water Department

Address	CHACKED SNOWS - PUMPING FULL PIPE BUT LAKE WATER STILL OVER WELL
Jobs Completed	JETTED LINE Ex. 6 (Personal Privacy) BATES TO RELIEVE BACKUP - (VILLAGE TRUCK)
Employees on Job F.P. - B.S. - K.M. Jare	BY-PASS PUMPED WITH 3" GAS PUMP AT RENOIS
Vehicles or Equip. Used	LOCATES
5-14-BACKHOE	

Meter Readers

Employees on Job

T.C.

FINISHED
14 & 17

Areas - Read

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace

Date 2-4-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. - B.S. - T.C. GHR 2me	
Vehicles or Equip. Used 3	

Water Department

Address	DUG DITCH AROUND SNOWS STATION TO DRAIN LAKE INTO CANAL - PUMP STILL PUMPING
Jobs Completed	CHECKED STATIONS CYCLED BLOWERS AT OAKLAND & CROCKETTS
Employees on Job B.S. - K.M. GHR	
Vehicles or Equip. Used 5 - BACKHOE	

Water Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky Pace

Water Department		Comments
Address	W.O./Locates	
Jobs Completed		
Employees on Job	B.S., G.F.	
Vehicles or Equip. Used	2, 3	
Sewer Department		
Address	Bypass pumped T1st	
Jobs Completed	Cycled stations (Crockett, Clinton, Pershing, Oakland)	
Employees on Job	Search for manholes between Helen Court & _____	
Vehicles or Equip. Used	2, 5	
Meter Readers		
Employees on Job	T.C.	
Meters - Read	19, 20, 21	
Vehicles Used		
General Foreman	K. M. Hall	

Ex. 6 (Personal Privacy)

Date 2-7-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address Ex. 6 (Personal Privacy) ADAMS SEWER BACKING UP / Customer problem, lines down

Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

HM

2

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Kurt McFall

Comments

Address	Locates
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used 5	

Water Department

Address	Bypass pumped 71 ST [REDACTED] violet stations Cycled stations (oakland, crockett, clinton, pershing)
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job	<u>Started & Finished</u>	<u>Started</u>
T.C	22, 23	24
Areas - Read		
22, 23, 24		
Vehicles Used		

General Foreman

Water Department

Comments

Address	Comments
	<u>W.O / Locates</u>
Jobs Completed	
Employees on Job	
GF	
Vehicles or Equip. Used	
3	

Water Department

Address	Checked stations Bypass pumped field in parkfield
Job Completed	Pulled and replaced Ex. 6 (Personal Privacy) station Pump
Employees on Job B.S, T.C, KM	Pulled and replaced clinton station pump
Vehicles or Equip. Used 2, 5, Backhoe	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Date 2-10-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	W.O./Locates
Jobs Completed	
Employees on Job	
G.F./B.S./T.C. Vehicles or Equip. Used	
1, 3	

Water Department

Address	Pumped T1 st pillbox Checked Stations
Jobs Completed	
Employees on Job K.M./T.C./B.S.	* Blower shot at crackett station *
Vehicles or Equip. Used 1, 5	

Water Readers

Employees on Job	started & Finished 24 & 26
Areas - Read	24+26
Vehicles Used	1

General Foreman W. McCall

Date 2-11-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	W.O. / Locates
Jobs Completed	Repaired main break @ Ex. 6 (Personal Privacy) & fall using 4" cast iron repair clamp
Employees on Job	
Vehicles or Equip. Used	
	3, 14, Backhoe

Water Department

Address	Pulled pump @ Bellevue station
Jobs Completed	checked stations
Employees on Job	
Vehicles or Equip. Used	
	Backhoe, 5, 1

Meter Readers

Employees on Job

Meters - Read

Vehicles Used

General Foreman *[Signature]*

Date 2-12-21

Daily Job Sheet

Sheet of

Water Department

Comments	
Address	repaired main break on Harvest 6" main. 1 clamp used, Ex. 6 (Personal Privacy)
Jobs Completed	W.D / Locates
Employees on Job	
GF, BS, TC	
Vehicles or Equip. Used	
Backhoe, 3,	

Sewer Department

Address	Replaced blower in Crockett station
Jobs Completed	Replaced pump in Belleview station Jetted a line on Bates per sewer backup @ Ex. 6 (Personal Privacy)
Employees on Job	
BS, I.C., KM	
Vehicles or Equip. Used	
Backhoe, 5, 14, Jet track	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman K. M. McCall

Date 2-12-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	mainbreak on harvest repair
Jobs Completed	
Employees on Job	
GF, BS, TC	
Vehicles or Equip. Used	
Bachlor, 3	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Date 2-16-21

Daily Job Sheet

Sheet of

Water Department

Comments	
Address	<div>Replaced broken shut off</div> <div>Turned water off</div> <div>mildred</div> <div>Ex. 6 (Personal Privacy)</div> <div>Ex. 6 (Personal Privacy)</div> <div>Christopher,</div> <div>Ex. 6 (Personal Privacy)</div>
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Meters - Read	
Vehicles Used	

General Foreman

Date _____

Daily Job Sheet

Sheet _____ of _____

Water Department

Comments

Address	W.O / Locates Repaired main break on Church Road w/ 4" clamp
Jobs Completed	
Employees on Job	
KM, BS, TC, GF	
Vehicles or Equip. Used	
3, 14, Backhoe	

Sewer Department

Address	Cycled stations on 73rd Ex. 7f (Water Infra.)
Jobs Completed	
Employees on Job	
KM, TC	
Vehicles or Equip. Used	
5	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman _____

Date 2-17-21 (Overtime)

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	Turn off / busted house line, turned meter off. <small>Ex. 6 (Personal Privacy)</small> [Redacted]
Jobs Completed	
Employees on Job	
GF	
Vehicles or Equip. Used	
3	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job	
Meters - Read	
Vehicles Used	

General Foreman John McCall

Date 2-18-21

Daily Job Sheet

Sheet of Water Department

Comments

Address

W.O./Locates

Ex. 6 (Personal Privacy)

Repaired main break on Lorraine
(2) 6" 501 used on repair w/ 3' water pipe

Jobs Completed

Employees on Job

T.C, B.S, KM, GF

Vehicles or Equip. Used

3, 14, Backhoe

Water Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

K. D. McCall

Date 2-19-21

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	Repaired main break @ Range lane using (1) 6" clamp cast iron. Ex. 6 (Personal Privacy)
Jobs Completed	Repaired main break @ Ex. 6 (Personal Privacy) fore out service line in process. Repaired main and service line using 4" CI clamp and 4" cast iron clamp with tap Repaired 2" main on Carol st using 6' of pvc and (2) 2" 501. (T.C, G.F, L.M)
Employees on Job	Repaired main break @ Range lane using (1) 6" cast iron clamp. (T.C, G.F, L.M) Ex. 6 (Personal Privacy)
Vehicles or Equip. Used	
Backhoe, 14, 3	

Sewer Department

Address	Cycled stations @ 73 rd , Oakland, east west Clinton & parking
Jobs Completed	
Employees on Job	
G.F	
Vehicles or Equip. Used	
3	


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Water Department

Comments

Address	Comments
	Finished repairing main breaks on Lynn, Carol, and Range & Sports.
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Date 2-20-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	Finished repairing mainbreak on Range
Jobs Completed	
Employees on Job	
GF, KM, TC	
Vehicles or Equip. Used	
3, 1H	

Ex. 6 (Personal Privacy)

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Readers

Employees on Job	
Meas - Read	
Vehicles Used	

General Foreman




Date 2-20-21

Daily Job Sheet

Sheet of

Water Department


Comments	
Address	Turn off @  Burst pipe per customer.
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman 

ate 2-22-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

W.O / Locates

Repaired mainbreak

Ex. 6 (Personal Privacy)

hercaine with

(1) 4" cast iron clamp

Jobs Completed

Employees on Job

GF, B.S, T.C, K.M

Vehicles or Equip. Used

Backhoe, 3, 14

sewer Department

address

Cycled stations (73^d, oakland, clinton + pershing)

Job Completed

Employees on Job

TC: KM

Vehicles or Equip. Used

5

meter Readers

Employees on Job

reas - Read

Vehicles Used

General Foreman

Kurt McCall

Date 2-22-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	Repaired main break Ex. 6 (Personal Privacy) Lorraine using 4" cast iron clamp. w.D. / Locates
Jobs Completed	Repaired mainbreak @ George St using 4" cast iron clamp.
Employees on Job	
Vehicles or Equip. Used	
	Backhoe, 14, 3

Sewer Department

Address	Cycled stations of 73rd, Oakland Clinton and Pershing stations.
Jobs Completed	Bypass pumped Renois (field)
Employees on Job	
Vehicles or Equip. Used	
	14, Backhoe

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman 

Date 2-23-21

Daily Job Sheet

Sheet of

Water Department

Comments

Address	W.O / Locates Ex. 6 (Personal Privacy) Missouri Ave; ran new line from main to service used 5' off copper,
Jobs Completed	(1) copper to copper, (1) shut off, (1) backside
Employees on Job	Restored service Ex. 6 (Personal Privacy) Williams; block in main used the tap screw to relieve.
Vehicles or Equip. Used	
Backhoe, 14, 3	

Water Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Water Readers

Employees on Job	
Teas - Read	
Vehicles Used	

General Foreman

Kurt McCall